



- Active Tucson Water DW Well — Surface Water Drainage
- Tucson Water DW Well Removed from Service
- CTPP Work Plan - Potential ADEQ Monitoring Well
- PFOA+PFOS >70 ppt**
- Approximate Groundwater Flow Direction

**Contours represent the estimated area of groundwater currently known to exceed the USEPA Health Advisory Level (HAL) of 70 parts per trillion (ppt) for the combined concentration of PFOA and PFOS

Central Tucson PFAS Project (CTPP)

PFAS = per- and polyfluorinated alkyl substances
PFOA = perfluorooctanoic acid
PFOS = perfluorooctane sulfonic acid
DW = Drinking Water

12/8/2020

