MINUTES OF THE **ENVIRONMENTAL PROTECTION COMMISSION M**EETING

April 20, 2021

Video and Teleconference

Approved by the Commission May 18, 2021

RECORD COPY

File Name Admin 01-05

Sender's Initials jzs

Table of Contents

Call to Order	2
Commissioners Present	2
Commissioners Absent	2
Approval of Agenda	2
Agenda Approved as Presented	2
Approval of Minutes	3
Approved as Presented	3
Monthly Reports	3
Information	3
Director's Remarks	3
Information	3
Contract with The University of Iowa – Beach Monitoring	3
Approved as Presented	3
Solid Waste Environmental Management System Program – Designation of Applicant	3
Approved as Presented	4
Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Easter Lake Watershed Project.	4
Approved as Presented	4
Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Black Hawk Lake Watershed	
Project	4
Approved as Presented	4
Adopted and Filed – Chapter 134 Underground Storage Tank Licensing and Certification Programs, Chapter 13	5
Technical Standards and Corrective Action Requirements for Owners and Operators of Underground	
Storage Tanks, and Chapter 136 Financial Responsibility for Underground Storage Tanks	4
Approved as Presented	5
General Discussion	5
Adjourn	
Adjourned	5

Meeting Minutes

CALL TO ORDER

The meeting of the Environmental Protection Commission (Commission or EPC) was called to order by Chairperson Ralph Lents at 9:30 a.m. on April 20, 2021, via a combination of in-person and video/teleconference attendees. A verbal roll call was conducted for Commissioners, Department of Natural Resources (DNR) staff, and members of the public. Jerah Sheets, Board Administrator, provided a tutorial of the Google Meet features.

COMMISSIONERS PRESENT

Rebecca Dostal Stephanie Dykshorn Amy Echard Lisa Gochenour Howard Hill Harold Hommes Ralph Lents Bob Sinclair

COMMISSIONERS ABSENT

Rebecca Guinn

David Scott, DNR Attorney, stated that the Commission was hosting this meeting via teleconference consistent with lowa Code section 21.8, which authorizes electronic meetings when meeting in person is impossible or impractical. The impractical standard was satisfied due to COVID-19-based medical directives to physically distance.

OFFICIAL MEETINGS OPEN TO PUBLIC (OPEN MEETINGS), § 21.8

Electronic meetings. 1. A governmental body may conduct a meeting by electronic means only in circumstances where such a meeting in person is impossible or impractical and only if the governmental body complies with all of the following: a. The governmental body provides public access to the conversation of the meeting to the extent reasonably possible. b. The governmental body complies with section 21.4. For the purpose of this paragraph, the place of the meeting is the place from which the communication originates or where public access is provided to the conversation. c. Minutes are kept of the meeting. The minutes shall include a statement explaining why a meeting in person was impossible or impractical. 2. A meeting conducted in compliance with this section shall not be considered in violation of this chapter. 3. A meeting by electronic means may be conducted without complying with paragraph "a" of subsection 1 if conducted in accordance with all of the requirements for a closed session contained in section 21.5.

APPROVAL OF AGENDA

Motion was made by Bob Sinclair to approve the agenda as presented. Seconded by Lisa Gochenour. The Chairperson asked for the Commissioners to approve the agenda by saying aye. There were no nay votes. Motion passes.

AGENDA APPROVED AS PRESENTED

APPROVAL OF MINUTES

Motion passes.

Motion was made by Amy Echard to approve the March 16, 2021, EPC minutes as presented. Seconded by Rebecca Dostal.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

APPROVED AS PRESENTED

MONTHLY REPORTS

- Division Administrator Ed Tormey summarized yesterday's educational tours in relation to newer lowa Code
 provisions for the facilities (e.g., fish confinement and animal truck wash facilities). The PFAS stakeholder
 engagement sessions have begun with public drinking water supplies.
- The monthly reports have been posted on the DNR's website under the appropriate meeting month: http://www.iowadnr.gov/About-DNR/Boards-Commissions

INFORMATION

DIRECTOR'S REMARKS

• Director Kayla Lyon recognized the importantance of the Commissioners' role for rulemaking, appeals, budgetary matters, and more. The Director recognized Rebecca Guinn, Howard Hill, and Bob Sinclair for their contributions to Iowa. Ed Tormey expressed his appreciation for the Commission's work and their investment in Iowa's air, land, and water quality. Howard Hill expressed his appreciation for the dedication and professionalism of DNR staff and particularly DNR's field staff. Bob Sinclair praised the DNR for being able to do more with less, for the continuous improvement projects to make work simpler or more efficient, and for assisting companies to locate and grow in Iowa.

Information

CONTRACT WITH THE UNIVERSITY OF IOWA - BEACH MONITORING

Roger Bruner presented a contract with the University of Iowa. He summarized the reporting requirements for the EPA funding and evolution of the monitoring program approach since 2006.

Public Comments – None Written Comments – None

Motion was made by Harold Hommes to approve the agenda item as presented. Seconded by Stephanie Dykshorn.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

SOLID WASTE ENVIRONMENTAL MANAGEMENT SYSTEM PROGRAM — DESIGNATION OF APPLICANT

Laurie Rasmus presented recommendations for the Solid Waste Environmental Management System (EMS) Program. Currently there are 14 EMS participants out of the 44 planning areas. The application would add the Mahaska County Solid Waste Management Commission as a participant in the Solid Waste EMS Program.

Public Comments – None Written Comments – None

Motion was made by Stephanie Dykshorn to approve the agenda item as presented. Seconded by Rebecca Dostal.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

CONTRACT WITH IOWA DEPARTMENT OF AGRICULTURE AND LAND STEWARDSHIP (IDALS) — EASTER LAKE WATERSHED PROJECT

Kyle Ament presented a contract for Easter Lake Watershed. He summarized the contracting approach for overlapping agreements with grant funding cycles, longer time frame projects, and working with unpredictable weather.

Public Comments – None Written Comments – None

Motion was made by Harold Hommes to approve the agenda item as presented. Seconded by Stephanie Dykshorn.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

CONTRACT WITH IOWA DEPARTMENT OF AGRICULTURE AND LAND STEWARDSHIP (IDALS) — BLACK HAWK LAKE WATERSHED PROJECT

Kyle Ament presented a contract for Black Hawk Lake Watershed. This Contract will provide funding and support for the ongoing Black Hawk Lake Watershed Project (Project). The Project is contracted through IDALS and carried out by the Sac County Soil and Water Conservation District.

Public Comments – None Written Comments – None

Motion was made by Bob Sinclair to approve the agenda item as presented. Seconded by Rebecca Dostal. Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye. Motion passes.

APPROVED AS PRESENTED

ADOPTED AND FILED — CHAPTER 134 UNDERGROUND STORAGE TANK LICENSING AND CERTIFICATION PROGRAMS, CHAPTER 135 TECHNICAL STANDARDS AND CORRECTIVE ACTION REQUIREMENTS FOR OWNERS AND OPERATORS OF UNDERGROUND STORAGE TANKS, AND CHAPTER 136 FINANCIAL RESPONSIBILITY FOR UNDERGROUND STORAGE TANKS James Gastineau presented the Underground Storage Tanks proposed final rules. He summarized the multiple revisions completed since the original NOIA was presented to the Commission. These revisions were made at the request of various stakeholders and primarily focused on training requirements for inspectors. Also, Mr. Gastineau noted that the proposed rule was necessary to make the DNR program consistent with recent federal regulation changes which will allow the DNR to maintain its State Program Approval (SPA) from the US EPA. Mr. Gastineau answered questions from Commissioners concerning the walk-through inspection form revisions, whether above-ground storage tanks (ASTs) are subject to these rules, and whether the DNR was concerned about unknown, unregistered underground storage tanks operating in the state.

Public Comments – Brian Wiegert of PMMIC Insurance requested a revision to the commencement date for regulated entities to conduct certain walk-through inspections.

Written Comments – Freedom Malik asked for tank owners to have insurance plans to handle incidents rather than taxing the consumer.

Motion was made by Howard Hill to approve the agenda item as presented. Seconded by Stephanie Dykshorn.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

GENERAL DISCUSSION

- Commissioners were reminded of the Personal Financial Disclosure Reporting deadline of April 30.
- Commissioners were reminded of the Election of Officers during the May 2021 meeting.
- Jerah Sheets provided logistic details for the upcoming EPC business meetings and received feedback from Commissioners for improvements.

ADJOURN

Chairperson Lents thanked the Commission and DNR for the educational tour. The Chairperson adjourned the Environmental Protection Commission meeting at 11:05 am on April 20, 2021.

Motion was made by Harold Hommes to adjourn. Seconded by Stephanie Dykshorn. The Chairperson asked for the Commissioners to approve the agenda by saying aye. There were no nay votes. Motion passes.



Sheets, Jerah <jerah.sheets@dnr.iowa.gov>

Financial responsibility for USTs

1 message

Freedom F. Malik <FMalik@dbq.edu>

Thu, Apr 15, 2021 at 8:45 PM

To: "Jerah.Sheets@dnr.iowa.gov" < Jerah.Sheets@dnr.iowa.gov>

Hello,

I would like to submit for the public comments for the April 20th meeting one thing about the new rules pertaining to the USTs. I understand the UST board will be dissolved as the funds from the fuel tax are removed and replaced with an insurance policy that all owner/operators of underground storage tanks have to have. I think that forcing the owners to have an insurance plan in place in case of bobbing or explosion or inevitable leaking is a much more fiscally responsible action. Taxing the people being given a product to clean up the product is not a responsible idea. These tanks contain extremely dangerous materials when they are mishandled and no one who can't properly take care of AND pay to clean up after them should have any. Make them have insurance just like people have to have insurance on our mortgages and our houses and our cars and our health and our lives. Not all of those insurances are particularly useful or wanted but in this case the alternative is we have to pay for him or her so make them pay to clean up their own mess and maybe they will be less likely to make them in the future. Thank you.

Freedom Malik

Humane Policy Volunteer Leader Pronouns: she/her Iowa Congressional District 2

fmalik@dbq.edu P 563-579-0163 humanesociety.org

Fight for all animals. The Humane Society of the United States is the nation's most effective animal protection organization, fighting for all animals for more than 65 years. To support our work, please make a monthly donation, give in another way or volunteer.



Environmental Protection Commission

Tuesday, April 20, 2021

Teleconference: (240) 794-2779 PIN: 934 190 235# Video Conference: https://meet.google.com/pcd-ryjg-uoa

Monday, April 19, 2021

1:00 PM – EPC Educational Tour – Reservations required by April 15th by calling Jerah Sheets at 515-313-8909 or emailing jerah.sheets@dnr.iowa.gov

Tuesday, April 20, 2021 9:30 AM – EPC Business Meeting

If you are unable to attend the business meeting, comments may be submitted to Jerah Sheets at <u>Jerah.Sheets@dnr.iowa.gov</u> or 502 East 9th St, Des Moines IA 50319 up to one day prior to the business meeting for the public record.

	, for the public record.	
1	Approval of Agenda	
2	Approval of the Minutes (Packet Page 3)	
3	Monthly Reports (Packet Page 9)	Ed Tormey (Information)
4	Director's Remarks	Kayla Lyon (Information)
5	Contract with The University of Iowa – Beach Monitoring (Packet Page 23)	Roger Bruner (Decision)
6	Solid Waste Environmental Management System Program – Designation of Applicant (Packet Page 32)	Laurie Rasmus (Decision)
7	Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Easter Lake Watershed Project (Packet Page 33)	Kyle Ament (Decision)
8	Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Black Hawk Lake Watershed Project (Packet Page 35)	Kyle Ament (Decision)
9	Adopted and Filed – Chapter 134 Underground Storage Tank Licensing and Certification Programs, Chapter 135 Technical Standards and Corrective Action Requirements for Owners and Operators of Underground Storage Tanks, and Chapter 136 Financial Responsibility for Underground Storage Tanks (Packet Page 37)	James Gastineau (Decision)
10	 General Discussion Personal Financial Disclosure Election of Officers May 2021 	
11	Items for Next Month's Meeting	
	Tuesday, May 18, 2021 – EPC Business Meeting Tuesday, June 15, 2021 – EPC Business Meeting	
	Tuesday, June 15, 2021 – EPC Business Meeting	


For details on the EPC meeting schedule, visit http://www.iowadnr.gov/About-DNR/Boards-Commissions

¹Comments during the public participation period regarding proposed rules or notices of intended action are not included in the official comments for that rule package unless they are submitted as required in the Notice of Intended Action.

Any person participating in the public meeting and has special requirements such as those related to mobility or hearing impairments should contact the DNR or ADA Coordinator at 515-725-8200, Relay Iowa TTY Service 800-735-7942, or webmaster@dnr.iowa.gov, and advise of specific needs.

Utilize bookmarks to transition between agenda items or progress forwards and backwards in the packet page by page with the Packet Page number on the agenda.

The upper right-hand corner will indicate the Agenda Item Number and the page of the agenda item.



MINUTES OF THE ENVIRONMENTAL PROTECTION COMMISSION MEETING

March 16, 2021

Video and Teleconference

Approved by the Commission TBD

RECORD COPY

File Name Admin 01-05

Sender's Initials jzs

Table of Contents

Call to Order	2
Commissioners Present	2
Commissioners Absent	2
Approval of Agenda	2
Agenda Approved as Presented	2
Approval of Minutes	3
Approved as Presented	3
Monthly Reports	3
Information	3
Director's Remarks	3
Information	3
Clean Water and Drinking Water State Revolving Loan Fund (SRF) – FY 2021 Intended Use Plan Fourth Quarter	
Update	
Approved as Presented	3
Solid Waste Alternatives Program – Contract Recommendations	
Approved as Presented	4
Contract with The University of Iowa - SHL - Lakes	
Approved as Presented	
Memorandum of Understanding with Iowa Department of Administrative Services (DAS)	
Approved as Presented	
Air Quality – Fiscal Year 2022 Draft Budget Review	4
Information	4
PFAS Informational Presentation	
Information	5
Antidegradation Informational Presentation	
Information	
General Discussion	5
Adjourn	
Adjourned	5

Meeting Minutes

CALL TO ORDER

The meeting of the Environmental Protection Commission (Commission or EPC) was called to order by Chairperson Ralph Lents at 9:30 a.m. on March 16, 2021, via video and teleconference. A verbal roll call was conducted for Commissioners, DNR staff, and members of the public. Jerah Sheets, Board Administrator, provided a tutorial of the Google Meet features.

COMMISSIONERS PRESENT

Rebecca Dostal Stephanie Dykshorn Amy Echard Lisa Gochenour Howard Hill Harold Hommes Ralph Lents Bob Sinclair

COMMISSIONERS ABSENT

Rebecca Guinn

Tamara McIntosh, DNR General Counsel, stated that the Commission is hosting this meeting via teleconference consistent with Iowa Code section 21.8, which authorizes electronic meetings when meeting in person is impossible or impractical. The impractical standard was satisfied due to COVID-19-based medical directives to physically distance.

OFFICIAL MEETINGS OPEN TO PUBLIC (OPEN MEETINGS), § 21.8

Electronic meetings. 1. A governmental body may conduct a meeting by electronic means only in circumstances where such a meeting in person is impossible or impractical and only if the governmental body complies with all of the following: a. The governmental body provides public access to the conversation of the meeting to the extent reasonably possible. b. The governmental body complies with section 21.4. For the purpose of this paragraph, the place of the meeting is the place from which the communication originates or where public access is provided to the conversation. c. Minutes are kept of the meeting. The minutes shall include a statement explaining why a meeting in person was impossible or impractical. 2. A meeting conducted in compliance with this section shall not be considered in violation of this chapter. 3. A meeting by electronic means may be conducted without complying with paragraph "a" of subsection 1 if conducted in accordance with all of the requirements for a closed session contained in section 21.5.

APPROVAL OF AGENDA

Motion was made by Amy Echard to approve the agenda as presented. Seconded by Bob Sinclair. The Chairperson asked for the Commissioners to approve the agenda by saying aye. There were no nay votes. Motion passes.

AGENDA APPROVED AS PRESENTED

APPROVAL OF MINUTES

Motion passes.

Motion was made by Lisa Gochenour to approve the February 16, 2021, EPC minutes as presented. Seconded by Harold Hommes.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

APPROVED AS PRESENTED

MONTHLY REPORTS

- Division Administrator Ed Tormey informed the Commission he would be attending the Environmental Council of the States' national virtual meeting and summarized a few of the major speakers and topics.
- The monthly reports have been posted on the DNR's website under the appropriate meeting month: http://www.iowadnr.gov/About-DNR/Boards-Commissions

INFORMATION

DIRECTOR'S REMARKS

Director Kayla Lyon summarized for the Commission some of the Environmental Services Division's (ESD) successes from the past year while teleworking. Performance measures are continually reviewed and adjusted to remain effective. The agency continues to evaluate each facility's ability to safely accommodate returning staff and customers. The legislative session has bottle deposit bills being reviewed.

INFORMATION

CLEAN WATER AND DRINKING WATER STATE REVOLVING LOAN FUND (SRF)— FY 2021 INTENDED USE PLAN FOURTH QUARTER UPDATE

Theresa Enright presented the fourth quarter of the SRF's Intended Use Plan and explained the respective programs for loan forgiveness and disadvantaged communities.

Public Comments – None Written Comments – None

Motion was made by Bob Sinclair to approve the agenda item as presented. Seconded by Stephanie Dykshorn.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

SOLID WASTE ALTERNATIVES PROGRAM - CONTRACT RECOMMENDATIONS

Tom Anderson presented contract recommendations for the Solid Waste Alternatives Program and explained the repayment timeline based on the project and value of the loan.

Public Comments – None Written Comments – None

Motion was made by Harold Hommes to approve the agenda item as presented. Seconded by Amy Echard.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

CONTRACT WITH THE UNIVERSITY OF IOWA - SHL - LAKES

Roger Bruner presented a contract with The University of Iowa. Due to Covid-19, only 17 of the 25 lakes were monitored in 2020. Of the listed lakes, a core group are monitored every year and another set of lakes are monitored on a rotating schedule.

Public Comments – None Written Comments – None

Motion was made by Bob Sinclair to approve the agenda item as presented. Seconded by Stephanie Dykshorn.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

MEMORANDUM OF UNDERSTANDING WITH IOWA DEPARTMENT OF ADMINISTRATIVE SERVICES (DAS)

Steve Konrady presented a contract to implement watershed best practices. Additional examples of best practices from DAS were provided. Commissioners commended the DNR for demonstrating contributions from all applicants on this project.

Public Comments – None Written Comments – None

Motion was made by Lisa Gochenour to approve the agenda item as presented. Seconded by Harold Hommes.

Bob Sinclair-aye, Lisa Gochenour-aye, Howard Hill-aye, Rebecca Guinn-absent, Stephanie Dykshorn-aye, Amy Echard-aye, Harold Hommes-aye, Rebecca Dostal-aye, and Ralph Lents-aye.

Motion passes.

APPROVED AS PRESENTED

AIR QUALITY - FISCAL YEAR 2022 DRAFT BUDGET REVIEW

Wendy Walker presented an informational item on the Air Quality budget. Catharine Fitzsimmons, Bureau Chief, provided historical and projected revenue and expense examples, along with how the indirect rate compares with other government entities. There is no change to the fees so the Air Quality budget will not be brought back to the Commission for a decision. Commissioners expressed positive stories of the service the Air Quality team provides to their customers.

Public Comments – None	
Written Comments - None	
	Information

Rebecca Dostal left for the remainder of the meeting.

PFAS INFORMATIONAL PRESENTATION

Roger Bruner provided a presentation summarizing per- and polyfluoroalkyl substances (PFAS) uses over the past 80 years, including an overview of more recent research on long-term exposure that resulted in health advisories. The DNR's PFAS action plan addresses PFOA and PFOS in drinking water and provides a timeline of actions for the remainder of the year. EPA currently has two certified methods for analytical testing of PFAS in drinking water. There is technology to remove the compound from drinking water. In comparison to other parts of the nation, lowa doesn't have industries that produce or use these compounds in similar quantities. Through the action plan's scheduled sampling of drinking water at lowa's public water supplies, the state will know more to determine lowa's risk.

Public Comments – None		
Written Comments – None		
	Information	

ANTIDEGRADATION INFORMATIONAL PRESENTATION

Katie Greenstein provided a presentation on the antidegradation policy and methods. This included defining water quality standards of designated uses and numeric and narrative criteria. States have the responsibility to certify whether a federal project meets the state's water quality standards. The review process includes social and economic importance. Examples of recent state 401 water quality certification approvals were provided to the Commission.

Public Com	ments – None		
Written Co	mments – None		
		Information	

GENERAL DISCUSSION

- Jerah Sheets provided logistic details and travel reimbursement reminders for the upcoming EPC educational tours and business meetings.
- Commissioners were reminded of the Personal Financial Disclosure Reporting deadline.

ADJOURN

Chairperson Lents thanked the Commission and DNR for their efforts. The Chairperson adjourned the Environmental Protection Commission video and teleconference meeting at 12:30 pm on March 16, 2021.

Motion was made by Bob Sinclair to adjourn. Seconded by Harold Hommes. The Chairperson asked for the Commissioners to approve the agenda by saying aye. There were no nay votes. Motion passes.

ll .	ADIOLIDAED
ll .	ADJOURNED

Item 3, Page 1 of 14

	Monthly Waiver Report								
	March 2021								
Item #	DNR Reviewer	Facility/City	Program	Subject	Decision	Date	Agency		
110111 //	211111101101101		l i ogi a	Waiver of Initial Stack Test			/ igosy		
				Requirement for infrared flash-off tunnel					
1	Rachel Quill	Windsor Windows & Doors	Air Quality Construction Permits	(EP-4, Permit No. 21-A-102).	Approved	2/23/21	21aqv030		
				Waiver of Initial Stack Test					
2	Priyanka Painuly	Douds Stone Inc.	Air Quality Construction Permits	Requirement.	Approved	2/23/21	21aqv031		
	•			A variance from requirements to					
				construct conflicting storm sewers of					
				water main material where separations					
				cannot be obtained by instead					
				constructing storm sewers of corrugated					
		JOHNSTON MUNICIPAL WATER		HDPE with ASTM D3212 (10.8 psi)					
3	Matt Phoenix	SUPPLY	Water Supply Construction (WC)	gaskets.	Approved	2.25.21	21wcv032		
		Cemstone Concrete Materials - Sac		Waiver of Initial Stack Test					
4	Ashley Dvorak	City	Air Quality Construction Permits	Requirement.	Approved	2.25.21	21aqv033		
_		l	1 2 2	Waiver of Initial Stack Test					
5	Rachel Quill	Iowa Spring Manufacturing	Air Quality Construction Permits	Requirement.	Approved	2.26.21	21aqv034		
				Waiver of Initial Stack Test	l				
6	Rachel Quill	Seneca Foundry, Inc.	Air Quality Construction Permits	Requirement.	Approved	3.1.21	21aqv035		
_	B. Committee Committee	0.1		Request to demolish and open burn	D	0.4.04	04		
7	Brian Hutchins	City of Seymour	AQ		Denied	2.1.21	21aqv036		
8	Julie Duke	Typen Freeh Meets	40	Request to increase flow rate o protect		2.18.21	04 0 00 10 27		
- 8	Julie Duke	Tyson Fresh Meats	AQ	lagoon cover.	Approved	2.18.21	21aqv037		
9	Danjin Zulic	University of Iowa	Air Quality Construction Permits	Waiver of Initial Stack Test	Approved	3.4.21	21aqv038		
	Danjin Zulic	Offiversity of lowa	All Quality Constituction Fermits	Requirement. Allow a water main (WM) to cross under	Approved	3.4.21	2 Taqv030		
				a sanitary sewer (SAN) that was cured					
				in place (CIPP), instead of replacing the					
				SAN with WM materials, while					
				maintaining 18 inches of vertical					
10	Sara Smith, P.E.	Indianola Municipal Utilities	Water Supply Construction (WC)	clearance between SAN and WM.	Approved	3.4.21	21wcv039		
				Waiver of Initial Stack Test	777				
11	Rachel Quill	IPL - Lansing Generating Station	Air Quality Construction Permits	Requirement.	Approved	3.8.21	21aqv040		
			İ	Vermeer has requested an 6 month					
				extension to the testing deadline of		1			
				construction permit 19-A-665. New					
				equipment will not reach capacity by		1			
12	Mark Fields	Vermeer Manufacturing Company	AQ	test due date of 6/5/21.	Approved	3.5.21	21aqv041		
				In lieu of in-situ permeability tests every					
				five years, in accordance with 567 IAC					
				Chapter 114.21(2)"d", a well recharge		1			
rate evaluation be performed biennially,									
				similar to that required in 567 IAC		1			
13	Nina M. Booker	Plymouth County Sanitary Landfill	SD	Chapter 113.10(2)"f"(4).	Approved	3.10.21	21sdv042		

Item 3, Page 2 of 14

						Item 3, Pa	ge 2 of 14
				Request to increase our biogas flowrate			
				going to the flare from 550 to 600			
				standard cubic feet per minute to	ı		
				protect the lagoon covers integrity. This			
				is temporary until lagoon covers are at			
14	Julie Duke	Tyson Fresh Meats	AQ	normal height	Approved	2.18.21	21aqv043
				Waiver of Initial Stack Test			
15	Danjin Zulic	Tri-Mark Corporation	Air Quality Construction Permits	Requirement.	Approved	3.12.21	21aqv044
				Waiver of Initial Stack Test			
16	Rachel Quill	Pella Corporation - Pella Division	Air Quality Construction Permits	Requirement.	Approved	3.12.21	21aqv045
				A variance from requirements to			
				construct conflicting storm sewers of			
				water main material where horizontal			
				separations cannot be obtained by			
				instead constructing the storm sewers			
17	Matt Phoenix	INDEPENDENCE WATER DEPT	Water Supply Construction (WC)	of RCP with gaskets.	Approved	3.16.21	21wcv046
				A variance from requirements to			
				construct conflicting storm sewers of	:		
				water main material where horizontal			
				and crossing separations cannot be			
				obtained by instead constructing the			
18	Matt Phoenix	Eldridge Water Supply	Water Supply Construction (WC)	water main of DIP w/ nitrile gaskets.	Approved	3.19.21	21wcv047
				A variance from requirements to			
				construct conflicting storm sewers of	:		
				water main material where horizontal			
				and crossing separations cannot be			
				obtained by instead constructing the			
19	Matt Phoenix	Eldridge Water Supply	Water Supply Construction (WC)	water main of DIP w/ nitrile gaskets.	Approved	3.19.21	21wcv048
		Cemstone Concrete Materials - Sac		Waiver of Initial Stack Test			
20	Ashley Dvorak	City	Air Quality Construction Permits	Requirement.	Approved	3.18.21	21aqv049
21	Julie Duke	SSAB lowa, Inc	AQ	Four week trail of new ladle preheater	Approved	3.18.21	21aqv050
		,		A variance from requirements to			
				construct conflicting storm sewers of			
				water main material where sewer/water			
				main separations cannot be obtained by			
				instead constructing the water main of			
22	Matt Phoenix	Council Bluffs Water Works	Water Supply Construction (WC)	DIP w/ nitrile gaskets.	Approved	3.23.21	21wcv051
		Southwest Iowa Renewable Energy,	, , ,	Waiver of Initial Stack Test			
23	Nate Tatar	LLC	Air Quality Construction Permits	Requirement.	Approved	3.24.21	21aqv052
		Cemstone Concrete Materials - Sac	j	Waiver of Initial Stack Test			,
24	Ashley Dvorak	City	Air Quality Construction Permits	Requirement.	Approved	3.25.21	21aqv053
	•	Ajinomoto Health and Nutrition North		Waiver of Initial Stack Test			
25	Michael Hermsen	Ame	Air Quality Construction Permits	Requirement.	Approved	3.25.21	21aqv054
				A variance from requirements to			
				construct conflicting storm or sanitary			
				sewers of water main material and			
				provide 18" of separation by instead			
				constructing water main of DIP w/ nitrile			
				gaskets or placing the water main in a			
26	Matt Phoenix	Des Moines Water Works	Water Supply Construction (WC)	sealed casing pipe.	Approved	3.26.21	21wcv055
	1	<u> </u>	117	rocalca casilla pipo.			1

Item 3, Page 3 of 14

				This private transfer station is seeking a			
				waiver to commence operations without			
				the installation of a secure perimeter			
				fence. The dense timber surrounding			
				the facility provides a natural barrier to			
		Kluesner Sanitation LLC Transfer		discourage any illegal dumping activity.			
27	Chad Stobbe	Station	SD - Sanitary Disposal		Approved	3.25.21	21sdv056

IOWA DEPARTMENT OF NATURAL RESOURCES LEGAL SERVICES BUREAU

DATE: April 2021

TO: Environmental Protection Commission

FROM: Tamara McIntosh

SUBJECT: Attorney General Referrals (November 25, 2020 – March 25, 2021)

Name, Location and Region Number	Program	Alleged Violation	DNR Action	Status	Date
Abatement Specialties, LLC Cedar Rapids (1)	Air Quality	Asbestos	Referred to Attorney General	Referred Petition Filed Discovery Requests Served on AS Settlement Agreement to enter into Consent Decree	2/16/16 7/18/19 10/16/19 8/5/20
City of Sioux City (3)	Wastewater		Referred to Attorney General	Referred	6/27/16
61 Park LLC Muscatine (6)	Wastewater Solid Waste	NPDES violations; Open Dumping	Referred to Attorney General	Referred	3/20/18
JB2 and Phoenix Newton (5)	Air Quality	Asbestos	Referred to Attorney General	Referred Petition Filed JB2 Services, JB2 Environmental, and Robert Peret served Consent Decree w/Phoenix Approved-\$75,000 civil penalty & Injunctive relief Answer filed by Robert Peret Application for Default filed against JB2 and JB2 Env. Default granted against JB2 and JB2 Env. Motion for Judgment on Default against JB2 and JB2 Env. Order for Judgment against JB2 and JB2 Env. (\$150,000 civil penalty; injunctive relief) Trial Sched Conf. w/Peret- continued; rescheduled	2/19/19 4/6/20 4/15/20 4/17/20 5/20/20 5/20/20 5/21/20 5/22/20 5/22/20 7/7/20 12/8/20
Steven Kerns Clearfield (4)	Animal Feeding Operation	Manure release; Composting dead animals	Referred to Attorney General	Trial scheduled (2 days) Referred Tolling Agreement through August 17, 2020 Consent Decree Approved - \$23,000 penalty and injunctive relief to be repaid over 2 years	11/4-5/21 10/15/19 9/4/20
John Goldsmith Sergeant Bluff (3)	Solid Waste	Open Burning; Open Dumping	Referred to Attorney General	Referred Petition Filed Defendant out of state/unable to be served Voluntary Motion to Dismiss by Plaintiff – to wait until Defendant returns	10/16/18 1/31/19 2/19/19 3/15/19

Item 3, Page 5 of 14

				Item 3, Page 5 o	f 14
				Petition Filed	3/4/20
				Motion for Judgment on Default	4/22/20
				Granted	
				Motion to Set Aside Judgment	5/12/20
				Hearing on Motion	6/1/20
				Default Judgment Set Aside	
				Trial set for March 31, 2020	
JDog and Justin Pollard	Solid Waste	Open Dumping;	Referred to	Referred	6/16/20
Cambridge (5)		Open Burning	Attorney	Petition Filed	10/1/20
2 , ,			General	Answer	10/14/20
				Court Ordered Stay due to Pollard	11/3/20
				filing for bankruptcy	
				Court Granted Relief From Stay	2/25/21
				_	
Iowa Grocery Industry	Land Quality	Petition for	DNR Named	Petition Filed	10/27/20
Association		Judicial Review	Respondent	Answer Filed	11/09/20
Des Moines (5)		Bottle/Can		Respondent's Brief Filed	1/15/21
		Redemption		Court Hearing on Petition	1/29/21
		Rules		_	
		(Convenience			
		Standard)			
Iowa Grocery Industry	Land Quality	Petition for	DNR Named	Petition Filed	1/22/21
Association		Judicial Review	Respondent	Answer Filed	2/15/21
Des Moines (5)		Bottle/Can		Respondent's Brief due	6/11/21
		Redemption			
		Rules			
		(distributors)			
Iowa Grocery Industry	Land Quality	Petition for	DNR Named	Petition Filed	12/16/20
Association		Judicial Review	Respondent	Answer Filed	1/4/21
Des Moines (5)		Bottle/Can		Respondent's Brief due	4/16/21
		Redemption			
		Rules (Equal			
		Enforcement)			
Batey Ltd. and Old	Forestry	Timber Bond	Referred to	Petition Filed	1/22/21
Republic Surety		Violation	Attorney		
			General		

IOWA DEPARTMENT OF NATURAL RESOURCES LEGAL SERVICES BUREAU

DATE: April 2021

TO: Environmental Protection Commission

FROM: Tamara McIntosh

SUBJECT: Contested Cases (November 25, 2020 – March 25, 2021)

Date Received	Name Of Case	Action Appealed	Program	Assigned Attorney	Status
6/10/13	Mike Jahnke	Dam Application	FP	Schoenebaum	Hearing held 7/30/14. ALJ upheld the permit issued by the Department. Mr. Jahnke appealed but on 11/3/14 he asked that his appeal be put on hold until April, 2015. For various reasons has asked that the appeal be postponed. Sept. 2017 – Mr. Jahnke called and asked that his appeal be put on hold until Spring 2018. September 2018 Mr. Jahnke called and asked that the matter be postponed to Spring '19. Jan. 2019 no changes, matter was postponed to Spring 2019. April 2019 – no change; matter postponed to Spring 2019. July 2019 – No changes. 10/25/19 – Mr Jahnke has called many times to discuss his ongoing medical problems and his families' each time he asks for the matter not to be placed on the agenda and asks for a delay. He again asked for a delay until Spring. 1/24/20 – Mr. Jahnke called again and explain ongoing medical problems and that he cannot be present for a winter meeting and asked that the matter continue to be delayed. 5/25/20 – No changes 11/18/20 – no changes 3/29/21 – no changes
6/27/16	Plum River Fault Line Golf Inc.; Meadowcrest Farms, Ltd.	Order/Penalty	WS	Schoenebaum	Assigned to new attorney. negotiating. August 2017 - Settlement offers mailed. April 2018 – Dept sent an updated settlement offer. 1/24/20 – No changes since July 2019 (7/19 and 10/25/19) 5/25/20 – No changes 11/18/20 – No Changes (new referral forthcoming) 3/29/21 – no changes

Item 3, Page 7 of 14

			I	1	Item 3, Page 7 of 14
4/27/16	City of Waterloo	Permit Issuance	WW	Poppelreiter (Crotty)	Disputed permit limits were stayed on 5/18/16. DNR and city have agreed to delay setting a hearing while city completes facility improvements. Improvements expected to be completed 9/18. Then will re-evaluate if hearing is needed. DNR has agreed to postpone setting a hearing date until Waterloo has completed facility repairs which it believes will resolve the appeal. Repairs are expected to be complete by Spring 2019. Jan. 2019 - DNR agreed to postpone setting a hearing date .April 2019 - Facility repairs are complete, facility will evaluate efficacy of repairs in summer 2019, with a new permit to be issued. 10/25/19 - City completed repairs and conducted hydrological testing. Internal DNR review of the testing will result. Will discuss with Waterloo's attorney after DNR review. 1/24/20 - Meeting between DNR and the City scheduled for February 4, 2020 to discuss their progress. 5/25/20 - No Changes 11/18/2020 - Ongoing negotiations with the City. Hearing is set for January 11. However, after excellent discussions with the City/Mayor, anticipation is for the case to settle. 3/25/2021 - Final stages of negotiations. We anticipate a negotiated 2021 NPDES permit going to public comment within a few weeks. The parties will jointly reevaluate the litigation of the 2016 permit once comments are received.
11/9/17	IA Regional Utilities Association	Permit Issuance	WW	Poppelreiter (Crotty)	10/25/18 –Negotiating before setting a hearing date. A final meeting with facility's new director is expected before the end of 2018. 01/24/19 –Negotiating before setting a hearing date. Meeting with permittee 1/24/19. Permittee must discuss options with Board. Decision from Permittee on whether to withdraw appeal or move forward with hearing is expected in Spring 2019. April 2019 – Waiting on permittee to decide whether to set a hearing or withdraw

Item 3, Page 8 of 14

	appeal. 10/25/19 – Permittee and DNR still in negotiations re: engineering proposals at the facility. No change in the appeal status. 1/24/20 – Finalizing the report on the progress they have made and will meet with DNR's Wastewater staff in February to discuss settlement options. 5/25/20 – No Changes
	11/18/2020 - Ongoing negotiations with IRUA. No hearing set as yet. Looking into alternative solutions. 3/25/2021 - Continuing discussions with IRUA. Both parties are
	interested in non-litigation solutions. No hearing set.

//// /

IOWA DEPARTMENT OF NATURAL RESOURCES LEGAL SERVICES BUREAU

DATE: April 2021

TO: Environmental Protection Commission

FROM: Tamara McIntosh

SUBJECT: Enforcement Report Update (November 20, 2020 – March 25, 2021)

The following new enforcement actions were taken during this reporting period:

Individual/Entity (County)	Program	Alleged Violation	Type of Order/Action	Penalty Amount Due	Date
	Animal				
	Feeding				
Schmit Pork, L.C.	Operation	Construction permit	Consent	\$5,000.00	11/23/20
	Animal				
	Feeding				
Buch Farms, LLC	Operation	Prohibited discharge	Consent	\$750.00	11/23/20
		Operator			
Kendall Kipp	Water Supply	Certification	Consent	0	11/23/20
	Animal				
	Feeding	Manure			
Rausch Feedlot Co.	Operation	Management Plan	Consent	\$3,000.00	11/30/20
		Open Burning and			
	Air Quality;	Improper Solid Waste			
Larry and Joyce Egemo	Solid Waste	Disposal	Consent	\$2,000.00	12/2/20
	Animal				
	Feeding				
Kris Ehlers	Operation	Prohibited discharge	Consent	\$2,500.00	12/3/20
		Improper Solid Waste			
Global Fiberglass Solutions	Solid Waste	Disposal	Consent	0	12/7/20
K and N Holdings, LLC	Wastewater	NPDES Permit	Consent	\$8,000.00	12/7/20
	Animal				
	Feeding	Construction design			
JT Enterprises, Ltd.	Operation	statement	Consent	\$10,000.00	12/10/20
		Amended			
City of Clarence	Wastewater	Completion Date	Amendment	0	12/10/20
	Animal				
	Feeding	Manure			
John and Cathy Tuttle	Operation	Management Plan	Consent	\$2,000.00	12/14/20
	Animal				
	Feeding				
	Operation and				
Fremont Farms of Iowa L.L.P.	Wastewater	Prohibited discharge	Consent	\$4,000.00	12/18/20
		Rescission of			
Thomas Chris Dodge	Solid Waste	Previous Order	Rescission	0	1/8/21

	1			1	
	Air Ovality and	Open Burning and			
Charles Manning	Solid Waste	Improper Solid Waste Disposal	Consent	\$5,350.00	1/12/21
Charles Manning		'			1/12/21
City of Armstrong	Wastewater	NDPES Permit	Consent	\$2,000.00	1/15/21
	At a altra and	Open Burning and			
Damuarianan	1	Improper Solid Waste	Canaant	¢2.500.00	1 /1 5 /21
Denver Larson	Solid Waste	Disposal	Consent	\$2,500.00	1/15/21
	Air Quality and	Open Burning and Improper Solid Waste			
Cory Schaff and Sharane Brown	Solid Waste	Disposal	Consent	\$4,135.00	1/19/21
Cory Schart and Sharane Brown	Animal	ызрозаі	Consent	\$4,133.00	1/13/21
	Feeding	Manure			
Double A Pork, Inc.	Operation	Management Plan	Consent	\$2,000.00	1/19/21
Bodbie 711 orky mo.	Animal	Prohibited discharge	CONSCIT	φ2,000.00	1, 13, 11
	Feeding	and Applicator			
Vorwerk Custom Pumping	Operation	Certification	Consent	\$5,000.00	1/19/21
	'	Open Burning and		. ,	
	Air Quality and	Improper Solid Waste			
M.A. Mortenson Company	Solid Waste	Disposal	Consent	\$10,000.00	1/26/21
		Amended			
City of Emmetsburg	Wastewater	Construction Date	Amendment	0	1/28/21
	Animal				
	Feeding				
Fredco, Inc.	Operation	Prohibited discharge	Consent	\$8,000.00	2/3/21
City of Waukon	Wastewater	Prohibited discharge	Consent	\$2,500.00	2/3/21
		Manure			
	Animal	Management Plan			
	Feeding	and Construction			
Gary Nielsen	Operation	Design Statement	Consent	\$1,500.00	2/15/21
Tyler Investment Co., Inc.	Wastewater	Prohibited Discharge	Unilateral	\$10,000.00	2/16/21
Global Fiberglass Solutions, Inc.	Solid Waste	Compliance Plan	Amendment	0	2/18/21
Hy-Vee, Inc.	Wastewater	Prohibited discharge	Consent	\$5,200.00	2/19/21
	Animal	Construction Permit			-
	Feeding	and Failure to comply			
Roger Kilburg	Operation	with Previous Order	Unilateral	\$5,000.00	2/25/21
		Amendment to			
Steven and Jane Hemmingstad	Flood Plains	Previous Order	Amendment	\$3,000.00	2/26/21
Des Moines Area Community		Minor Source			
College	Air Quality	Emissions Inventory	Consent	\$2,500.00	3/3/21
		Failure to Obtain			
Keystone Equity Group, LLC	Wastewater	Permit	Consent	\$5,000.00	3/3/21
Harold Chapman	Wastewater	Prohibited Discharge	Consent	\$1,350.00	3/4/21
Cities of Davenport, Bettendorf,		Amended			
Riverdale, and Panorama Park	Wastewater	Construction Dates	Amendment	0	3/4/21
		Operator			
Tyler Bauer	Water Supply	Certification	Consent	0	3/5/21
Ven Green Land Development,			_		
LLC	Wastewater	Prohibited Discharge	Consent	\$6,000.00	3/9/21

Grand Total		\$124,910.00			
Frank's Auto & Truck Salvage, LLC	Water	Storm Water Permit	Consent	\$6,625.00	3/22/21
	and Storm	Demanufacturing and			
	Solid Waste	Appliance			
Amy Kohlwes	Water Supply	Certification	Consent	0	3/18/21
		Operator			
City of Corydon	Wastewater	Construction Dates	Amendment	0	3/11/21
		Amended			

IOWA DEPARTMENT OF NATURAL RESOURCES LEGAL SERVICES BUREAU

DATE: April 2021

TO: Environmental Protection Commission

FROM: Tamara McIntosh

SUBJECT: Summary of Administrative Penalties (November 21, 2020 – March 25, 2021)

The following administrative penalties are being collected by DRF:

NAME/LOCATION	PROGRAM	AMOUNT (remaining)
Jon Knabel (Clinton Co.)	AQ/SW	\$1,187.33
Randy Wise; Wise Construction (Buena Vista Co.)	AQ/SW	\$2,081.32
Gary Eggers (Stacyville)	SW/WW	\$10,000.00
Dennis R. Phillips; Marty's Convenience Mart (Riverton)	UT	\$9,954.53
Frank Robak (Little Sioux)	UT	\$10,000.00
Randy Cates	AQ/SW	\$10,000.00
JS Properties LLC (Terry Anderson)	AQ	\$6,500.00
Jeff Gray dba Grayz Metal Recycling	AQ/SW	\$918.53
Keaven Faber	AQ/AFO	\$231.64
Jayson Schlafke	AFO	\$3,000.00
Jason Wernimont	AFO	\$84.58
Strickler Farms, LTD	AFO	\$4,000.00
Carl DeJoode	SW	\$10,000.00
Grand Total		\$67,957.93

The following administrative penalties are DUE (and being collected by DNR):

NAME/LOCATION	PROGRAM	AMOUNT (remaining)
Sport Wade, Inc. (Decatur Co)	UT	\$10,000.00
Recycling Services	WW/HC/SW	\$7,000.00
Michael Pearson	ww	\$5,000.00
Lu Jen Farms	AFO	\$5,000.00
Blue Hyll Dairy Farm, LLC	AFO	\$6,500.00
Michael Matthews	AQ	\$4,630.00
Bar K Cattle, LLC	AFO	\$5,000.00
Robert Bryant	AFO	\$2,000.00
Amritdeep Kaur – Pari, Inc.	UT	\$7,000.00
Amritdeep Kaur – Cissy's II	UT	\$8,890.00
Ronald Stratton	FP	\$5,000.00
Jaymaharaj, L.L.C. and Monaj Desai	HC	\$7,000.00
Calcium Products	WW	\$6,700.00
CJ's Construction, Inc.	WW	\$5,000.00
Grand Total		\$84,720.00

The following administrative penalties have been COLLECTED:

NAME/LOCATION	PROGRAM	AMOUNT (Collected)
Ag Partners, L.L.C.	AFO	\$6,500.00
Rausch Feedlot Company	AFO	\$3,000.00
Dolezal Farm Account	AFO	\$2,000.00
Keaven Faber	AFO/Revenue	\$2,300.36
Jason Wernimont	AFO/Revenue	\$836.42
NEW Cooperative, Inc.	AQ/SW	\$10,000.00
Lehigh Hanson (Lehigh Cement Company LLC)	AQ/AG	\$69,402.05
Abatement Specialties	AQ/AG	\$10,000.00
Oleg Sharpelyuk	AQ/SW	\$1,000.00
Fink Electric, Inc.	AQ	\$780.00
Joyce Egemo	AQ/SW	\$2,000.00
Richard Tompkins	AQ/SW	\$400.00
Jiya Food Mart Inc.	WW	\$1,333.00
Kris Ehlers	AFO	\$2,500.00
Chisagkumar Patel	WW	\$666.00
Chad Hansmann	AFO	\$750.00
Gaylon Rozeboom	AFO	\$1,500.00
K&N Holdings, LLC	WW	\$8,000.00
Vitlax, Inc.	WW	\$2,500.00
Schmit Pork, L.C.	AFO	\$5,000.00
Sheryl Sovereign	WS/Revenue	\$150.00
Fremont Farms of Iowa	AFO/WW	\$4,000.00
JT Enterprises Ltd.	AFO	\$2,500.00
Andrew Vorwerk dba Vorwerk Custom Pumping	AFO	\$1,824.64
Double A Pork, Inc.	AFO	\$2,000.00
Charles Manning	AQ/SW	\$5,350.00
Cory Schaff and Sharane Brown	AQ/SW	\$4,135.00
John and Cathy Tuttle	AFO	\$248.00
Gary Nielsen	AFO	\$1,500.00
City of Armstrong	WW	\$2,000.00
LCNJ Farms, L.L.C.	AFO	\$455.00
Brian Behrens	AFO	\$833.00
Curt Stencil	AQ	\$2,000.00
M.A Mortenson Company	AQ/SW	\$10,000.00
Pro Pumping & Ag Services LLC	AFO	\$625.00
City of Waukon	WW - Administrative	\$2,500.00
City of Waukon	WW – Restitution	\$1,568.60
Grand Total		\$172,157.07

IOWA DEPARTMENT OF NATURAL RESOURCES LEGAL SERVICES BUREAU

DATE: April 2021 (November 25, 2020 – March 25, 2020)

TO: Environmental Protection Commission

FROM: Tamara McIntosh

SUBJECT: Rulemaking Status Report

Rule Proposal	Sent to Director for Approval	Sent for Governor's Approval	Received Governor's Approval	Notice to EPC	Notice Published	ARRC#	ARRC Mtg	Hearing	Comment Period ends	Final to EPC	Rules Published	ARRC#	ARRC Mtg	Rules Effective
Ch 61 - 401 rule, Amended NOIA	1/29/2021	1/29/21	02/02/21	02/16/21	3/10/21	5508C	April	3/30/21	4/2/21	(MAY)				
UST rules	9/9/2020 10/27/20	XX	10/2/20 10/27/20	11/17/20	12/16/20	5316C	1/8/20	1/8/21	1/8/21	04/20/21				
FP rules	12/21/20	12/21/20												
Air Quality - NSPS, NESHAP updates	3/17/21	3/19/21												

Iowa Department of Natural Resources Environmental Protection Commission

ITEM 5 DECISION

Contract with THE UNIVERSITY OF IOWA

Recommendation:

Commission approval is requested for a service contract with the State Hygienic Laboratory at the University of Iowa.

Contract Terms:

Amount: Not to exceed \$84,956.58 **Dates:** May 1, 2021, to October 31, 2021.

Funding Source(s): Environment First Appropriation and EPA Region VII Grant No. 00793518-0, Clean Water Act

section 106 Special Monitoring Funds.

Statutory Authority: lowa Code section 455B.103(3).

Contract Background:

Since 2006, the Iowa Department of Natural Resources Beach Monitoring Program has sampled and reported indicator bacteria concentrations at swimming areas throughout the state. Routine monitoring takes place from the week before Memorial Day through Labor Day. The beach monitoring project fits into the mission of the DNR by ensuring high quality recreational opportunities within the state park system and by assessing and reporting on the quality of surface waters in the state.

<u>Contract Purpose</u>: The parties propose to enter into this Contract to retain the Contractor to provide assistance to DNR in the analysis of indicator bacteria and cyanobacteria toxin (microcystin) samples collected by the DNR as part of the beach monitoring program. Indicator bacteria samples are collected weekly during the monitoring period at up to 40 state park beaches and as many as 32 city and county park beaches. Cyanobacteria toxin (microcystin) samples are collected weekly during the monitoring period from 9 beach locations and 1 composite at up to 8 state park beaches. This additional cyanobacteria toxin sampling for the 2021 sampling season is to validate our current sampling procedure of collecting a 9 point composite sample vs a targeted grab sample.

Contractor Selection Process:

DNR is allowed to contract with the University of Iowa pursuant to Iowa Code section 455B.103(3).

Contract History:

The DNR has entered into contracts with the State Hygienic Laboratory at the University of Iowa on a regular basis since 2014. The purpose of the contracts with University of Iowa is to have the State Hygienic Laboratory provide the DNR with indicator bacteria analysis at state, county, and city owned beaches. This information is used to inform the public of current beach warning status. Additionally, the DNR intends to utilize the information gathered and analyzed in this Contract in partial fulfillment of sections 303d and 305b of the Clean Water Act including: biennial reports on the status of lake water quality, impaired water listing, and total maximum daily load reports. The most recent contracts have been the following:

Contract #1: Timeframe: May 23, 2016, to September 30, 2016; Amount \$26,605.80; Amendment: None Contract #2: Timeframe: May 15, 2017, to September 30, 2017; Amount \$23,817.24 Amendment: None Contract #3: Timeframe: May 1, 2018, to October 31, 2018; Amount \$24,457.14; Amendment: None Contract #4: Timeframe: May 1, 2019, to October 31, 2019; Amount \$25,963.74; Amendment: None Contract #5: Timeframe: May 1, 2020, to October 31, 2020; Amount \$27,839.16; Amendment: None

Roger Bruner, Supervisor, Water Quality Bureau Environmental Services Division April 20, 2021

5.1 Statement of Work. Contractor shall perform the following Tasks. Contractor shall complete its obligations under this Contract by the Task Milestone Dates set out in the following table.

Obligat	ion	Task Milestone Date
Descrip	Analysis of water samples from state park beaches for indicator bacteria otion: Laboratory analysis shall be completed for <i>Escherichia coli</i> (see Table 4 for a	Contractor shall conduct sample analysis, including sample set-up, on a weekly
	parameter list) on surface water samples collected at up to 40 state park beaches by DNR staff (see Table 1 for a list of these beaches). All samples submitted for analysis through this task shall be coded as IDNR	basis beginning no later than May 24, 2021, and continuing for 15 weeks.
	BEACH.	
c) d)	Laboratory staff shall email the Contract Manager with notification of results greater than 235 CFU/100ml within 2 hours of sample analysis completion. SHL shall provide sample containers and chain of custody forms for water samples to be collected by DNR staff during the Contract period.	Contractor shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 2 hours after completion of sample analysis.
	Analysis of QA/QC samples	Contractor shall conduct
Descrip a) b)	Laboratory analysis shall be completed for <i>Escherichia coli</i> (see Table 4 for a parameter list) on all QA/QC samples (field blanks and splits) submitted to SHL by DNR as part of the state beach monitoring program.	sample analysis, including sample set-up, on a weekly basis beginning no later than May 24, 2021, and continuing for 15 weeks.
c)	SHL shall provide sample containers and chain of custody forms for water samples to be collected by DNR staff during the Contract period.	Contractor shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 2 hours after completion of sample analysis.
	Assemble and ship bacteria sample kits to city/county beaches	Contractor shall complete
Descrip a)	SHL shall ship coolers, cold packs, bottles, and chain of custody forms to all beaches participating in the city/county beach monitoring program (see Table 2 for a list of these beaches).	the first shipment of this Task no later than May 17, 2021.
b)	SHL shall provide return shipping labels to meet required holding times.	Contractor shall continue to ship supplies outlined in this Task on an as needed basis with the last shipment sent no later than August 31, 2021.
	Return shipping and analysis of city/county beach bacteria samples	SHL shall complete this Task
Descrip a)		weekly, beginning week of May 24, 2021, and continuing for 15 weeks. SHL shall make completed results available to DNR via
	to arrive at SHL and be analyzed within the 30 hour sample holding time.	results available to DNR the SHL OpenELIS web portal not later than clos

Item 5, Page 3 of 9

- b) Samples received outside of the 30 hour sample holding time shall not be analyzed. SHL shall email the DNR Contract Manager by end of business on date of sample receipt when city/county beach samples are not analyzed.
- c) SHL shall email the DNR Contract Manager to notify when city/county beach samples are received on a Thursday or Friday. Samples received on a Thursday or Friday and within 30-hour sample holding time shall be analyzed.
- d) All samples submitted for analysis through this Task shall be coded as **CO BEACH**.

business on Thursday of each week of the monitoring season (May 24– Sept 6, 2021).

Task 5: Analysis of water samples from state park beaches for Microcystin Toxin Description:

- a) Laboratory analysis shall be completed for Microcystin Toxin (Table 6) on surface water samples collected at up to a maximum of eight (8) state park beaches by DNR staff. A total of 10 samples (9 discrete and 1 composite) will be collected from each sampling location on weekly basis.
- b) All samples submitted for analysis through this task shall be coded as **IDNR BEACH MICRO**.
- c) SHL shall provide sample containers and chain of custody forms for water samples to be collected by DNR staff during the Contract period.
- d) SHL shall provide quality assurance information collected during the laboratory analysis samples. This information shall include, but shall not be limited to: Standard Curve concentrations; positive control (QCS) concentrations; LCRC concentrations; LRB concentrations; and all %CV's and absorbances for all standards, quality control, and sample results.

Contractor shall conduct sample analysis no later than holding times established by SHL (Table 6) unless authorized in writing by the DNR completion of sample analysis.

Task 6: Special Projects Description:

- a) SHL shall complete additional analyses from state park or county beaches for indicator bacteria (see Table 4 for a parameter list) as mutually agreed upon in writing by SHL and DNR.
- b) All samples submitted for analysis through this task shall be coded as **IDNR BEACH SPECIAL**.
- c) Laboratory staff shall email the Contract Manager with notification of results greater than 235 CFU/100ml.

Contractor shall conduct sample analysis, including sample set-up, on an as needed basis beginning no later than May 24, 2021, and continuing for 15 weeks.

Contractor shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 2 hours after completion of sample analysis.

Task 7: Data Transfer

Description: SHL shall make the data generated pursuant to this Contract available to DNR electronically through the State Hygienic Laboratory OpenELIS database web portal. Data shall be available for download by DNR staff in a mutually agreeable format. The available sample information shall include the STORET station identification number (aka AQuIA SiteID), which will be provided by DNR for all station locations. Data shall be retrievable via the web portal by DNR staff.

Analytical reports may be retrieved electronically by DNR staff having the appropriate authorization. SHL shall assist DNR staff in obtaining appropriate authorization when requested.

When accessing electronic data, the following information is required:

SHL OpenELIS/Telcor Organization ID number: 7002 (IDNR BEACH MONITORING)

SHL shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 15 calendar days after the end of each month.

If SHL determines that extra time for analysis should be allowed in specific cases, then a written notification shall be made to the DNR Project Manager, stating that analytical results from a sample will be delayed and

Item 5, Page 4 of 9

SHL Project Code: (IDNR BEACH; IDNR BEACH QAQC; CO BEACH; IDNR BEACH
 SPECIAL; IDNR BEACH MICRO)
 This notification shall occur as soon as possible but not later than 15 days following receipt of the sample.

7.1 Budget & Submission of Invoices. The budget and submission of invoices for this Contract shall be as follows:

Task* Task 1. Analysis of water samples from state park beaches for indicator bacteria (see Table 4 for a parameter list)	Total Amount of compensation allotted to Task** (Variable Payment) No greater than \$11,100.00, at the per sample costs contained in Table 3.	Task Milestone Date Contractor shall conduct sample analysis including sample set-up, on a weekly basis beginning no later than May 24, 2021, and continuing for 15 weeks. Contractor shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 2 hours after completion of sample analysis.	Invoice Due No Later Than: Monthly, no later than thirty (30) days following the end of each month.
Task 2: Analysis of QA/QC samples (see Table 4 for a parameter list)	No greater than \$1,406.00, at the per sample costs contained in Table 3.	Contractor shall conduct sample analysis including sample set-up, on a weekly basis beginning no later than May 24, 2021, and continuing for 15 weeks. Contractor shall make completed data and results available to DNR via the SHL OpenELIS web portal not later than 2 hours after completion of sample analysis.	Monthly, no later than thirty (30) days following the end of each month.
Task 3: Assemble and ship bacteria sample kits to city/county beaches	\$ 0	Contractor shall complete the first shipment of this Task no later than May 17, 2021. Contractor shall continue to ship supplies outlined in this task on an as needed basis and no later than August 31, 2021.	N/A
Task 4: Return shipping and analysis of city/county beach bacteria samples (see Table 5 for a parameter list)	No greater than \$11,880.00, at the per sample costs contained in Table 3.	SHL shall complete this Task weekly, beginning week of May 24, 2021, and continuing for 15 weeks. SHL shall make completed results available to DNR via the SHL OpenELIS web portal not later than close of business on Thursday of each week of the monitoring season (May 24– September 6, 2021).	Monthly, no later than thirty (30) days following the end of each month.
Task 5: Analysis of water samples from state park	No greater than \$54,000.00, at the per sample costs contained in Table 3.	Contractor shall conduct sample analysis no later than holding times established by SHL (Table 6) unless authorized in writing by the DNR completion of sample analysis.	Monthly, no later than thirty (30) days following the end of each month.

Item 5, Page 5 of 9

	1		Item 5, 1 age 5 of 5
beaches for			
Microcystin Toxin			
(see Table 6 for a			
parameter list)			
Task 6: Special	No greater than	Contractor shall conduct sample analysis	Monthly, no later than
Projects (see Table	\$277.50, at the per	including sample set-up, on an as needed	thirty (30) days following
4 for a parameter	sample costs	basis beginning no later than May 24, 2021,	the end of each month.
list)	contained in Table 3.	and continuing for 15 weeks.	
		Contractor shall make completed data and	
		results available to DNR via the SHL	
		OpenELIS web portal not later than 2 hours	
		after completion of sample analysis.	
Task 7: Data	N/A	SHL shall make completed data and results	N/A
Transfer	.,,,,	available to DNR via the SHL OpenELIS web	
		portal not later than 15 calendar days after	
		the end of each month.	
		the end of each month.	
		If SHL determines that extra time for	
		analysis should be allowed in specific cases,	
		then a written notification shall be made to	
		the DNR Project Manager, stating that	
		analytical results from a sample will be	
		delayed and the reasons for the delay. This	
		notification shall occur as soon as possible	
		but not later than 15 days following receipt	
		of the sample.	
Sub-totals	\$78,663.50		
Facilities and			
Administrative	\$6,293.08		
Costs @ 8%			
Total	Not to exceed		
TOLAT	\$84,956.58		

^{*}Payment for completion of Tasks where specific payment is allotted shall be dependent upon the timely completion of corresponding items required by Tasks where no specific payment is allotted.

^{**}Payment also shall conform to any pricing Tables contained in this Contract and referenced in the Budget Table above; or to the relevant SHL Pricing Table. Tables contained in this Contract shall take precedence, in the event of any inconsistency.

^{***}Variable payment" shall mean that the number of specific analyses per Task may vary, and the Contractor shall be paid only for the number of specific analyses performed per Task. "Fixed payment" shall mean that the Contractor shall be paid an amount that is fixed in the Contract, with no variations based on analyses per Task actually performed.

Table 1 – List of 40 State Park Beaches (Collected by DNR)

Beach Name	<u>Park</u>	AQuIA SiteID	
Backbone Beach	Backbone State Park	21280001	
Beed's Lake Beach	Beed's Lake State Park	21350001	
Big Creek Beach	Big Creek State Park	21770001	
Black Hawk Beach	Black Hawk State Park	21810002	
Denison Beach	Black Hawk State Park	21810001	
Brushy Creek Beach	Brushy Creek State Recreation Area	21940001	
Clear Lake Beach	Clear Lake State Park	21170001	
Crandall's Beach	Crandall's Beach	21300005	
Emerson Bay Beach	Emerson Bay State Recreation Area	21300004	
Geode Beach	Geode State Park	21440001	
George Wyth Beach	George Wyth Memorial State Park	21070001	
Green Valley Beach	Green Valley State Park	21880001	
Gull Point Beach	Gull Point State Park	21300001	
Honey Creek Resort Beach	Honey Creek Resort State Park	21040001	
Lacey-Keosauqua Beach	Lacey-Keosauqua Sate Park	21890001	
Lake Ahquabi Beach	Lake Ahquabi State Park	21910001	
Lake Anita Beach	Lake Anita State Park	21150001	
Lake Darling Beach	Lake Darling State Park	21920001	
Lake Keomah Beach	Lake Keomah State Park	21620001	
Lake Macbride Beach	Lake Macbride State Park	21520001	
Lake Manawa Beach	Lake Manawa State Park	21780001	
Lake of Three Fires Beach	Lake of Three Fires St. Park	21870001	
Lake Wapello Beach	Lake Wapello State Park	21260001	
Lewis and Clark (Blue Lake) Beach	Lewis & Clark State Park	21670001	
Marble Beach	Marble Beach State Rec Area	14000380	
McIntosh Woods Beach	McIntosh Woods State Park	21170002	
Nine Eagles Beach	Nine Eagles State Park	21270001	
Pike's Point Beach	Pike's Point State Park	21300002	
Lower Pine Lake Beach	Pine Lake State Park	21420001	
Pleasant Creek Lake Beach	Pleasant Creek State Recreation Area	21570001	
Prairie Rose Beach	Prairie Rose State Park	21830001	
Red Haw Beach	Red Haw State Park	21590001	
Rock Creek Beach	Rock Creek State Park	21500001	
Springbrook Beach	Springbrook State Park	21390001	
Triboji Beach	Triboji Beach	21300003	
North Twin Lake East Beach	Twin Lakes State Park	21130002	
North Twin Lake West Beach	Twin Lakes State Park	21130001	
Union Grove Beach	Union Grove State Park	21860001	
Viking Lake Beach	Viking Lake State Park	21690001	
Bob White Beach	Bob White State Park	21930001	

Table 2 – 32 City/County Park Beaches (Collected by City/County Personnel)

<u>Site</u>	<u>Contact</u>	Street Address/P.O.Box	<u>City</u>	Zip Code	AQuiA SiteID
Mormon Trail Beach	Greenfield Lumber - Dominic Johnson	107 NE 6th Street	Greenfield	50849	21010001
lannen Lake Park Collin Strickland		1949 Benton-Iowa Road	Blairstown	52209	14000158
Rodgers Lake Beach	Ed Hach	2113 57th Street Trail	Vinton	52349	14000236
Don Williams Beach	Boone County Conservation - Don Williams Park	610 H Ave	Ogden	50212	21080001
Struchler Pit Beach	Buena Vista County Conservation, Greg Johnson	377 440th Street	Peterson	51047	21110002
Gabrielson Park Beach	Buena Vista County Conservation, Greg Johnson	377 440th Street	Peterson	51047	21110001
Malone Park	Philip Visser	P.O. Box 68	Grand Mound	52751	21230001
Little River Recreation Area	Decatur CCB - Richard Erke	20401 NW Little River Rd	Leon	50144	21270002
Big Hollow Recreation Area	Big Hollow Maintenance Shops - Pat Rogge	18853 152nd Ave	Sperry	52650	21290001
Willow Lake Recreation Area	Harrison County Conservation Board - Byron Vennink	2725 Easton Trail	Woodbine	51579	21430001
Lake Iowa Park	lowa County Conservation - Chris Anderson	2576 G Ave	Williamsburg	52361	21480001
Fairfield Waterworks Park	The Fairfield Waterworks	700 Waterworks Rd	Fairfield	52556	21510001
Pollmiller Park	Lee County Conservation - Clint Oldfield	2652 Hwy 61	Montrose	52639	21560001
Muscatine Island	Muscatine Co Cons Bd - Dave Bakke	3300 Cedar Street/PO Box 109	Muscatine	52761	14000136
Gray's Lake Park	Julie Hempel, Parks and Recreation	1551 E. Martin Luther King Dr.	Des Moines	50317	21770003
Big Sioux Recreation Area	Sioux County Conservation - Big Sioux Rec. Area	4051 Cherry Ave	Hawarden	51023	21840001
Sandy Hollow Recreation Area	Sioux County Conservation - Sandy Hollow Rec. Area	3395 400th St	Sioux Center	51250	14000120
Three Mile Lake beach	Union CCB - Doug Jones	1577 Creamery Rd	Afton	50830	14000186
Lake Cornelia	Wright CCB - Eric Rector	1768 O'Brien Ave	Clarion	50525	21990001
Lake Pahoja	Kyle Ciesielski	1831 Buchanan Ave	Inwood	51240	21600001
Treman Park Beach	Calhoun County Conservation - Curtis Vanderheiden	1228 W. High St	Rockwell City	50579	21130003
Central Park Lake Beach	Jones County Conservation - John Klein	12515 Central Park Road	Center Junction	52212	21530001
Easter Lake Park Beach	The UPS Store - Polk County Conservation, Brad Janssen	4225 Fleur Drive	Des Moines	50321	21770002
Hickory Grove Park	Story County Conservation - Luke Feilmeier	67464 250th Street	Colo	50056	21850001
Peterson Park Beach	Story County Conservation - Danny Simcox	56461 180th St.	Ames	50010	21850002
Awaysis Park*	City of Storm Lake - Kim Woltman	433 Vilas Rd	Storm Lake	50588	21110004
Bel Air Beach*	City of Storm Lake - Kim Woltman	433 Vilas Rd	Storm Lake	50588	21110005

					· ·
Casino Beach*	City of Storm Lake - Kim	433 Vilas Rd	Storm Lake	50588	21110006
	Woltman				
Chautauqua Park*	City of Storm Lake - Kim	433 Vilas Rd	Storm Lake	50588	21110007
	Woltman				
Frank Starr Beach*	City of Storm Lake - Kim	433 Vilas Rd	Storm Lake	50588	14000121
	Woltman				
Edson Park*	City of Storm Lake - Kim	433 Vilas Rd	Storm Lake	50588	21110008
	Woltman				
Old Water Plant*	City of Storm Lake - Kim	433 Vilas Rd	Storm Lake	50588	21110009
	Woltman				

^{*}Indicates DNR will drop off to SHL

Table 3 – Breakdown of Costs

<u>Task</u>		Number of Samples	<u>Cost per</u> <u>Sample</u>	<u>Total Cost</u>
Task 1: Analysis of water samples from state park beaches for indicator bacteria		600 (40 state park beaches × 15 weeks)	600 @ \$18.50	\$11,100.00
Task 2: Analysis of QA/QC samples		76 (4 field replicate per week × 15 weeks=60) + (4 equipment blank × 4 (every 4 weeks)=16)	76 @ \$18.50	\$1,406.00
	e and ship bacteria ty/county beaches	Outgoing shipments	\$0.00	\$0.00
Task 4: Return	- Analysis of city/county beach bacteria samples	375 (25 beaches × 15 weeks)	375 @ \$18.50	\$6,937.50
shipping and	(shipped)	Ground return shipping	375@ \$8.00	\$3,000.00
analysis of city/county beach bacteria samples	- Analysis of city/county beach bacteria samples (delivered by DNR)	105 (7 beaches × 15 weeks)	105 @ \$18.50	\$1,942.50
Task 5: Analysis of water samples from state park beaches for Microcystin Toxin		1200 (8 state park beaches × 10 samples × 15 weeks)	1200 @ \$45.00	\$54,000.00
Task 6: Special Projects.		Up to 15 samples	15 @ \$18.50	\$277.50
Task 7: Data Transfer			\$0.00	\$0.00
			Subtotal	\$78,663.50
		Facilities and Administra	ative Costs @ 8%	\$6,293.08
			Contract Total	\$84,956.58

Table 4. Water quality sampling parameters and frequency for Tasks 1 & 2.

		SHL Bottle	Reporting			
Parameter	Analytical Method	# ¹	Limit ²	Holding Time	Preservation	# of Samples
E. coli	SM 9223 B	81	<10	CWA 8 hours	Cool to < 10° C,	676
L. COII	31VI 9223 B	01	MPN/100mL	CVVA 8 Hours	Sodium thiosulfate	070
¹ Final type and quantity of bottles will be specified in the bottle order and on the test request form (TRF).						

²Reporting limits can vary.

Table 5. Water quality sampling parameters and frequency for Task 4.

		SHL Bottle	Reporting			
Parameter	Analytical Method	# ¹	Limit ²	Holding Time	Preservation	# of Samples
E. coli	SM 9223 B	81	<10 MPN/100mL	30 hours	Cool to < 10° C, Sodium thiosulfate	480

¹Final type and quantity of bottles will be specified in the bottle or<u>der and on the test request form (TRF).</u>

Table 6. Water quality sampling parameters and frequency for Task 5.

Parameter	Analytical Method	SHL Bottle #1	Reporting Limit ²	Holding Time	Preservation	# of Samples
Microcystin (Total)	CV ENV 1166	102	0.30 ug/L	2 weeks	Cool to < 10° C or Freeze within 5 days	1200

¹Final type and quantity of bottles will be specified in the bottle order and on the test request form (TRF).

²Reporting limits can vary.

²Reporting limits can vary.

Iowa Department of Natural Resources Environmental Protection Commission

ITEM	6		DECISION
ТОРІС	Solid Wa	ste Environmental Management System Program – Designation of Applicant	

The Commission, as authorized by Code of Iowa Section 455J.7, is requested to approve the designation of Mahaska County Solid Waste Management Commission as a participant in the Solid Waste Environmental Management System (EMS) Program.

Background

The EMS program was established in 2008 with the creation of lowa Chapter 455J, *Environmental Management Systems*. The voluntary program serves as an alternative to solid waste comprehensive planning. Interested solid waste planning areas submit an application, proposing their plans to implement program goals in each of the six EMS component areas:

- Organics waste management
- Hazardous household materials collection
- Water quality improvement
- Greenhouse gas reduction
- Recycling services
- Environmental education

lowa Code section 455J.7(1)(a) states: By October 1 each year, the department may recommend the designation of any additional planning or service areas as systems, provided those areas meet the requirements of section 455J.3. DNR typically accepts applications through February 1st of each year in order to efficiently manage the process for newly designated participants.

Each newly designated participant enters into a Tier 1 period of twelve to eighteen months in which they receive specialized training. Upon completion of the training, their submittal of a complete Annual Report and the successful completion of both an internal and external audit of their EMS, the participant gains Tier 2 status.

The statute appropriates ongoing support and financial assistance for participants in developing their EMS. Presently, fourteen planning areas/solid waste facility service areas participate in the voluntary Solid Waste EMS Program.

During the FY2021 application period, one application was received: Mahaska County Solid Waste Management Commission, a solid waste planning area that consists of a population of approximately 24,700 and includes all cities and unincorporated areas of Mahaska County, the City of Eddyville in Wapello County and the City of Corydon in Wayne County.

Recommendation

DNR staff attended a Mahaska County Solid Waste Management Commission meeting and held multiple conversations with staff to discuss EMS program requirements. A DNR application review team evaluated the application according to program guidelines. Both the review team and Bureau Chief Amie Davidson recommend designating Mahaska County Solid Waste Management Commission as an Iowa Solid Waste EMS participant.

Laurie Ramus, Program Planner 3 Land Quality Bureau Environmental Services

April 20, 2021

09/2020 cmc DNR Form 542-0850

Iowa Department of Natural Resources Environmental Protection Commission

#7

Decision Item

Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Easter Lake Watershed Project

Commission approval is requested for a contract with IDALS, of Des Moines, Iowa.

Contract Terms:

Amount: Not to exceed \$185,156 **Dates:** June 1, 2021 to June 30, 2023

DNR shall have the option to extend this Contract for up to six years from the beginning date of the original

contract by executing a signed amendment prior to the expiration of this Contract.

Funding Source(s): U.S. EPA Clean Water Act Section 319 grant to DNR (Grant Number 00740427)

Statutory Authority: Funds are administered by DNR under statutory authority granted by Iowa Code section

455B.103.

Contract Background:

This Contract will provide funding and support for the ongoing Easter Lake Watershed Project (Project) for the Easter Lake Watershed. This Project is contracted through IDALS and carried out by the Polk Soil and Water Conservation District.

The Project has been active since 2013 and is one of the largest active restoration projects in the state. Historically, there have been concerns at Easter Lake with water clarity, algal blooms, high sedimentation rates and low oxygen concentrations. Since construction of the lake in 1967 the water volume has decreased by nearly 30% as a result of sediment being deposited in the lake. The 2005 Easter Lake Total Maximum Daily Load plan identified phosphorus and sediment as the pollutants of concern. Watershed modeling has identified high sediment and phosphorus loads originating from predominantly urban areas of the watershed, and the Yeader Creek drainage area.

In response to these water quality problems, area stakeholders worked together to develop the Easter Lake Water Quality Management Plan (WQMP). The WQMP serves as the culmination of existing studies, citizen and stakeholder input, and a consultant's recommendations for structural and non-structural best management practices (BMPs) intended to reduce stormwater runoff and delivery of pollutants from the watershed and ultimately renovate Easter Lake through dredging and other in-lake improvements.

Contract Purpose:

The purpose of this Contract is to designate Section 319 funding to support this Project. This Contract will work to carry out the goals of the Project for the stated contract term. The partners providing financial support and technical assistance in this Project are the DNR, the City of Des Moines, Polk County Conservation Board, the Conservation Districts of Iowa, Polk County Soil and Water Conservation District, IDALS, and the Natural Resources Conservation Service.

Phase Two projects and programs are aimed at reducing external pollutant delivery to the lake through cost-share and financial incentives for watershed BMPs and two major stream stabilization projects. Watershed BMPs will focus on rainscaping practices such as rain gardens, bioswales, and pervious pavement. Decreasing the transport of eroded soil is critical to restoring Easter Lake and the watershed to a healthy, functioning system. The goal of Phase Two is a 25% reduction of sediment and 20% reduction of phosphorus loading. This Contract will be for year 9 of the WQMP to reduce sedimentation and phosphorous loading by 5%.

Selection Process Summary:

Intergovernmental contracting with IDALS is authorized under 11 IAC 118.4. Contracts with state universities and other public agencies for laboratory work, scientific field measurement and environmental quality evaluation services necessary to implement Iowa Code Chapter 455B is authorized under Iowa Code section 455B.103(3).

Contract History:

The DNR has contracted with IDALS to administer Section 319-funded watershed projects since the early 1990s. The purpose of the contracts with IDALS is to provide funds and project management support to IDALS, which then enters into subsequent agreements with soil and water conservation districts to implement the specific watershed implementation project activities. In the Easter Lake Watershed, the DNR and IDALS have previously partnered in the following contracts:

Contract #1: Timeframe: November 1, 2013 to June 30, 2017; Amount \$577,286; Amendment: Original Contract was for \$415,786, two amendments were made due to expanded scope of services.

Contract #2: Timeframe: August 25, 2106 to December 31, 2018; Amount \$185,646; Amendment: Extended contract time frame by one year.

Contract #3: Timeframe: August 27, 2018 to June 30, 2021; Amount \$143,090 **Contract #4**: Timeframe: June 21, 2020 to June 30, 2022; Amount \$91,674

STATEMENT OF WORK

- Task 1. **Project Coordinator** Contractor shall hire and maintain a project coordinator position for the duration of the Contract. *Timeframe* Continuous
- Task 2. **Submit and Carry Out Project Activities** Contractor shall submit annual Work Plan and Budget consistent with EPA-Approved Project Implementation Plan. *Timeframe* No later than May 1 of each year
- Task 3. **Quarterly Financial Reports** Summarize expenses each quarter. *Timeframe* 10/15, 1/15, 4/15 yearly
- Task 4. **Quarterly Progress Reports** Summarize activities each quarter. *Timeframe* 10/15, 1/15, 4/15 yearly *Note: Quarterly reports are superseded by annual reports for the expected 7/15 report as follows*
- Task 5. Annual Progress Report Summarize activities, progress, project costs, water monitoring data (if applicable), and water quality improvements (load reductions) made during the previous fiscal period. *Timeframe* No later than August 1 of each year
- Task 6. **Final Project Report** Total Section 319 funds expended by the project, summary of other funds, summary of accomplishments and objectives, comparison of actual accomplishments to objectives established by annual work plans and project implementation plan, summary of water quality improvements (load reductions), explanation of unmet objectives, and all other reporting requirements in the Section 319 guidance document. *Timeframe* Due no later than 30 days prior to the expiration of this Contract.

Budget Item	Amount of 319 Funds
Salary & Benefits:	\$79,000
IDALS Conservation Assistant (formerly called Secretary) Support:	\$5,000
Travel/Training:	\$1,500
Supplies:	\$1,500
Inform./Outreach:	\$8,000
Practices	
Rainscaping Practices	\$50,156
Engineering	\$40,000
Total:	\$185,156

Kyle Ament, Watershed Basin Coordinator, Water Quality Bureau Environmental Services Division April 20, 2021

Iowa Department of Natural Resources Environmental Protection Commission

#8

Decision Item

Contract with Iowa Department of Agriculture and Land Stewardship (IDALS) – Black Hawk Lake Watershed Project

Commission approval is requested for a contract with IDALS, of Des Moines, Iowa.

Contract Terms:

Amount: Not to exceed \$31,288 **Dates:** June 1, 2021 to June 30, 2023

DNR shall have the option to extend this Contract for up to six years from the beginning date of the original

contract by executing a signed amendment prior to the expiration of this Contract.

Funding Source(s): U.S. EPA Clean Water Act Section 319 grant to DNR (Grant Number 00740427)

Statutory Authority: Funds are administered by DNR under statutory authority granted by Iowa Code section

455B.103.

Contract Background:

This Contract provides funding and support for an ongoing water quality project in the Black Hawk Lake Watershed. This Project is contracted through IDALS and carried out by the Sac County Soil and Water Conservation District. The focus of the Project is to work with partners, residents, landowners and farm operators in the 13,256 acre watershed to reduce nutrient and sediment loss that is impairing Black Hawk Lake. The lake is currently on the Iowa 303(d) list of impaired waterbodies for algae and turbidity.

The Project has a goal of addressing the excess sediment and phosphorus load that has been identified as the primary cause of water quality problems in the lake. Findings identified in the Total Maximum Daily Load plan indicate that a 78% reduction is phosphorus inputs is needed to achieve water quality success.

Contract Purpose:

The purpose of this Contract is to designate Section 319 funding to support this Project. This Contract will work to carry out the goals of the Project for the stated contract term. The partners involved in this project are the DNR, Sac County Conservation Board, Conservation Districts of Iowa, Sac and Carroll County Soil and Water Conservation District, IDALS – Division of Soil Conservation, and the Natural Resources Conservation Service. Each partner will provide financial support and/or technical assistance to help ensure the successful completion of the activities proposed in this Project.

This Contract will place an emphasis on load reductions from row crops, streambanks and urban inputs. For row crop production areas, the targeted load reduction is 138 tons per year of sediment and 307 pounds per year of phosphorus. For streambank inputs, the targeted load reduction is 15 tons per year of sediment and 22 pounds per year of phosphorus. For urban inputs, the target load reduction is 65 pounds of suspended solids and a 40% reduction in phosphorus inputs.

Selection Process Summary:

Intergovernmental contracting with IDALS is authorized under 11 IAC 118.4. Contracts with state universities and other public agencies for laboratory work, scientific field measurement and environmental quality evaluation services necessary to implement Iowa Code Chapter 455B is authorized under Iowa Code section 455B.103(3).

Contract History:

The DNR has contracted with IDALS to administer Section 319-funded watershed projects since the early 1990s. The purpose of the contracts with IDALS is to provide funds and project management support to IDALS, which then enters into subsequent agreements with soil and water conservation districts to implement the specific watershed

implementation project activities. In the Black Hawk Lake Watershed, the DNR and IDALS have previously partnered in the following contracts:

Contract #1: Timeframe: August 21, 2014 to December 31, 2018; Amount \$363,800; Amendment: Two amendments – Modify duration of Contract.

Contract #2: Timeframe: August 27, 2018 to June 30, 2021; Amount \$97,250.

Contract #3: Timeframe: August 15, 2019 to June 30, 2021; Amount \$151,850

STATEMENT OF WORK

- Task 1. **Submit and Carry Out Project Activities** Contractor shall submit annual Work Plan and Budget consistent with EPA-Approved Project Implementation Plan. *Timeframe* No later than May 1 of each year
- Task 2. Quarterly Financial Reports Summarize expenses each quarter. *Timeframe* 10/15, 1/15, 4/15 yearly
- Task 3. **Quarterly Progress Reports –** Summarize activities each quarter. *Timeframe* 10/15, 1/15, 4/15 yearly *Note: Quarterly reports are superseded by annual reports for the expected 7/15 report as follows*
- Task 4. **Annual Progress Report** Summarize activities, progress, project costs, water monitoring data (if applicable), and water quality improvements (load reductions) made during the previous fiscal period. *Timeframe* No later than August 1 of each year
- Task 5. **Final Project Report** Total Section 319 funds expended by the project, summary of other funds, summary of accomplishments and objectives, comparison of actual accomplishments to objectives established by annual work plans and project implementation plan, summary of water quality improvements (load reductions), explanation of unmet objectives, and all other reporting requirements in the Section 319 guidance document. *Timeframe* Due no later than 30 days prior to the expiration of this Contract.

Budget Item	Amount of 319 Funds
IDALS Conservation Assistant (formerly called Secretary) Support:	\$5,000
Travel/Training:	\$750
Supplies:	\$150
Inform./Outreach:	\$3,000
Practices	
To-till	\$12,000
Terraces	\$3,250
Streambank Stabilization	\$4,950
Rain Barrels	\$188
Rain Garden	\$2,000
Total:	\$31,288

Kyle Ament, Watershed Basin Coordinator, Water Quality Bureau Environmental Services Division
April 20, 2021

Iowa Department of Natural Resources Environmental Protection Commission

ITEM 9 DECISION

TOPIC

Adopted and Filed – Chapter 134 Underground Storage Tank Licensing and Certification Programs,
Chapter 135 Technical Standards and Corrective Action Requirements for Owners and Operators
of Underground Storage Tanks, and Chapter 136 Financial Responsibility for Underground
Storage Tanks

The Commission is requested to approve this Adopted and Filed rule making that amends 567 Iowa Administrative Code (IAC) chapters 134, 135, and 136. This rulemaking is in response to the 2015 federal Underground Storage Tank (UST) rule revisions as contained in 40 Code of Federal Regulations (CFR) Parts 280 and 281. The rules are necessary for the Department to maintain its delegated state program approval (SPA) under the federal Resource Conservation and Recovery Act (RCRA). Iowa Code section 455B.474(8) directs the Commission to maintain its SPA. The proposed rules also update and remove outdated provisions, remove outdated code language, and revise leaking underground storage tank (LUST) rules to be consistent with current risk evaluation processes.

In November 2020, the Commission approved moving forward with formal rule making. The Notice of Intended Action (NOIA) was published in the Iowa Administration Bulletin on December 16, 2020 as ARC 5316C. Public hearings were held January 6, 7, and 8, 2021. In response to comments received during the comment period and at the hearings, the Department made several additional changes to the final rule. The Public Participation Responsiveness Summary details the comments from the public and DNR's response, and itemizes the most recent changes to the final rule. The effective date of the rule, if approved, will be June 23, 2021.

A summary of the revisions from the NOIA is provided here for the Commission's review:

IAC 567-134 *Underground Storage Tank Licensing and Certification Programs.* The final rule amends this chapter by updating nomenclatures to lowa Code (455B); updating licensee application, training and renewal requirements; expanding the eligibility for certain inspectors and testers, and clarifying licensed professional duties and documentation requirements for work performed.

IAC 567-135 *Technical Standards and Corrective Action Requirements for Owners and Operators of Underground Storage Tanks.* The most recent federal UST rule revisions improve upon the 1988 federal UST regulations by emphasizing the proper operation and maintenance of UST equipment. The revisions prevent and detect UST petroleum releases, which are a leading source of groundwater contamination, often resulting in expensive cleanups. The primary provisions of the federal rule that have been incorporated into the final rule include:

- regulation of certain tanks deferred by the 1988 federal regulations;
- disallowing flow restrictors in vent lines for new installations or when replacing equipment;
- requiring the closure of internally lined tanks that fail a lining inspection and cannot be repaired;
- requiring a demonstration that equipment is compatible with the fuel stored (addressing biofuel compatibility);
- requiring monthly and annual facility walkthrough inspections;
- requiring annual release detection equipment testing;
- requiring spill prevention equipment testing every three years;
- requiring overfill prevention equipment inspection every three years; and
- requiring containment sump testing every three years for those sumps used for piping interstitial monitoring.

The final rule also removes outdated or unused regulations and references, updates temporary tank closure and tank system corrosion protection requirements. In addition, the final rules include updated provisions to reflect what the Department has learned over the last 20 years of the risk-based corrective action (RBCA) evaluation process and

03/2021 DNR Form 542-0850

remediation methods.

IAC 567-136 *Financial Responsibility for Underground Storage Tanks.* The final rule modifies definitions to better clarify the financial responsibility regulation's applicability and compliance requirements.

Timeline for Rule-making

The Department has worked in close partnership with interested stakeholders to update Iowa's regulations since the implementation of the 2015 federal regulations. Between December 2015 and December 2017, the Department hosted eight stakeholder meetings. Attendees included representatives from the Iowa Petroleum Equipment Contractors Association (IPECA), FUELIowa (formerly Petroleum Marketers and Convenience Stores of Iowa), the Petroleum Marketers Management Insurance Company (PMMIC), environmental consultants, major convenience store chains, small business owners/operators, fuel supply companies, and the Department. Stakeholders joined the Department in establishing a Task Force to address technical issues and other areas of concern. Several proposed changes raised by the Task Force were incorporated into this final rule. Others were not incorporated because they were inconsistent with the federal rules and would prevent the Department from meeting SPA requirements.

Following the October 20, 2020, Commission meeting, two additional stakeholder meetings were held to address concerns with new federal testing requirements and the need for personnel to complete the testing before October 2021. As a result, compliance inspector certification criteria has been expanded to allow more persons to qualify and certification training timeframes were relaxed to add more flexibility. License fees for the individual compliance inspectors were reduced, while fees for a UST compliance inspector company were raised to a level consistent with other Chapter 134 license fees. Testing qualifications were modified for licensed UST professionals to allow more persons to qualify for licensure. Representatives from the Department, IPECA, Seneca Companies, FUELIowa, and PMMIC attended the meetings.

This final rule contains language acceptable to EPA, which will allow the Department to maintain its SPA. This final rule is also generally acceptable to the industry. **The Commission is asked to approve this Adopted and Filed rule.**

James Gastineau, Environmental Specialist Senior Underground Storage Tank Section, Land Quality Bureau Environmental Services Division

03/2021 DNR Form 542-0850

FOR RULEMAKING ON 567 IAC 134, 135, & 136

Underground Storage Tank Regulations

IOWA DEPARTMENT OF NATURAL RESOURCES ENVIRONMENTAL SERVICES DIVISION LAND QUALITY BUREAU

March 22, 2021

Table of Contents

INTRODUCTION	3
COMMENTS	3
COMMENTER 1: Joe Zietlow, Kwik Trip / Kwik Star	3
COMMENTER 2: Todd Ferguson, Tanknology	3
COMMENTER 3: John Maynes, FUELIowa	3
COMMENTER 4: Patrick Rounds PMMIC Insurance	4
DNR RESPONSE; CHANGES TO FINAL RULE	5
ATTACHMENTS	
ITEM 1: Email from Joe Zietlow, Kwik Trip / Kwik Star	
ITEM 2: Letter from Todd Ferguson, Tanknology	
ITEM 3: Letter from John Maynes, FUELIowa	
ITEM 4: Email from Patrick Rounds, PMMIC Insurance	

INTRODUCTION

This is a summary of the Iowa Department of Natural Resources' (DNR) response to comments received in response to the proposed rulemaking for 567 Iowa Administrative Code - chapters 134, 135, and 136. The primary purpose of the rulemaking is to conform regulations to recently enacted federal rules promulgated by the U.S. Environmental Protection Agency (EPA). The Environmental Protection Commission (EPC) must adopt rules consistent with EPA's rules in order for the DNR to maintain its delegated state program. Notice of the proposed rulemaking was released for public review and comments following approval of the Notice of Intended Action (NOIA) by the EPC on November 17, 2020. The EPC meeting minutes that include the NOIA are available online (https://www.iowadnr.gov/API/Evotiva-

UserFiles/FileActionsServices/DownloadFile?ItemId=68529&ModuleId=16274&TabId=593).

The proposed rulemaking was published in the Iowa Administrative Bulletin (NOIA ARC 5044C) on December 16, 2020, (w www.legis.iowa.gov/docs/aco/bulletin/12-16-2020.pdf). Public comments were accepted from December 16, 2020, through January 8, 2021, with three virtual public hearings held on January 6th, 7th and 8th from 1pm to 2 pm each day. The Iowa Administrative Rules Review Committee (ARRC) meeting was also held on January 8, 2021. Comments were presented to the ARRC by Mr. John Maynes of FUELIowa and Mr. Patrick Rounds of PMMIC Insurance. Following the comments, committee members urged the DNR to work with stakeholders to reduce any additional regulatory burdens on rural Iowa. The minutes of the ARRC meeting are available online (file://iowa.gov.state.ia.us/data/dnrusers/jgastin/Downloads/IAC%20-%20ARC%20mintures%20for%20Jan.%208.pdf)

COMMENTS

Commenter 1: Joe Zietlow, Kwik Trip / Kwik Star Date Received, January 8, 2021

Commenter 2: Todd Ferguson, Tanknology Date Received, January 8, 2021

Comments from Joe Zietlow of Kwik Trip, Inc. recommended reconsideration of the licensing requirements for licensed testers, noting the years of experience required for an individual licensed as a tester of underground storage tank (UST) systems as outlined in IAC 567 -134.25 (455B) is difficult to attain.

Todd Ferguson of Tanknology presented similar comments. In addition, Mr. Ferguson noted a concern with a rule modification regarding the responsibilities of testers (rule 134.25). For this item, Mr. Ferguson recommended a wording change, reasoning that during normal course of testing or troubleshooting, testers often need to replace certain pieces of equipment. He further recommended a statement be added to the proposed rule allowing for certain modifications; namely, "except for the removal, cleaning, and replacement of ancillary parts of the UST system, which are directly related to the procedures of testing and troubleshooting."

Commenter 3: John Maynes, FUELlowa

Date Received, January 8, 2021

Mr. John Maynes of FUEL lowa presented verbal comments during the public hearing on Friday, January 8, 2021 and then presented written comments describing the same issues. Mr. Maynes noted his association's appreciation for the DNR's willingness to consider comments during the stakeholder meetings that led up to the rule package, but asked for consideration on a few rules.

First, concerning subrules 135.4(8) and 135.4(9) Operator Training. He noted Iowa has been following EPA regulations requiring operator training for over 10 years, yet the rule proposes changing the examination required to complete operator training requirements to a department examination and requiring the operator to pass a department examination by achieving a passing score of 85 percent or greater. FUELIowa requests that these items be removed from the rule.

Mr. Maynes commented that in general, Iowa Code section 455B.474A requires rules adopted by the EPC to be consistent with and shall not exceed the federal regulations relating to the regulation of underground storage tanks. Mandating operators to take a department examination and achieve a baseline score of 85 percent to pass are not requirements within the federal regulation so should be removed. Mr. Maynes noted FUELIowa is amenable to working with the DNR to review current operator training requirements noting that with the changes presented in the rule package, changes to the content and examinations being offered by the third-party vendors will be needed. Mr. Maynes also asked for a change to the licensing of testers but in the context of the limitation presented in paragraph 135.25(2)"c". Mr. Maynes asked the date provision be removed to remain consistent the federal regulation, which places no restrictions on persons conducting the prescribed testing.

Commenter 4: Patrick Rounds, PMMIC

Date Received, January 8, 2021

In the comments presented by Mr. Patrick Rounds, President and COO of PMMIC Insurance, Mr. Rounds notes that PMMIC is one of the stakeholders who has been working with the DNR since 2015 to develop these rules. The required changes to implement the new federal regulations are significant and PMMIC is supportive of the majority of the changes; however, it was noted the proposed rules are still a work in progress and outlined a few changes to consider.

Mr. Rounds stated concerns have been discussed with the DNR and asked that the concerns be addressed prior to these rules becoming final. Mr. Rounds noted one of their key concerns include ensuring that the rule language mirrors federal regulations. Another was ensuring that new requirements are not more stringent than the federal regulations; cleaning up language that may create ambiguities or confusion going forward; properly implementing training, licensing and certification processes; ensuring small businesses are not burdened with greater costs than necessary, and ensuring that forms and policies are also not more stringent than federal regulations. PMMIC's comments were presented in multiple sections of the NOIA.

PMMIC also submitted comments on licensing subrules 134.24(3) and (4), 134.25(2) and (3), 134.27 (2) and (3), as they pertain to the responsibilities of and documentation of the work performed by certified installers, testers, and installation inspectors. PMMIC stated their belief that the certification rules overlap with the technical rules in Chapter 135 so the certification rules should be deleted; but if those rules are deemed necessary, they should be inserted into Chapter 135. As these comments would result in a substantial revision to both Chapters 134 and 135 if implemented, the DNR requested that this be a topic for future rulemaking, which PMMIC agreed to. Further discussions are needed specifically in light of the fact that Chapter 134 is not tied to Federal regulations and is not subject to review in the State's application for program approval. This approach was agreed upon to allow the current rule package to move forward at this time.

In addition to the rule changes, Mr. Rounds requested changes to the DNR's walkthrough inspection form so that the form does not contain requirements that are more stringent that the federal regulation. He also requested that the language regarding who is qualified to complete the form be removed. Finally, Mr. Rounds asked that the DNR's website accurately reflect the effective date of the rule, specifically regarding walkthrough inspections

Other comments:

In addition to the comments presented by the public, a few additional changes have been incorporated into the rule package to remove unused language, correct citations and terminology, and to add rule changes as recommended by the EPA.

DNR RESPONSE TO COMMENTS:

Thank you for the comments.

DNR RESPONSE; CHANGES TO FINAL RULE

Following the January 8, 2021 deadline for presenting written comments, the DNR met with the commenters on January 21, 2021, and with the commenters and Mr. Grant Palmer, representing the Iowa Petroleum Equipment Contractors Association (IPECA), on January 25, 2021, to review the comments and consider options for the concerns presented. Following discussion, the DNR has agreed to the following revisions to the rules to address stakeholder concerns and the comments of the ARRC committee members. Several rule modifications were necessitated by the change in nomenclature regarding "certified" rather than "licensed" compliance inspectors, as provided in Chapter 134, Part B Certification of Compliance Inspectors.

ITEM 13. Amend rule 567—134.7(455B) as follows:

567—134.7(455B) Certification requirements for UST compliance inspectors.

Item 13: 134.7(2) Inspector certification will be issued by the department only to a person who:

- a. no change from NOIA
- 2.b. Attends the required training approved by the department as provided in rule 567—134.10(455B).
- (1) Temporary exception to required training. An applicant may be issued a license certification without the required training if all other requirements of Part B of this chapter are satisfied and the required training is not offered within 60 days of the date of application. The applicant must attend required training within one year or, if training is not offered within one year, when required training is next offered. If an applicant receives a license certification under this temporary exception, the individual must attend required training, if offered, before renewal of the license certification.
- (2) If an applicant receives a license certification under a temporary training exception pursuant to paragraph 134.7(2)"a," all compliance inspection activities must be conducted under the supervision of a trained lowa-certified compliance inspector. Supervision does not require the trained lowa-certified compliance inspector to be on site for compliance inspections conducted by the inspector who has not completed the required training. The trained lowa-certified compliance inspector must co-sign compliance inspections conducted by the inspector who has not completed the required training.
- $\frac{3. c.}{2.}$ Achieves a passing grade of $\frac{8575}{2.}$ percent on a certification examination administered or approved by the department as provided in <u>rule</u> $\frac{567-134.10}{455B}$.
 - 4. <u>d.</u> Submits an accurate and complete application.
- 5. <u>e.</u>Is not found to be in violation of this chapter and has not had a certification revoked by the department pursuant to <u>rule</u> 567—134.16(455B)or by the underground storage tank fund board pursuant to 591—Chapter 15.

DNR response: Change "license" to "certification"; reduce passing grade required to 75 percent.

ITEM 16. Amend rule 567—134.10(455B) as follows:

567—134.10(455B) Training and certification examination

134.10(1) Prior to taking the compliance inspector examination, the applicant must:

a. Complete the U.S. EPA UST Web-based training modules: "Introduction to the Underground Storage Tanks (UST) Program" and "Basic UST Inspector Training" with a minimum passing grade of 85-percent.

b. Attend attend the department's inspector training course or designated approved course.

134.10(2) to 134.10(4) No change.

134.10(5) To receive a passing grade on the examination, the applicant for certification must achieve a minimum score of <u>8575</u> percent. An applicant who fails an initial examination may take a second examination.

134.10(6) No change.

DNR response: Reduce passing grade required to 75 percent.

ITEM 19. Amend rule 567—134.13(455B) as follows:

567—134.13(455B) Licensed Certified company. A company employing certified UST compliance inspectors shall be registered with the department as a <u>licensed</u> certified UST compliance company. A company shall lose its <u>license</u> certification if it fails to employ at least one certified inspector or if it employs uncertified individuals to do compliance inspections required by the department. The <u>annual initial and biennial renewal license</u> certification fee is \$50 \$200.

DNR response: Change nomenclature wording "licensed" to "certified" and "license" to "certification"

NEW ITEM 21. Amend subrule 134.14(1) as follows:

134.14(1) Inspection process. The inspector shall record the inspection on a form provided by the department and conduct the inspection to address all items contained on the inspection form. The department may approve an alternative inspection form if requested by the inspector. The completed inspection form must be maintained by the inspector or licensed certified company for five years. Upon completion of the site inspection, the inspector shall send an inspection report to the owner and operator within ten business days, except for the notice of a potential suspected or confirmed release as provided in paragraph "b." At a minimum, the report shall satisfy the following: a. to d. No change

DNR response: Change nomenclature wording "licensed" to "certified"

NEW ITEM 24. Amend rule 567—134.15(455B) as follows:

567—134.15 (455B) Disciplinary actions.

134.15(1) The department may impose disciplinary actions which may include, but are not limited to, notices of deficiency, probationary notices, suspension of a certification-or license and, pursuant to 567—134.16(455B), revocation of a certification or license.

134.15(2) No change.

134.15(3) The department may suspend the certification of a certified inspector or licensed certified company for good cause, and based on a single act or omission or repeated acts or omissions. The suspension may require the certified inspector to take remedial measures intended to correct or

prevent future acts and omissions. Good cause includes, but is not limited to: a. to f. No change.

134.15(4) The suspension of a company <u>license</u> <u>certification</u> or inspector certification shall prevent the company or person from engaging in activities for which certification or licensure is required. **134.15(5)** No change.

134.15(6) A certified inspector or licensed certified company shall immediately surrender the certificate-or license, as applicable, to the department as of the effective date of a suspension order. The department may reinstate the certification or license if it is determined the person has satisfied the terms of the suspension order and the certification has not expired.

DNR response: Change nomenclature wording "license" to "certification" and "licensed" to "certified"

NEW ITEM 25. Amend rule 567—134.16(455B) as follows:

567—134.16 (455B) Revocation of inspector certification or company license certification.

134.16(1) The department may revoke the inspector certification or company license certification for one or more of the following:

a. to c. No change.

d. Acts or omissions warranting suspension after having certification-or license previously suspended.

e. The revocation of a certification as an installer or installation inspector under 591—Chapter 15 <u>rule</u> <u>567—134.24(455B)</u> or 567—134.27(455B).

134.16(2) A certified inspector or licensed certified company shall immediately surrender certification or licensing documents after the effective date of a revocation decision.

These rules are intended to implement Iowa Code section 455B.474.

DNR response: Change nomenclature wording "license" to "certification" and "licensed" to "certified"

ITEM 26. Amend rule **567—134.17(455B)**, definitions of <u>"Deductible," "In the aggregate,"</u> "Modification," <u>"OSHA,"</u> "Removal," <u>"Self-insured retention,"</u> "Underground storage tank professional" and "Underground storage tank system," as follows:

"Deductible" means the portion of a claim paid by insureds on the policy issued by the board.

"In the aggregate" means for all claims or suits in a single year seeking damages-under an insurance policy issued by the board.

"Modification" means to change a UST system currently in use by the installation of new UST system components. "Modification" includes, but is not limited to, the addition of corrosion protection to a previously lined tank, installation of new underground piping or replacement of existing underground piping, changing the primary release detection method to one of the methods listed in OAR 340-150-0450 through 340-150-0470, or adding secondary containment. "Modification" does not include those activities defined in this rule as "repair" or "replacement."

"OSHA" means the Occupational Safety and Health Act Administration.

"Removal" means the process of removing and disposing of an underground storage tank system no longer in service or the process of abandoning an underground storage tank system in place, in accordance with rule $\frac{567-135.9(455B)}{567-135.15(455B)}$.

"Self-insured retention" means the portion of a claim paid by insureds who self-insure a portion of their risk as part of a policy issued by the board. Expenses included as a part of the self-insured retention are the cost of claims settlements or suits, the cost of adjusting, legal fees, court costs and any other investigative cost associated with the claim.

DNR response: Delete phrase "issued by the board"; correct wording errors

ITEM 28. Amend rule 567—134.19(455B)

134.19(6) Examinations and course of instruction. Prior to the issuance of a license as an installer, installation inspector, remover, liner, tester, or cathodic protection tester, the applicant shall successfully complete a department or department-approved course of instruction and pass a qualification examination approved by the department.

- a. Examination requirements for all license holders.
- (1) A passing grade of not less than 8575 percent is required on the Iowa examination.
- (2) to (4) No change.
- b. to d. No change.

134.19(7) Continuing education. Each person licensed under Part C of this chapter shall complete a department-approved refresher course every two years, except for licensed cathodic protection testers. Cathodic protection testers shall maintain NACE or STI certification or another certification approved by the department. Beginning with the first application for license renewal, each UST professional shall provide evidence to the department, prior to submission of the application for renewal, that at least 42 eight credit hours of department-approved continuing education have been satisfactorily completed since the last license was issued or renewed. The department may limit the number of credit hours granted for similar courses during a renewal period. The requirement for continuing education may be met only by those continuing education offerings which have been approved by the department.

DNR response: Reduce passing grade required to 75 percent. Delete the word "credit" to be consistent with other continuing education provisions in rule.

ITEM 30. Amend subrule 134.24(3) as follows:

134.24(3) Responsibilities of installers.

- a. no change from NOIA
- b. no change from NOIA
- c. Testing of UST equipment. Spill prevention equipment, containment sumps and UDC at new installations must be tested to ensure the equipment is liquid-tight before the UST system is placed into service. Acceptable test methods include vacuum, pressure or liquid testing used in accordance with requirements developed by the manufacturer, a code of practice such as PEI RP1200 or methods determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule. Licensed installers may also perform periodic testing of spill and overfill devices, containment sumps and UDC as required by 567-Chapter 135

DNR response: Delete sentence as superfluous.

ITEM 32. Amend rule 567—134.25(455B), introductory paragraph, as follows:

567—134.25(455B) Testers. A tester of underground storage tank systems shall apply for licensing as a tester and note on the license application the systems and method(s) of testing the tester will use, except that a person engaging in testing described in paragraph 134.25(2) "b" need not be licensed if that person is under the supervision of an individual licensed under Chapter 134, Part B or Part C, when conducting those tests. In addition to the licensing requirements listed under rule 567—134.19(455B), a tester shall provide documentation of at least two years of relevant experience, documentation of manufacturer certification for past testing, and proof of current certification for future work. the following:

a. Current manufacturer certification(s) for equipment being used for testing; and

b. Experience as documented by at least one of the following:

- 1. One years of relevant experience.
- 2. Has completed a minimum of 80 on-site tests with an lowa-licensed tester.
- 3. Other relevant experience as approved by the department.

DNR response: Change the qualifications needed for licensing of a tester; provides for additional avenues to become a licensed UST Tester.

ITEM 33. Amend subrule 134.25(2) as follows:

134.25(2) Documentation of work performed Responsibilities of testers. A copy of the test results shall be attached to DNR Form 148 when testing is done in connection with a new installation or the upgrading of an existing underground storage tank system. The licensed tester is responsible for testing tanks, lines, leak detection systems, or monitoring systems as required by 567—Chapter 135 and this chapter. An owner, operator or an employee of an owner or operator performing leak detection or cathodic protection monitoring, as required by 567—Chapter 135, is not a tester. A tester license does not qualify an individual to perform replacements or repairs to a UST system.

- a. no change from NOIA
- b. A licensed tester may also perform periodic inspections of overfill devices and testing of spill prevention equipment, containment sumps and UDC as required by 567—Chapter 135. Spill prevention equipment, containment sumps and UDC at new installations must be tested to ensure the equipment is liquid-tight before the UST system is placed into service. Acceptable methods include vacuum, pressure or liquid testing used in accordance with requirements developed by the manufacturer, a code of practice such as PEI RP1200 or methods determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule.
- c. Periodic testing of spill prevention equipment, containment sumps and UDC as required by Subrule 135.4(12) conducted prior to October 13, 2021, may be conducted by a service technician. An individual licensed under Chapter 134, Part B or Part C, is not required to conduct periodic inspections of overfill devices and testing of spill prevention equipment, containment sumps, and UDC as required by 567—subrule 135.4(12) prior to October 13, 2021.

DNR response: Delete sentence on what a tester may do as superfluous. For clarity, add "prevention equipment" after the word "spill". Include inspection of overfill devices as part of the periodic maintenance checks, consistent with 135.4(12). Delete reference to October 13, 2021, limitation.

NEW ITEM 58. Amend paragraph 135.3(8)"e"(1) as follows:

(1) Prior to imposing a delivery prohibition response action under paragraph 135.3(8)"b" above, the department will provide notice to the owner or operator or, if notice to the owner or operator cannot be confirmed, to a person in charge at the UST facility of the basis for the finding and the intent to initiate a delivery prohibition response action. Notice may be by verbal contact, by facsimile, or by regular or certified mail to the UST facility address or the owner's or operator's last-known address. The owner and operator will be given a minimum of one business day to provide documentation that the finding is inaccurate or that reinstatement criteria in subparagraphs 135.3(8)"b"(1) through (5) have been satisfied. Additional days and the opportunity for a telephone or in-person conference may be provided the owner and operator to contest the factual basis for a finding under subparagraphs 135.3(8)"b"(6) through (1014). Additional procedural due process may be afforded the owner and operator on a case-by-case basis sufficient to satisfy Constitutional due process standards.

DNR response: Update rule citation to be consistent with new numbering sequence.

ITEM 62. Amend subrule 135.4(2) as follows:

135.4(2) Operation and maintenance of corrosion protection. All owners and operators of steel metal UST systems with corrosion protection must comply with the following requirements to ensure that releases due to corrosion are prevented for as long as until the UST system is used to store regulated substances. permanently closed or undergoes a change in service in accordance with 135.15(2).

DNR response: Add phrase per request of EPA, requiring corrosion protection to remain active until the UST system is permanently closed.

ITEM 69. Amend paragraph 135.4(7)"a", as follows:

- a. Class A operator.
- (1) Class A operators have the primary responsibility to operate, and maintain, and have knowledge of the regulatory requirements for the underground storage tank system and facility. The Class A operator's responsibilities include managing resources and personnel to achieve and maintain compliance with regulatory requirements under this chapter in the following ways:
- 1. Class A operators assist the owner by ensuring that underground storage tank systems are properly installed and expeditiously repaired and inspected; financial responsibility is maintained; and records of system installation, modification, inspection and repair are retained and made available to the department and licensed certified compliance inspectors. The Class A operator shall properly respond to and report emergencies caused by releases or spills from UST systems, ensure that the annual tank management fees are paid, and ensure that Class B and Class C operators are properly trained.
 - 2. No change.
 - 3. No change.
- (2) Department-licensed installers, installation inspectors, and <u>department-certified</u> compliance inspectors may perform Class A operator duties when employed or contracted by the tank owner to perform these functions so long as they are properly trained and designated as Class A operators pursuant to subrules 135.4(9) through 135.4(11). Class A operators who are also <u>licensed certified</u> compliance inspectors under 567—Chapter 134, Part <u>CB</u>, may perform in-house facility inspections of the UST system, but shall not perform department-mandated compliance inspections pursuant to rule 567—135.20(455B). Compliance inspections of a UST facility required by rule 567—135.20(455B) must be completed by a third-party compliance inspector <u>licensed certified</u> under 567—Chapter 134, Part B.
 - (3) No change.
 - (4) No change.

DNR response: Add new items to change term "licensed compliance inspector" to "certified compliance inspector" to ensure no confusion in the regulation of compliance inspectors.

ITEM 70. Amend paragraph **135.4(7)"b"**, as follows:

(1) A Class B operator implements is knowledgeable of the applicable underground storage tank regulatory requirements and standards and implements them in the field or at the tank facility. A Class B operator oversees and implements the day-to-day aspects of operation, maintenance, and record keeping for the underground storage tanks at facilities within four hours of travel time from the Class B operator's principal place of business. A Class B operator's responsibilities include, but are not limited

to:

- 1. to 8. No change.
- 9. Training and documenting Class C operators to make sure at least one Class C operator is on site during operating hours. Class B operators shall be familiar with Class C operator responsibilities and may provide additional required training for Class C operators.
- (2) Department-licensed installers, installation inspectors, and <u>department-certified</u> compliance inspectors may perform Class B operator duties when employed or contracted by the tank owner to perform these functions so long as they are properly trained and designated as Class B operators under subrules 135.4(9) through 135.4(11). Class B operators who are also <u>licensed certified</u> compliance inspectors under 567—Chapter 134, Part €<u>B</u>, may perform in-house facility inspections of the UST system, but cannot perform department-mandated compliance inspections pursuant to rule 567—135.20(455B). Compliance inspections of a UST facility pursuant to rule 567—135.20(455B) must be completed by a third-party compliance inspector <u>licensed certified</u> under 567—Chapter 134, Part B.
 - (3) No change.

DNR response: Delete the added word "additional" and delete "required", as it is redundant. Add new items to change term "licensed compliance inspector" to "certified compliance inspector" to ensure no confusion in the regulation of compliance inspectors.

NOIA ITEM 69. Amend subrule 135.4(8), introductory paragraph, as follows:

135.4(8) UST operator training course requirements. Individuals must attend a department- approved training course covering material designated for each operator class. Individuals must attend every session of the training, and take the department's examination, and attend examination review. (REVERT TO ORIGINAL LANGUAGE)

DNR response: Delete the added requirement for a department examination; revert to original language in existing rule.

NOIA ITEM 73. Amend subrule 135.4(9) as follows:

135.4(9) Examination and review requirement. Class A and Class B operators must complete the department-approved training course and take <u>an</u> and achieve a passing grade of 85 percent on the examination to verify their understanding and knowledge. The examination may include both written and practical (hands-on) testing activities. The trainer must follow up the examination with a review of missed test questions with the class or individual to ensure understanding of problem areas. Upon successful completion of the training course, the applicant will receive a certificate verifying the applicant's status as a Class A, Class B, or Class C operator. (REVERT TO ORIGINAL LANGUAGE)

DNR response: Delete requirement for passing an exam with a grade of 85 percent; revert to original language in existing rule.

ITEM 78. Adopt the following **new** subrules 135.4(12) and 135.4(13):

135.4(12) Periodic testing of spill prevention equipment and containment sumps used for interstitial monitoring of piping and periodic inspection of overfill prevention equipment.

- a. no change from NOIA
- (1) no change from NOIA
- 1. The equipment is double walled and the integrity of both walls is periodically monitored at a

frequency of not less than every 30 days the frequency of the walkthrough inspections described in 135.4(13). If owners and operators discontinue periodic monitoring of this equipment, they must begin meeting paragraph 135.4(12)"a"(1)"2" and conduct a test within 30 days of discontinuing periodic monitoring of this equipment; or

- 2. no change from NOIA
- (2) Overfill prevention equipment must be inspected at least once every three years. At a minimum, the inspection must ensure that overfill prevention equipment is set to activate at the correct level specified in paragraph 135.3(1) "c" and will activate when regulated substance reaches that level. Inspections must be conducted in accordance with one of the following criteria:
- Requirements developed by the manufacturer (Note: Owners and operators may use this option only if the manufacturer has developed requirements); or
- A code of practice developed by a nationally recognized association or independent testing laboratory; or
- Requirements determined by the department to be no less protective of human health and the environment than the requirements listed in this section-subrule.
 - b. no change from NOIA
 - c. no change from NOIA

135.4(13) no change from NOIA

DNR response: Modification to frequency of walkthrough inspections to conform to federal rule. Nomenclature corrections.

ITEM 96. Adopt the following **new** paragraph **135.5(4)"h"**:

- h. no change from NOIA
- (1) to (5) no change from NOIA
- (6) The statistical inventory reconciliation method must be certified by a third party and meet US EPA testing procedures in *Standard Test Procedures for Evaluating Release Detection Methods: Statistical Inventory Reconciliation* (EPA 510-B-19-004) May 2019 or as revised by EPA.

DNR response: Update reference to current EPA standard method and add phrase to allow for updates to methodology.

ITEM 97. Amend paragraphs 135.5(5)"a" to "c" as follows:

- a. no change from NOIA
- b. Line tightness testing. A periodic test of piping may be conducted only if it can detect a 0.1 gallon-per-hour leak rate at one and one-half times the operating pressure. The line leak detection method must be certified by a third party and meet US EPA testing procedures in Standard Test Procedures for Evaluating Release Detection Methods: Pipeline Release Detection (EPA 510-B-19-005) May 2019 or as revised by EPA.
 - c. no change from NOIA

DNR response: Update reference to current EPA standard method and add phrase to allow for updates to methodology.

ITEM 143. Amend paragraph 135.12(10)"b," introductory paragraph, as follows:

b. No further action certificate. When the no action required site classification has been

determined based on a recommendation of the certified groundwater professional as provided in <u>subrules</u> 135.9(11), 135.10(11) and $\frac{135.12(12)}{135.12(6)}$ (see also $\frac{2009}{135.12(6)}$ lowa Code Supplement section $\frac{4558.474(1)"h"(1)}{100}$ and $\frac{4558.474(1)"a"(8)(a)}{100}$
DNR response: Correct citation to Iowa Code.

ITEM 144. Amend subparagraph 135.12(10)"b"(9) as follows:

(9) The owner or operator or other persons conducting corrective action shall be responsible for recording the no further action certificate with the county recorder and return a file-stamped copy to the department within 30 days of the issue date. At its discretion, the department may record the no further action certificate with the appropriate county recorder as authorized in 2009 lowa Code Supplement section 455B.474(1)"h"(3) as amended by 2010 lowa Acts, House File 2531, section 174 455B.474(1)"a"(8)(c).

DNR response: Correct citation to Iowa Code.

ITEM 150. Amend subrule 135.15(3) as follows:

135.15(3) Assessing the site at closure or change-in-service

a. no change from NOIA

b. For all permanent tank and piping closures or changes-in-service, at least one water sample must be taken from the first saturated groundwater zone via a <u>developed</u> monitoring well or borehole except as provided in paragraph 135.13 "g." The well or borehole must be located downgradient from and as close as possible to the excavation <u>UST system</u> but no farther away than 20 feet <u>from system components</u>. At some tank and piping closures, a minimum of one monitoring well may not be sufficient to represent a release where it is most likely to be present. An additional groundwater monitoring well or wells may be necessary.

DNR response: Strike added citation; paragraph 'g' is correct.

FURTHER WORK

In addition to the changes noted, PMMIC's comment regarding the overlap of Chapter 134 provisions regarding responsibilities of UST professionals with Chapter 135 provisions on the technical requirements for owners, warrants further consideration. As addressing these comments would result in a substantial revision to both Chapters 134 and 135, the DNR requested that this topic be deferred to a future rulemaking, which PMMIC agreed to. Further discussions are needed specifically in light of the fact that Chapter 134 is not tied to federal regulations and is not subject to review in the State's application for program approval. The authority for certification and licensing requirements is found in Iowa Code 455B.474(1)"a"(8) and 455B.474(1)"a"(10).

Lastly, from the comments presented by Mr. Rounds and from the acknowledgement of the ARRC, the DNR is in the process of looking at options to revise certain inspection forms to ensure that the forms are consistent with federal requirements. These include the 30-day walkthrough form and the Secondary Containment Testing Form. Additional forms may also be revised to ensure appropriate information is being provided to the DNR, consistent with federal requirements and as needed by the DNR to ensure that State Program approval is maintained.

ENVIRONMENTAL PROTECTION COMMISSION [567]

Adopted and Filed

The Environmental Protection Commission (Commission) hereby amends Chapter 134, "Underground Storage Tank Licensing and Certification Programs," Chapter 135, "Technical Standards and Corrective Action Requirements for Owners and Operators of Underground Storage Tanks," and Chapter 136, "Financial Responsibility for Underground Storage Tanks," Iowa Administrative Code.

Legal Authority for Rule Making

This rule making is adopted under the authority provided in Iowa Code section 455B.474.

State or Federal Law Implemented

This rule making implements, in whole or in part, Iowa Code sections 455B.474 and 455B.474A.

Purpose and Summary

The purpose of this rulemaking is to conform Chapters 134, 135, and 136 to recently enacted federal rules promulgated by the U.S. Environmental Protection Agency (EPA). The Commission must adopt rules consistent with EPA's rules in order for the Department of Natural Resources (Department) to maintain its delegated state program.

Specifically, this rulemaking adopts the 2015 federal Underground Storage Tank (UST) rule revisions contained in 40 Code of Federal Regulations Parts 280 and 281. The amendments also update and remove outdated provisions, clean up language, and revise leaking underground storage tank (LUST) rules to be consistent with current risk evaluation processes.

The federal UST rule revisions improve upon the 1988 federal UST regulations by increasing emphasis on properly operating and maintaining UST equipment. The revisions will help prevent and detect UST petroleum releases, which are a leading source of groundwater

contamination, often resulting in expensive cleanups. The primary provisions of the federal rule that have been incorporated into the amendments include:

- Regulation of certain tanks that were deferred by the 1988 regulations (i.e., emergency power generator tanks, airport hydrant fuel distribution systems, and field-constructed tanks);
- Disallowing flow restrictors in vent lines for new installations or when replacing equipment;
- Requiring the closure of internally lined tanks that fail a lining inspection and cannot be repaired;
- Requiring a demonstration that equipment is compatible with the fuel stored (addressing biofuel compatibility);
 - Monthly and annual facility walkthrough inspections;
 - Annual release detection equipment testing;
 - Spill prevention equipment testing every three years;
 - Overfill prevention equipment inspection every three years; and
- Containment sump testing every three years of sumps used for piping interstitial monitoring.

Other revisions are adopted as part of the Department's five-year rules review process. At the request of multiple stakeholders, Chapter 134 was amended. New federal testing requirements have been added, and it has been clarified which licensees must perform the federal tests and by when they must be performed. Compliance inspector certification criteria were expanded to allow more persons to qualify. Licensure training time frames were relaxed to add more flexibility to the

process. This change in particular will alleviate some industry concerns about inconsistent licensure class schedules impacting business.

Additionally, stakeholder-supported amendments have been made to the license fees in Chapter 134. The fee for compliance inspector certification has been lowered, although this may not be obvious at first. Previously, a compliance inspector had to also be a licensed installer, so two license fees were always owed for an initial certification: \$150 for compliance inspector and \$200 for installer, for a total of \$350. That requirement has been removed. Under the adopted amendments, a compliance inspector will be a stand-alone license class, subject to a single initial \$200 fee. Therefore, this amendment will produce \$150 in savings for many UST professionals. The biennial renewal fee has been changed as well. Previously, a compliance inspector had to renew biennially both the inspector certification (\$50) and the installer license (\$200) for a total renewal fee of \$250. The new biennial renewal will be a single fee of \$200. This amendment will produce another \$50 in on-going savings. Similarly, the UST compliance company initial and biennial license fee has been raised from \$50 to \$200. This amendment will make this fee consistent with the \$200 fee assessed for all other Chapter 134 license classes (installers, installation inspectors, liners, testers, removers, and groundwater professionals).

Other five-year rules review process amendments include removing outdated or unused regulations and references. And, finally, some provisions have been updated to reflect what the Department has learned over the last 20 years of the risk-based corrective action (RBCA) evaluation process, remediation methods, tank temporary closure requirements, and tank system corrosion protection.

Public Comment and Changes to Rule Making

Notice of Intended Action (NOIA) for this rule making was published in the Iowa Administrative Bulletin on December 16, 2020, as **ARC 5316C**.

Three virtual public hearings were held on January 6, 2021, January 7, 2021, and January 8, 2021, at 1 p.m. each day. Three people from the public attended the meetings. Oral and written comments were received from FUELIowa. Written comments were also received from Tanknology, Petroleum Marketers Management Insurance Company (PMMIC), and Kwik Trip, Inc. Comments related primarily to Chapter 134 – licensing requirements, but also operator training requirements under Chapter 135. Two meetings with the commenters were held on January 21, 2021, and January 25, 2021, to determine what additional rule modifications were necessary to address their concerns.

Kwik Trip, Inc. and Tanknology recommended reconsideration of the years of experience required for an individual licensed as a tester of UST systems. In addition, Tanknology recommended a change to the rule regarding the responsibilities of testers to allow testers to complete cleaning and repairs of equipment tested. FUELIowa asked for a change to the licensing of testers; specifically, that the date be removed which places restrictions on persons who can conduct the prescribed periodic testing.

FUELIowa and PMMIC expressed appreciation to the Department for collaboration in revising the rules and both are supportive of the majority of the changes. Both entities referenced Iowa Code section 455B.474A, noting that the rules adopted by the Commission are to be consistent with and shall not exceed the federal regulations relating to the regulation of USTs. Both entities recommended changes to operator training provisions, specifically removing a passing grade requirement for the training exam, and relying on vendor-led training and examination criteria. FUELIowa and PMMIC emphasized the need to continue collaboration in implementing the new regulations, and in the development of forms to ensure these also do not contain requirements more stringent than federal regulations. PMMIC also proposed changes

regarding use of consistent terms throughout the rules. Additionally, they recommended a change in the passing grade for the compliance inspector examination.

Several edits were made to the NOIA in response to public comments:

- Rule 567--134.7(455B) [ITEM 13] was modified by lowering the passing grade threshold, and correcting the terminology from "license" to "certification" and "licensed" to "certified." This necessitated other rule changes to make the grade threshold and terminology consistent (see Items 16, 19, 21, 24, 25, 28, 69, and 70).
- A redundant sentence was deleted in subrule 134.24(3) [ITEM 30].
- Subrules 134.25 and 134.25(2) [ITEMS 32 and 33] were modified to expand qualification criteria for testers, to allow testers to perform repairs, and to remove the date restriction.
- Clarification was added to Class C operator training in subparagraph 135.4(7)"b"(1) [ITEM 70].
- Subrules 135.4(8) and 135.4(9) were reverted back to the original language (i.e., no rule modifications were made regarding operator training and examination requirements) [former ITEMs 69 and 73 in the NOIA].

In addition to the comments by the public, other changes have been made from the NOIA to remove unused language, to correct citations and terminology, and to make language consistent with federal rule provisions. These are as follows:

- Subrule 134.17 Definitions, [ITEM 26] was modified by removing references to the board and correcting the definition for OSHA.
- The word 'credit' was deleted from the continuing education section under subrule 134.19 [ITEM 28].
- A rule citation correction was made under subparagraph 135.3(8)"e"(1) [ITEM 58].

- Subrule 135.4(2), [ITEM 62] was modified to be consistent with the federal rule, clarifying corrosion protection for metal UST systems must be maintained until the UST system is permanently closed.
- Subrule 135.4(12), [ITEM 78] was modified to be consistent with the federal rule regarding frequency of monitoring double walled spill equipment and containment sumps.
- Paragraph 135.5(4)"h", [ITEM 96] was modified to be consistent with the federal rule in citing an EPA standard for testing procedures.
- Paragraph 135.5(5)"b", [ITEM 97] was modified to be consistent with the federal rule in citing an EPA standard for testing procedures.
- Iowa Code citation corrections were made under paragraph 135.12(10)"b" and subparagraph 135.12(10)"b"(9) [ITEMS 143 and 144].

The details of these changes can be viewed in the responsiveness summary for this rule making on the Department's UST regulations web page at https://www.iowadnr.gov/Environmental-Protection/Land-Quality/Underground-Storage-Tanks/UST-LUST-Regulations.

Adoption of Rule Making

This rule making was adopted by the Commission on April 20, 2021.

Fiscal Impact

This rule making has no meaningful fiscal impact to the State of Iowa. The Commission anticipates a minimal reduction, perhaps \$2,400, in license revenue due to the changes to the licensing fees in Chapter 134. A copy of the fiscal impact statement is available from the Department upon request.

There will be a fiscal impact to industry but it cannot be uniformly determined. EPA estimates an average annual compliance cost of \$715 per facility. However, the Commission and stakeholders jointly estimate an annual cost per facility between \$1,147 and \$4,053 depending on a facility's size, equipment, location, and frequency of inspections. The proposed amendments to license certification, qualifications, and fees in Chapter 134 will provide a \$150 one-time and \$50 on-going cost savings to some licensed UST professionals. Additional amendments may provide a cost savings to UST owners and operators who hire licensed UST professionals. For instance, amendments that allow service technicians to complete certain containment equipment testing, rather than requiring that a licensed UST professional complete the testing, may reduce associated costs. More information of these estimates is included in the Commission's fiscal impact statement.

The Commission believes that costs to comply with the new regulations may decline with time. For example, the first cycle of testing will identify faulty equipment at some facilities which will require repair or replacement. The fixed or newer equipment is expected to be durable and operable through subsequent testing cycles. Additionally, with time it is expected that new testing technologies will be developed that are more efficient and economical.

Jobs Impact

Both minor positive and minor negative impacts on private sector jobs and employment opportunities in the state are anticipated as a result of the proposed rule. Additionally, if the proposed rule making is not adopted, facilities will be required to comply with federal standards and separate state standards. Therefore, the effect on jobs could be considered neutral. A copy of the jobs impact statement is available from the Department upon request.

Waivers

Any person who believes that the application of the discretionary provisions of this rule making would result in hardship or injustice to that person may petition the Department for a waiver of the discretionary provisions, if any, pursuant to 561—Chapter 10.

Review by Administrative Rules Review Committee

The Administrative Rules Review Committee, a bipartisan legislative committee which oversees rule making by executive branch agencies, may, on its own motion or on written request by any individual or group, review this rule making at its regular monthly meeting or at a special meeting. The Committee's meetings are open to the public, and interested persons may be heard as provided in Iowa Code section 17A.8(6).

Effective Date

This rule making will become effective on June 23, 2021.

The following rule-making action is adopted:

ITEM 1. Amend rule 567—134.1(455G), parenthetical implementation statute, as follows:

567—134.1(455G 455B) Definition.

ITEM 2. Amend rule 567—134.2(455G) as follows:

567—134.2(455G 455B) Certification requirements.

- **134.2(1)** A groundwater professional must be certified as provided in 134.3(455G) <u>rule 567—134.3(455B)</u> before engaging in activities described in 134.1(455G) <u>rule 567—134.1(455B)</u>, except that a person engaging in activities described in 134.1(455G) <u>rule 567—134.1(455B)</u> need not be certified if that person is under direct supervision of a certified groundwater professional when engaging in such activities.
 - **134.2(2)** No change.
- **134.2(3)** In order to be certified as a groundwater professional, the applicant must complete the two-day risk-based correction action (RBCA) course or department-approved course and pass a certification examination offered or authorized by the department.
 - a. An applicant who fails an initial examination may take a second examination.
- b. Failure of the second examination will result in termination of the application. A person may reapply for groundwater professional certification. The applicant must complete a regularly scheduled course of instruction before retaking the certification examination.
- c. Professional engineers who qualify for an exemption from taking the certification examination under subrule 134.3(6) must attend the RBCA initial course of instruction or department-approved course in order to be certified.
 - ITEM 3. Amend rule 567—134.3(455G), parenthetical implementation statute, as follows:

567—134.3(455G 455B) Certification procedure.

- ITEM 4. Amend subrule 134.3(1) as follows:
- **134.3(1)** Application. Application for certification shall be made by completing a form provided by the department and submitting evidence of meeting the requirements found in rule <u>567—134.2(455G 455B)</u> (i.e., copy of certificate, license, description of experience and training).
 - ITEM 5. Amend subrule 134.3(6) as follows:
- **134.3(6)** Exemption from examination. The department may provide for an exemption from the certification examination requirements for a professional engineer registered pursuant to Iowa Code chapter 542B upon submission of sufficient proof of exemption to the Iowa comprehensive petroleum underground storage tank fund board as provided in Iowa Code section 455G.18(8) department. The person must be qualified in the field of geotechnical, hydrological, environmental, groundwater, or hydrogeological engineering. A groundwater professional exempted under this provision must meet the continuing education requirements of subrule 134.3(5).
 - ITEM 6. Amend rule 567—134.4(455G), parenthetical implementation statute, as follows:

567—134.4(455G 455B) Suspension, revocation and denial of certification.

ITEM 7. Amend subrule 134.4(1), introductory paragraph, as follows:

134.4(1) General policy. It is the policy of the department to enforce standards of professional and ethical conduct which are generally accepted within the professions which qualify persons for certification in Iowa as groundwater professionals. The department intends to rely on written standards of professional and ethical conduct and competency which are applicable to persons who qualify for certification by virtue of certification by or membership in a professional organization or state licensure as provided in Iowa Code section 455G.18(2).

ITEM 8. Amend paragraph 134.4(2)"d" as follows:

d. Insufficient proof of qualifications required under rule 134.2(455G) 567—134.2(455B).

ITEM 9. Amend paragraph 134.4(2)"g" as follows:

g. Default on an obligation owed to or collected by the state as provided in Iowa Code section 421.17(34)"e." 421.17(27)"e."

ITEM 10. Amend paragraph 134.4(3)"f" as follows:

f. Material misstatement of facts or misrepresentation of information required to be provided pursuant to Iowa Code chapters 455G and chapter 455B, division IV, part 8.

ITEM 11. Amend rule 567—134.5(455G) as follows:

- 567—134.5(455G 455B) Penalty. A groundwater professional who fails to obtain certification with the department of natural resources as required in this chapter is subject to a civil penalty of \$50. A groundwater professional who knowingly or intentionally makes a false statement or misrepresentation which results in a mistaken classification of a site shall be guilty of a serious misdemeanor and shall have the groundwater professional certification revoked.
- ITEM 12. Amend **567—Chapter 134**, Part A, implementation sentence, as follows: These rules are intended to implement Iowa Code section 455G.18 455B.474(9).
 - ITEM 13. Amend rule 567—134.7(455B) as follows:

567—134.7(455B) Certification requirements for UST compliance inspectors.

<u>134.7(1)</u> A person retained by an owner or operator of a UST facility for the purpose of establishing compliance with the annual <u>a</u> UST compliance inspection required by the department under <u>rule</u> 567—135.20(455B) must hold a current UST compliance inspector certification issued by the department.

134.7(2) Inspector certification will be issued by the department only to a person who:

- 1. <u>a.</u> Is an Iowa-licensed UST installer or installation inspector under 591—Chapter 15, except that the requirement as set forth under 591—subrule 15.3(4) shall not be applicable to a certified UST compliance inspector. Satisfies one of the following:
 - (1) Is an Iowa-licensed UST installer;

- (2) Is an Iowa-licensed installation inspector;
- (3) Has participated on a minimum of 50 on-site compliance inspections with an Iowa-certified compliance inspector;
- (4) Has two years of experience working with petroleum equipment, including installations, maintenance, or testing; or
 - (5) Has other relevant experience approved by the department.
 - 2. <u>b.</u> Attends the required training approved by the department as provided in <u>rule</u> 567—134.10(455B).
- (1) Temporary exception to required training. An applicant may be issued a certification without the required training if all other requirements of Part B of this chapter are satisfied and the required training is not offered within 60 days of the date of application. The applicant must attend required training within one year or, if training is not offered within one year, when required training is next offered. If an applicant receives a certification under this temporary exception, the individual must attend required training, if offered, before renewal of the certification.
- (2) If an applicant receives a certification under a temporary training exception pursuant to paragraph 134.7(2) "a," all compliance inspection activities must be conducted under the supervision of a trained Iowacertified compliance inspector. Supervision does not require the trained Iowacertified compliance inspector to be on site for compliance inspections conducted by the inspector who has not completed the required training. The trained Iowacertified compliance inspector must co-sign compliance inspections conducted by the inspector who has not completed the required training.
- 3. <u>c.</u> Achieves a passing grade of <u>8575</u> percent on a certification examination administered or approved by the department as provided in <u>rule</u> 567—134.10(455B).
 - 4. <u>d.</u> Submits an accurate and complete application.
- 5. <u>e.</u> Is not found to be in violation of this chapter and has not had a certification revoked by the department pursuant to <u>rule</u> 567—134.16(455B)or by the underground storage tank fund board pursuant to 591—Chapter 15.
 - ITEM 14. Rescind and reserve rule **567—134.8(455B)**.
 - ITEM 15. Amend subrule 134.9(3) as follows:
- 134.9(3) Training and certification fees. An initial nonrefundable application fee of $$150 \ \underline{$200}$$ in the form of a check or money order payable to the Department of Natural Resources must accompany the initial application for certification and $$50 \ \underline{$200}$$ for each renewal application. The $$150 \ \underline{$200}$$ application fee covers the cost of the certification examination. The department will assess an additional fee for each training course based upon the cost of administration.

ITEM 16. Amend rule 567—134.10(455B) as follows:

567—134.10(455B) Training and certification examination

134.10(1) Prior to taking the compliance inspector examination, the applicant must

a. Complete the U.S. EPA UST Web-based training modules: "Introduction to the Underground Storage Tanks (UST) Program" and "Basic UST Inspector Training" with a minimum passing grade of 85 percent.

b. Attend attend the department's inspector training course or designated approved course.

134.10(2) to 134.10(4) No change.

134.10(5) To receive a passing grade on the examination, the applicant for certification must achieve a minimum score of <u>8575</u> percent. An applicant who fails an initial examination may take a second examination.

134.10(6) No change.

ITEM 17. Amend subrule 134.11(1) as follows:

134.11(1) Renewal period. Certification shall be for a two-year period and must be renewed by January 1 of each odd-numbered year, beginning January 1, 2009. Applications for renewal must be submitted on a form provided by the department and no later than 60 30 days prior to the expiration date. If a certified inspector fails to renew the certification by the expiration date, the department may grant, upon a showing of good cause, a 30-day grace period during which the applicant may submit the application and payment of the renewal fee as provided in <u>subrule</u> 134.9(3).

ITEM 18. Amend subrule 134.11(3) as follows:

134.11(3) *Minimum inspections*. In order to renew certification, an inspector must have conducted at least 25 12 compliance inspections each year in the past two years.

ITEM 19. Amend rule 567—134.13(455B) as follows:

567—134.13(455B) Licensed Certified company. A company employing certified UST compliance inspectors shall be registered with the department as a licensed certified UST compliance company. A company shall lose its license certification if it fails to employ at least one certified inspector or if it employs uncertified individuals to do compliance inspections required by the department. The annual initial and biennial renewal license certification fee is \$50 \$200.

ITEM 20. Amend rule **567—134.14(455B)**, catchwords, as follows:

567—134.14(455B) Compliance inspection Responsibilities of compliance inspectors.

ITEM 21. Amend subrule 134.14(1) as follows:

134.14(1) Inspection process. The inspector shall record the inspection on a form provided by the department and conduct the inspection to address all items contained on the inspection form. The department may approve an alternative inspection form if requested by the inspector. The completed inspection form must be maintained by the inspector or licensed certified company for five years. Upon completion of the site inspection, the inspector shall send an inspection report to the owner and operator within ten business days, except for the notice of a potential suspected or confirmed release as provided in paragraph "b." At a minimum, the report shall satisfy the following:

a. to d. No change

ITEM 22. Amend subrule 134.14(3) as follows:

134.14(3) Any evidence of violations or deficiencies observed during the inspection must be photographed using a digital camera with at least a 1-2 megapixel resolution. The digital photographs must be submitted as part of the electronic inspection report and maintained by the inspector for five years as part of the inspector's records.

ITEM 23. Amend subrule 134.14(5) as follows:

134.14(5) Inspection technical requirements. An inspector of a UST system must check for compliance with the technical standards of 567—Chapter 135 following the department's guidance. The inspection of a UST system currently in operation shall include, but not be limited to, the following:

a. to g. No change.

Any problems observed during the inspection must be photographed using a digital camera with at least a 1-2 megapixel resolution.

ITEM 24. Amend rule 567—134.15(455B) as follows:

567—134.15 (455B) Disciplinary actions.

134.15(1) The department may impose disciplinary actions which may include, but are not limited to, notices of deficiency, probationary notices, suspension of a certification or license and, pursuant to 567—134.16(455B), revocation of a certification—or license.

134.15(2) No change.

134.15(3) The department may suspend the certification of a certified inspector or licensed certified company for good cause, and based on a single act or omission or repeated acts or omissions. The suspension may require the certified inspector to take remedial measures intended to correct or prevent future acts and omissions. Good cause includes, but is not limited to: *a.* to *f.* No change.

134.15(4) The suspension of a company license certification or inspector certification shall prevent the company or person from engaging in activities for which certification or licensure is required.

134.15(5) No change.

134.15(6) A certified inspector or licensed certified company shall immediately surrender the certificate or license, as applicable, to the department as of the effective date of a suspension order. The department may reinstate the certification or license if it is determined the person has satisfied the terms of the suspension order and the certification has not expired.

ITEM 25. Amend rule 567—134.16(455B) as follows:

567—134.16 (455B) Revocation of inspector certification or company license certification.

- **134.16(1)** The department may revoke the inspector certification or company license <u>certification</u> for one or more of the following:
- a. to c. No change.
- d. Acts or omissions warranting suspension after having certification-or license previously suspended.
- e. The revocation of a certification as an installer or installation inspector under 591 Chapter 15 rule 567—134.24(455B) or 567—134.27(455B).
- **134.16(2)** A certified inspector or <u>licensed</u> certified company shall immediately surrender certification or <u>licensing</u> documents after the effective date of a revocation decision.

These rules are intended to implement Iowa Code section 455B.474.

ITEM 26. Amend rule 567—134.17(455B), definitions of "Deductible," "In the aggregate,"

"Modification," "OSHA," "Removal," "Self-insured retention," "Underground storage tank professional" and "Underground storage tank system," as follows:

"Deductible" means the portion of a claim paid by insureds on the policy issued by the board.

"In the aggregate" means for all claims or suits in a single year seeking damages—under an insurance policy issued by the board.

"Modification" means to change a UST system currently in use by the installation of new UST system components. "Modification" includes, but is not limited to, the addition of corrosion protection to a previously lined tank, installation of new underground piping or replacement of existing underground piping, changing the primary release detection method to one of the methods listed in OAR 340-150-0450 through 340-150-0470, or adding secondary containment. "Modification" does not include those activities defined in this rule as "repair" or "replacement."

"OSHA" means the Occupational Safety and Health Act Administration.

"Removal" means the process of removing and disposing of an underground storage tank system no longer in service or the process of abandoning an underground storage tank system in place, in accordance with rule 567—135.9(455B) 567—135.15(455B).

"Self-insured retention" means the portion of a claim paid by insureds who self-insure a portion of their risk as part of a policy-issued by the board. Expenses included as a part of the self-insured retention are the cost of claims settlements or suits, the cost of adjusting, legal fees, court costs and any other investigative cost associated with the claim.

"Underground storage tank professional" or "UST professional" means an individual licensed by the department under Part C of this chapter. The licensing program includes underground storage tank system installation, installation inspection, UST system testing, tank lining, cathodic protection installation/inspection, and UST removal. The license issued will list the type of work the individual is licensed to perform.

"Underground storage tank system" or "UST system" means a tank or tanks and associated piping intended to contain and dispense petroleum products regulated substances and for which proof of financial responsibility is , or on a date definite will be required to be maintained pursuant to the Federal Resource Conservation and Recovery Act, 40 CFR 280, and the regulations in effect on December 31, 1994, adopted pursuant to that Act or successor Acts or amendments required.

ITEM 27. Amend rule 567—134.18(455B) as follows:

567—134.18(455B) Applicability of Part C. All persons and companies that are currently licensed under the former board rules in rescinded 591—Chapter 15 shall be subject to Part C of this chapter. All persons conducting underground storage tank installations and installation inspections as provided in 567—subparagraph 135.3(1)"e"(2) and installers, installation inspectors, liners, testers, and removers shall be licensed by the

department in accordance with Part C of this chapter. Service technicians as defined in rule 567—134.17(455B) are exempt from licensure under Part C of this chapter.

ITEM 28. Amend rule 567—134.19(455B) as follows:

567—134.19(455B) General licensing requirements. Applications for licenses shall be submitted on a form provided by the department along with all required supporting documentation. Existing licenses as of [insert the effective date of these amendments] and new licenses shall expire December 31, 2010. Subsequently, licenses Licenses shall be issued and renewed on a two-year calendar basis, beginning January 1, 2011 on the odd-numbered years. All applicants must be at least 18 years of age. The applicant shall not have been issued a certificate of noncompliance from the child support recovery unit.

134.19(1) *Licensing classifications.* A separate license will be issued for:

- a. UST installers and installation inspectors;
- b. UST removers;
- c. UST testers;
- d. Cathodic protection testers; and
- e. UST liners .; and
- f. Installation inspectors.

134.19(2) to 134.19(4) No change.

134.19(5) Environmental liability insurance. All license holders, including licensed companies, are required to have environmental liability insurance with minimum liability of \$1 million per occurrence, as well as in the aggregate. Current license holders shall have 45 days from August 19, 2009, to upgrade their environmental liability insurance.

a. to d. No change.

134.19(6) Examinations and course of instruction. Prior to the issuance of a license as an installer, installation inspector, remover, liner, tester, or cathodic protection tester, the applicant shall successfully complete a department or department-approved course of instruction and pass a qualification examination approved by the department.

- a. Examination requirements for all license holders.
- (1) A passing grade of not less than <u>8575</u> percent is required on the Iowa examination.
- (2) to (4) No change.
- b. to d. No change.

134.19(7) Continuing education. Each person licensed under Part C of this chapter shall complete a department-approved refresher course every two years, except for licensed cathodic protection testers. Cathodic protection testers shall maintain NACE or STI certification or another certification approved by the department. Beginning with the first application for license renewal, each UST professional shall provide evidence to the department, prior to submission of the application for renewal, that at least 12 eight-eredit hours of department-approved continuing education have been satisfactorily completed since the last license was issued or renewed. The department may limit the number of eredits-hours granted for similar courses during a renewal period. The requirement for continuing education may be met only by those continuing education offerings which have been approved by the department.

a. to c. No change.

ITEM 29. Amend subrule 134.20(1) as follows:

134.20(1) Renewal applications shall be made on a form provided by the department and received by the department or postmarked no later than November December 1 of the expiration year of the license at issue. The renewal application shall be accompanied by the \$200 renewal fee as specified in subrule 134.19(3) and proof of environmental liability insurance as required under subrule 134.19(5). Applications received after the November December 1 deadline, but before the January 1 expiration date, will be accepted and will require an additional \$50 late fee.

ITEM 30. Amend subrule 134.24(3) as follows:

134.24(3) Responsibilities of installers. A licensed installer shall be on site during the performance of all

work, including subcontracted work, for which the owner/operator has contracted to have completed by the installer. The licensed installer is responsible for all UST-related work at the site and must ensure that the performance of the work and the finished work conform to industry standards and codes and manufacturers' requirements.

- <u>a.</u> <u>Notification.</u> The licensed installer is responsible for ensuring that all local installation permits and notice requirements are satisfied. Tank
- <u>b.</u> Work performed. <u>UST system</u> installation includes all work associated with the placement of the tanks, pipes piping, pumps, dispensers, gauging systems, monitoring systems, corrosion protection, containment sumps, spill and overfill devices, and ancillary systems which, if installed incorrectly, could cause or delay detection of a leak. <u>Tank installation Installation</u> specifically includes excavation, equipment placement, backfilling, piping, electrical work, testing calibration, and start-up. Tank installation also includes installation of the appropriate equipment to meet National Emissions Standards for Hazardous Air Pollutants (NESHAP) requirements (40 CFR § 63.6580, Subpart ZZZZ), including submerged fill and vapor balance systems (Stage 1 vapor recovery) and the testing of those systems.
- c. Testing of UST equipment. Spill prevention equipment, containment sumps and UDC at new installations must be tested to ensure the equipment is liquid-tight before the UST system is placed into service. Acceptable test methods include vacuum, pressure or liquid testing used in accordance with requirements developed by the manufacturer, a code of practice such as PEI RP1200 or methods determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule.
- <u>d.</u> <u>Proof of training.</u> Installers shall have on their person at all times while on a UST job site a 40-hour general site worker program identification card or any valid refresher card that complies with OSHA standards.

ITEM 31. Amend subrule 134.24(4) as follows:

134.24(4) Documentation of work performed. Installing a new UST system or upgrading a UST system requires an installer to submit a copy of DNR Form 148 the department forms and testing documents applicable to the installation, signed by the owner, to the department no later than 30 days after the final third-party inspection or 30 days after completion if no inspection is required. Each licensed installer responsible for the new system installation or the upgrading of an existing system shall sign DNR Form 148 as required by 567—paragraph 135.3(3) "e." Secondary containment testing performed at installation or to meet periodic testing requirements shall be recorded on the department's Secondary Containment Testing form. Test results shall be dated and signed by the licensed installer who performed the test.

ITEM 32. Amend rule 567—134.25(455B), introductory paragraph, as follows:

567—134.25(455B) Testers. A tester of underground storage tank systems shall apply for licensing as a tester and note on the license application the systems and method(s) of testing the tester will use, except that a person engaging in testing described in paragraph 134.25(2)"b" need not be licensed if that person is under the supervision of an individual licensed under Chapter 134, Part B or Part C, when conducting those tests. In addition to the licensing requirements listed under rule 567—134.19(455B), a tester shall provide documentation of at least two years of relevant experience, documentation of manufacturer certification for past testing, and proof of current certification for future work, the following:

a. Current manufacturer certification(s) for equipment being used for testing; and b. Experience as documented by at least one of the following:

- 1. One year of relevant experience.
- 2. Has completed a minimum of 80 on-site tests with an Iowa-licensed tester.
- 3. Other relevant experience as approved by the department.

ITEM 33. Amend subrule 134.25(2) as follows:

134.25(2) <u>Documentation of work performed Responsibilities of testers</u>. A copy of the test results shall be attached to DNR Form 148 when testing is done in connection with a new installation or the upgrading of an existing underground storage tank system. The licensed tester is responsible for testing tanks, lines, leak detection systems, or monitoring systems as required by 567—Chapter 135 and this chapter. An owner, operator or an employee of an owner or operator performing leak detection or cathodic protection monitoring, as required

by 567—Chapter 135, is not a tester.

- <u>a.</u> A precision test is required when the system is covered and is ready to be placed into service; a volumetric, nonvolumetric, or vacuum test may be used as a method for testing the system and a hydrostatic pressure test may be used for testing the lines. Systems used for leak detection or monitoring (such as statistical inventory reconciliation, vapor or water monitoring wells, or tracer-type tests) shall not be acceptable as a precision test at the completion of the installation of a new system or the upgrading of an existing system. Automatic in-tank gauging may be acceptable if third-party U.S. EPA approval as a precision test has been received for testing tanks.
- a. The test results shall identify the tanks tested, the test method employed, and the results of the test. Test results shall be dated and signed by the licensed tester who performed the tests.
 - b. The original DNR Form 148 without attachments shall be mailed to the department.
- b. A licensed tester may also perform periodic inspections of overfill devices and testing of spill prevention equipment, containment sumps and UDC as required by 567—Chapter 135. Spill prevention equipment, containment sumps and UDC at new installations must be tested to ensure the equipment is liquid-tight before the UST system is placed into service. Acceptable methods include vacuum, pressure or liquid testing used in accordance with requirements developed by the manufacturer, a code of practice such as PEI RP1200 or methods determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule.
- c. An individual licensed under Chapter 134, Part B or Part C, is not required to conduct periodic inspections of overfill devices and testing of spill prevention equipment, containment sumps, and UDC as required by 567—subrule 135.4(12).
 - ITEM 34. Renumber subrule 134.25(3) as 134.25(4).
 - ITEM 35. Adopt the following **new** subrule 134.25(3):
- **134.25(3)** Documentation of work performed. A copy of the test results shall be attached to DNR Form 148 when testing is done in connection with a new installation or the upgrading of an existing underground storage tank system. The test results shall identify the tanks and piping tested, the test method employed, and the results of the test. Periodic testing shall be recorded on the department's Secondary Containment Testing form. Test results shall be dated and signed by the licensed tester who performed the tests.
 - ITEM 36. Amend rule 567—134.27(455B), introductory paragraph, as follows:
- 567—134.27(455B) Installation inspectors. In addition to the licensing requirements listed under rule 567—134.19(455B), an installation inspector shall provide documentation of at least one year two years of experience with underground storage installations, testing, inspecting, or design; documentation of manufacturer certification for past work; and proof of current certification for future work. An engineer who intends to apply for licensure as an installation inspector and who has met the requirements in Iowa to be a registered professional engineer (P.E.) may be exempt from the educational requirement so long as UST installation is in the scope of the engineer's P.E. license and regular practice as provided for in rule 567—134.19(455B). Engineers, however, are not exempt from fulfilling the examination requirement.

ITEM 37. Amend paragraph 134.27(2)"c" as follows:

c. For new installations, the first inspection shall occur before the UST system is installed. The second inspection shall occur before the covering of the system, when all tanks and pipes are exposed. The inspector shall witness testing of the primary and secondary piping and testing of the secondary containment, including sumps, under dispenser containment (UDC), and secondary containment leak detection equipment. The final inspection shall occur when all components are operational and the system has been covered, but before actual operation. The installation inspector shall be present on site, shall visually observe all inspections, and shall be able to attest to the results. A video or other recording device showing the work completed by the installer shall not be used nor shall it be an acceptable method of providing independent inspection of the work completed.

ITEM 38. Amend subrule 134.27(3) as follows:

134.27(3) Inspection Inspections required. When Inspections are required when concrete is cut or excavation is required that could affect the integrity or operation of the UST system or when a component that routinely

contains product is installed, replaced or repaired , one inspection is required. This inspection Inspections shall occur when the component is uncovered and replaced or repaired and during testing when required (i.e., piping replacement or repair) but before operation recommences. Whenever secondary containment, such as UDC or sump, is installed, at least one inspection is required after the equipment is installed and before the sytem is backfilled.

- a. An inspection shall occur before the tanks or piping are installed.
- <u>b.</u> An inspection shall occur before the covering of tank or piping, when all tanks and piping are exposed. The inspector shall witness testing of the primary and secondary piping and testing of the secondary containment, including sumps, under-dispenser containment (UDC), and secondary containment leak detection equipment.
- c. A final inspection shall occur when all components are operational and the system has been covered, but before actual operation.
- <u>d.</u> Whenever secondary containment (such as sumps or UDC) is installed, at least one inspection is required after the equipment is installed and before the system is backfilled.

ITEM 39. Rescind paragraph 135.1(3)"a" and adopt the following <u>new</u> paragraph in lieu thereof:

- a. The requirements of this chapter apply to all owners and operators of a UST system as defined in rule 567—135.2(455B) except as otherwise provided in paragraphs 135.1(3) "b" and "c."
- (1) Previously deferred UST systems. Airport hydrant fuel distribution systems, UST systems with field-constructed tanks, and UST systems that store fuel solely for use by emergency power generators must meet the requirements of these rules as follows:
- 1. Airport hydrant fuel distribution systems and UST systems with field-constructed tanks must meet the requirements in rule 567—135.21(455B).
- 2. UST systems that store fuel solely for use by emergency power generators installed on or before November 28, 2007, must meet the requirements in rule 567—135.5(455B) by October 13, 2021.
- 3. UST systems that store fuel solely for use by emergency power generators installed after November 28, 2007, must meet all applicable requirements of this chapter at installation.
 - (2) Any UST system listed in paragraph 135.1(3)"c" must meet the requirements of subrule 135.1(4).

ITEM 40. Amend paragraph 135.1(3)"b," introductory paragraph, as follows:

b. Exclusions. The following UST systems are excluded from the requirements of this chapter:

ITEM 41. Amend paragraph 135.1(3)"c" as follows:

- *c.* Deferrals Partial exclusions. Rules 567—135.3(455B), 567—135.4(455B), 567—135.5(455B), 567—135.5(455B), 567—135.6(455B) and 567—135.9(455B) 567—135.21(455B) do not apply to any of the following types of UST systems:
 - (1) to (3) No change.
 - (4) Airport hydrant fuel distribution systems; and Aboveground storage tanks associated with:
 - 1. Airport hydrant fuel distribution systems regulated under rule 567—135.21(455B); and
 - 2. UST systems with field-constructed tanks regulated under rule 567—135.21(455B).
 - (5) UST systems with field-constructed tanks.

ITEM 42. Rescind paragraph 135.1(3)"d."

ITEM 43. Reletter paragraph 135.1(3)"e" as 135.1(3)"d."

ITEM 44. Amend subrule 135.1(4) as follows:

135.1(4) Interim prohibition for deferred UST systems Installation requirements for partially excluded UST systems.

- a. No person may Owners and operators must install a UST system listed in 135.1(3) "c" for the purpose of subparagraphs 135.1(3) "c"(1) to 135.1(3) "c"(3) storing regulated substances unless the UST system (whether of single- or double-wall construction) that meets the following requirements:
 - (1) Will prevent releases due to corrosion or structural failure for the operational life of the UST system;
- (2) Is cathodically protected against corrosion, constructed of noncorrodible material, steel clad with a noncorrodible material, or designed in a manner to prevent the release or threatened release of any stored substance; and

- (3) Is constructed or lined with material that is compatible with the stored substance.
- b. Notwithstanding paragraph "a" of this subrule, 135.1(4) "a," a UST system without corrosion protection may be installed at a site that is determined by a corrosion expert not to be corrosive enough to cause it to have a release due to corrosion during its operating life. Owners and operators must maintain records that demonstrate compliance with the requirements of this paragraph for the remaining life of the tank.

NOTE: The National Association of Corrosion Engineers Standard RP-02-85, "Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems," may be used as guidance for complying with 135.1(4) "b." The following codes of practice may be used as guidance for complying with this subrule.

- NACE International Standard RP-02-85, Practice SP 0285, "External Corrosion Control of Underground Storage Tank Systems by Cathodic Protection";
- NACE International Standard Practice SP 0169, "Control of External Corrosion on Metallic Buried, Partially Buried, Underground or Submerged Metallic Piping Systems";
- American Petroleum Institute Recommended Practice 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems"; or
- Steel Tank Institute Recommended Practice R892, "Recommended Practice for Corrosion Protection of Underground Piping Networks Associated with Liquid Storage and Dispensing Systems."

ITEM 45. Amend the following definitions in rule 567—135.2(455B):

"Asbestos-cement pipe" (AC refers to asbestos-cement) means a pipe or conduit constructed of asbestos fiber ; and Portland cement, and water, which can be used to transport water.

"CERCLA" means the Comprehensive Environmental Response, Compensation, and Liability Act of 1980 as amended.

"Certified groundwater professional" means a person certified pursuant to 1995 Iowa Code section 455G.18 455B.474 and 567—Chapter 134, Part A.

"Chemicals of concern" means the compounds derived from petroleum-regulated substances which are subject to evaluation for purposes of applying risk-based corrective action decision making. These compounds are benzene, ethylbenzene, toluene, and xylenes (BTEX) and naphthalene, benzo(a)pyrene, benz(a)anthracene, and chrysene. (N OTE: Measurement of Concentration values for these last four constituents may be done are determined by a conversion method from total extractable hydrocarbons, see subrule 135.8(3).)

"Drinking water well" means any groundwater well used as a source for drinking water by humans and groundwater wells used primarily for the final production of food or medicine for human consumption in facilities routinely characterized with the Standard Industrial Codes (SIC) group 283 for drugs and 20 for foods. "Free product" refers to a regulated substance that is present as a <u>light</u> nonaqueous phase liquid (e.g., liquid not dissolved in water).

"Motor fuel" means petroleum or a petroleum-based substance that is a complex blend of hydrocarbons typically used in the operation of a motor engine, such as motor gasoline, aviation gasoline, No. 1 or No. 2 diesel fuel, or any grade of gasohol, and is typically used in the operation of a motor engine blend containing one or more of these substances (for example, motor gasoline blended with alcohol). "Owner" means:

- 1. In the case of a UST system in use on July 1, 1985, or brought into use after that date, any person who owns a UST system used for storage, use, or dispensing of regulated substances; and
- 2. In the case of any UST system in use before July 1, 1985, but no longer in use on that date, any person who owned such UST immediately before the discontinuation of its use.

"Owner" Owner does not include a person or institution, who, without participating in the management or operation of the underground storage tank or the tank site or engaging in petroleum production, refining or marketing, holds indicia of ownership primarily to protect that person's security interest in the underground storage tank or the tank site property, prior to obtaining ownership or control through debt enforcement, debt settlement, or otherwise.

"Pipe" or "piping" means a hollow cylinder or tubular conduit that is constructed of nonearthen materials and that routinely contains and conveys regulated substances from the underground tank(s) to the dispenser(s) or other end use equipment. Such piping includes any elbows, couplings, unions, valves, or other in line fixtures

that contain and convey regulated substances from the underground tank(s) to the dispenser(s). This definition does not include vent, vapor recovery, or fill lines.

"Regulated substance" means an element, compound, mixture, solution or substance which, when released into the environment, may present substantial danger to the public health or welfare or the environment. Regulated substance includes:

- 1. and 2. No change.
- 3. Any substance defined in Section 101(14) of the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) of 1980 (but not including any substance regulated as a hazardous waste under subtitle C), and
- 4. Petroleum, including crude oil or any fraction thereof that is liquid at standard conditions of temperature and pressure (60 degrees Fahrenheit and 14.7 pounds per square inch absolute). The term "regulated substance" includes but is not limited to petroleum and petroleum-based substances comprised of a complex blend of hydrocarbons derived from crude oil through processes of separation, conversion, upgrading, and finishing, such as motor fuels, jet fuels, distillate fuel oils, residual fuel oils, lubricants, petroleum solvents, and used oils.
- "Release detection" means determining whether a release of a regulated substance has occurred from the UST system into the environment or a leak has occurred into the interstitial space between the UST system and its secondary barrier or secondary containment around it.
- "Replace" or "replacement" means the installation of a new underground tank system or component, including dispensers, in substantially the same location as an existing tank system or component in lieu of that tank system or component.

"Site assessment investigation" means an investigation conducted by a registered certified groundwater professional to determine relevant site historical data, the types, amounts, and sources of petroleum contaminants present, hydrogeological characteristics of the site, full vertical and horizontal extent of the contamination in soils and groundwater, direction and rate of flow of the contamination, ranges of concentration of the contaminants by analysis of soils and groundwater, the vertical and horizontal extent of the contamination exceeding department standards, and the actual or potential threat to public health and safety and the environment.

"Tier 2 site assessment" means the process of assessing risk to actual and potential receptors by using site-specific field data contaminant concentrations and designated Tier 2 exposure and fate and transport models to determine the applicable target level(s).

"Under-dispenser containment (UDC)" means containment underneath a dispenser that will system designed to prevent leaks from the dispenser and piping within or above the UDC from reaching soil or groundwater. Such containment must:

- Be intact and liquid-tight on its sides and bottom and at any penetrations;
- Be compatible with the substance conveyed by the piping; and
- Allow for visual inspection and monitoring and access to the components in the containment system.

"Underground storage tank" or "UST" means any one or combination of tanks (including underground pipes connected thereto) that is used to contain an accumulation of regulated substances, and the volume of which (including the volume of underground pipes connected thereto) is 10 percent or more beneath the surface of the ground. This term does not include any:

- a. Farm or residential tank of 1100 gallons or less capacity used for storing motor fuel for noncommercial purposes. Iowa Code section 455B.471 455B.473(4) requires those tanks existing prior to July 1, 1987, to be registered. Tanks installed on or after July 1, 1987, must comply with all 567—Chapter 135 rules;
- b. Tank used for storing heating oil for consumptive use on the premises where stored;
- c. Septic tank:
- d. Pipeline facility (including gathering lines) regulated under:
- (1) The Natural Gas Pipeline Safety Act of 1968 (49 U.S.C. App. 1671, et seq.) Which is regulated under 49 U.S. Code Chapter 601, or
- (2) The Hazardous Liquid Pipeline Safety Act of 1979 (49 U.S.C. App. 2001, et seq.), or Which is an intrastate pipeline facility regulated under state laws as provided in 49 U.S.C. Chapter 601 and which is determined by the Secretary of Transportation to be connected to a pipeline, or to be operated or intended to be

capable of operating at pipeline pressure or as an integral part of a pipeline;

- (3) Which is an intrastate pipeline facility regulated under state laws comparable to the provisions of the law referred to in "d"(1) or "d"(2) of this definition;
- e. Surface impoundment, pit, pond, or lagoon;
- f. Storm-water or wastewater collection system;
- g. Flow-through process tank;
- h. Liquid trap or associated gathering lines directly related to oil or gas production and gathering operations; or
- *i*. Storage tank situated in an underground area (such as a basement, cellar, mineworking, drift, shaft, or tunnel) if the storage tank is situated upon or above the surface of the floor.

The term "underground storage tank" or "UST" does not include any pipes connected to any tank which is described in paragraphs "a" through "i" of this definition.

ITEM 46. Rescind the definitions of "Class A operator," "Class B operator," "Class C operator," "Dispenser," "Repair" and "Secondary containment tank" in rule **567—135.2(455B)**.

ITEM 47. Adopt the following **new** definitions in rule **567—135.2(455B)**:

"Airport hydrant fuel distribution system" or "airport hydrant system" means a UST system which fuels aircraft and operates under high pressure with large diameter piping that typically terminates into one or more hydrants (fill stands). The airport hydrant system begins where fuel enters one or more tanks from an external source such as a pipeline, barge, rail car, or other motor fuel carrier.

"Biodiesel" means a renewable fuel comprised of mono-alkyl esters of long-chain fatty acids derived from vegetable oils or animal fats, that is blended with petroleum-based diesel fuel, which meets the standards provided in Iowa Code section 214A.2.

"Class A operator" means the individual who has primary responsibility to operate and maintain the UST system in accordance with applicable requirements. The Class A operator typically manages resources and personnel, such as establishing work assignments, to achieve and maintain compliance with regulatory requirements under this chapter.

"Class B operator" means the individual who has day-to-day responsibility for implementing applicable regulatory requirements established by the department. The Class B operator typically implements in-field aspects of operation, maintenance, and associated record keeping for the UST systems.

"Class C operator" means the individual responsible for initially addressing emergencies presented by a spill or release from a UST system. The Class C operator typically controls or monitors the dispensing or sale of regulated substances.

"Containment sump" means a liquid-tight container that protects the environment by containing leaks and spills of regulated substances from piping, dispensers, pumps and related components in the containment area. Containment sumps may be single-walled or secondarily contained and located at the top of the tank (tank top or submersible turbine pump sump), underneath the dispenser (under-dispenser containment sump), or at other points in the piping run (transition or intermediate sump).

"Dispenser" means equipment located above ground that dispenses regulated substances from the UST system. "Dispenser system" means the dispenser and the equipment necessary to connect the dispenser to the underground storage tank system.

"Ethanol" means ethyl alcohol that is to be blended with gasoline if it meets the standards provided in Iowa Code section 214A.2.

"Field-constructed tank" means a tank constructed in the field. For example, a tank constructed of concrete that is poured in the field or a steel or fiberglass tank primarily fabricated in the field is considered field-constructed. "Light, nonaqueous-phase liquid" or "LNAPL" refers to an organic compound that is immiscible with, and lighter than water (e.g., crude oil, gasoline, diesel fuel, heating oil).

"Over-excavation" refers to the excavation of subsurface materials outside the excavation zone for the purpose of removing contaminated substances.

"Repair" means to restore to proper operating condition a tank, pipe, spill prevention equipment, overfill prevention equipment, corrosion protection equipment, release detection equipment or other UST system component that has caused a release of product from the UST system or has failed to function properly.

"Replaced" means:

- 1. For a tank: to remove a tank and install another tank.
- 2. For piping: to remove 50 percent or more of piping and install other piping, excluding connectors, connected to a single tank. For tanks with multiple piping runs, this definition applies independently to each piping run.

"Secondary containment" or "secondarily contained" means a release prevention and release detection system for a tank or piping. This system has an inner and outer barrier with an interstitial space monitored for leaks. This term includes containment sumps when used for interstitial monitoring of piping.

"Temporary closure" means a regulated tank or UST system that has been out of operation for three months or more.

"Training program" means any program that provides information to and evaluates the knowledge of a Class A, Class B, or Class C operator through testing, practical demonstration, or another approach acceptable to the department regarding requirements for UST systems that meet the requirements of subrules 135.4(6) to 135.4(12).

"Underground storage tank professional" or "UST professional" means an individual licensed by the department under 567—Chapter 134, Part C. The licensing program includes underground storage tank system installation, installation inspection, UST system testing, tank lining, cathodic protection installation/inspection, and UST removal. The license issued will list the type of work the individual is licensed to perform.

ITEM 48. Amend subrule 135.3(1) as follows:

- 135.3(1) Performance standards for new UST systems. In order to prevent releases due to structural failure, corrosion, or spills and overfills for as long as the UST system is used to store regulated substances, all owners and operators of new UST systems must meet the following requirements. The UST system must be secondarily contained in accordance with subrule 135.3(9).
- a. Tanks. Each tank must be properly designed and constructed, and any portion underground that routinely contains product must be protected from corrosion, in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory as specified below:
- (1) The tank is constructed of fiberglass-reinforced plastic; or

 NOTE: The following industry codes of practice may be used to comply with subparagraph 135.3(1) "a"(1):

 Underwriters Laboratories Standard 1316, "Standard for Glass-Fiber-Reinforced Plastic Underground Storage
 Tanks for Petroleum Products, Alcohols, and Alcohol-Gasoline Mixtures"; or Underwriters Laboratories of
 Canada CAN4-S615-M83 S615, "Standard for Reinforced Plastic Underground Tanks for Petroleum Products";
 or American Society of Testing and Materials Standard D4021-86, "Standard Specification for Glass-Fiber-Reinforced Polyester Underground Petroleum Storage Tanks." Flammable and Combustible Liquids."
 - (2) The tank is constructed of steel and cathodically protected in the following manner:
 - 1. The tank is coated with a suitable dielectric material;
 - 2. Field-installed cathodic protection systems are designed by a corrosion expert;
- 3. Impressed current systems are designed to allow determination of current operating status as required in paragraph 135.4(2) "c." This shall be accomplished by providing the rectifier with ampere and voltage meters that can be read by the owner and operator for comparison to the design standard set by the corrosion expert or a device that can warn the owner and operator when changes in ampere and voltage occur outside the design standard set by the corrosion expert; and
- 4. Cathodic protection systems are operated and maintained in accordance with 135.4(2) or according to guidelines established by the department; or and
- 5. <u>Impressed current systems must be designed not to cause stray current that can damage other underground structures (metal electrical conduits, water lines, gas lines, etc.); or </u>

NOTE: The following codes and standards may be used to comply with 135.3(1) "a"(2): Steel Tank Institute "Specification for STI-P3 System of External Corrosion Protection of Underground Steel Storage Tanks"; Underwriters Laboratories Standard 1746, "Corrosion Protection Systems for Underground Storage Tanks"; Underwriters Laboratories of Canada CAN4-S603-M85, "Standard for Steel Underground Tanks for Flammable and Combustible Liquids," and CAN4-GO3.1-M85, "Standard for Galvanic Corrosion Protection Systems for Underground Tanks for Flammable and Combustible Liquids," and CAN4-S631-M84, "Isolating Bushings for Steel Underground Tanks Protected with Coatings and Galvanic Systems"; or National Association of Corrosion

Engineers Standard RP-02-85, "Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems," and Underwriters Laboratories Standard 58, "Standard for Steel Underground Tanks for Flammable and Combustible Liquids." The following codes of practice may be used to comply with subparagraph 135.3(1) "a"(2):

- Steel Tank Institute "Specification STI-P3® Specification and Manual for External Corrosion Protection of Underground Steel Storage Tanks";
- Underwriters Laboratories Standard 1746, "External Corrosion Protection Systems for Steel Underground Storage Tanks";
- Underwriters Laboratories of Canada S603, "Standard for Steel Underground Tanks for Flammable and Combustible Liquids," and S603.1, "Standard for External Corrosion Protection Systems for Steel Underground Tanks for Flammable and Combustible Liquids," and S631, "Standard for Isolating Bushings for Steel Underground Tanks Protected with External Corrosion Protection Systems";
 - Steel Tank Institute Standard F841, "Standard for Dual Wall Underground Steel Storage Tanks"; or
- NACE International Standard Practice SP 0285, "External Corrosion Control of Underground Storage Systems by Cathodic Protection," and Underwriters Laboratories Standard 58, "Standard for Steel Underground Tanks for Flammable and Combustible Liquids."
- (3) The tank is constructed of a steel-fiberglass-reinforced plastic composite steel and clad or jacketed with a noncorrodible material; or

NOTE: The following industry codes may be used to comply with <u>subparagraph</u> 135.3(1) "a"(3): Underwriters Laboratories Standard 1746, "Corrosion Protection Systems for Underground Storage Tanks," or the Association for Composite Tanks ACT-100, "Specification for the Fabrication of FRP Clad Underground Storage Tanks."

- Underwriters Laboratories Standard 1746, "Corrosion Protection Systems for Underground Storage Tanks";
- Steel Tank Institute ACT-100® Specification F894, "Specification for External Corrosion Protection of FRP Underground Storage Tanks";
- Steel Tank Institute ACT-100-U® Specification F961, "Specification for External Corrosion Protection of Composite Steel Underground Storage Tanks"; or
 - Steel Tank Institute Specification F922, "Steel Tank Institute Specification for Permatank®."
 - (4) The tank is constructed of metal without additional corrosion protection measures provided that:
- 1. The tank is installed at a site that is determined by a corrosion expert not to be corrosive enough to cause it to have a release due to corrosion during its operating life; and
- 2. Owners and operators maintain records that demonstrate compliance with the requirements of 135.3(1)"a"(4)"1" for the remaining life of the tank; or
- (5) The tank construction and corrosion protection are determined by the department to be designed to prevent the release or threatened release of any stored regulated substance in a manner that is no less protective of human health and the environment than <u>subparagraphs</u> 135.3(1) "a"(1) to (4).
- b. Piping. The piping that routinely contains regulated substances and is in contact with the ground must be properly designed, constructed, and protected from corrosion in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory as specified below: in this rule. This includes piping for remote tank fill locations.
- All piping must have secondary containment, installed according to manufacturer's specifications, and be compatible with the product stored and the environment to which it will be exposed. Piping must maintain its original specifications and structural integrity. Piping whose structural integrity has degraded must be replaced. All piping installations must meet National Fire Prevention Association 2000 Edition of NFPA 30 and 30A codes or the International Fire Code as adopted by the Iowa state fire marshal in 661—Chapter 221, "Flammable and Combustible Liquids."
- (1) The piping is constructed of fiberglass reinforced plastic a noncorrodible material; or NOTE: The following codes and standards of practice may be used to comply with subparagraph 135.3(1) "b"(1): Underwriters Laboratories Subject 971, "UL Listed Non-Metal Pipe"; Underwriters Laboratories Standard 567, "Pipe Connectors for Flammable and Combustible and LP Gas"; Underwriters Laboratories of Canada Guide ULC-107, "Glass Fiber Reinforced Plastic Pipe and Fittings for Flammable Liquids"; and Underwriters

Laboratories of Canada Standard CAN 4-S633-M81, "Flexible Underground Hose Connectors."

- Underwriters Laboratories Standard 971, "Nonmetallic Underground Piping for Flammable Liquids";
 or
- Underwriters Laboratories of Canada Standard S6660, "Standard for Nonmetallic Underground Piping for Flammable and Combustible Liquids."
 - (2) The piping is constructed of steel and cathodically protected in the following manner:
 - 1. The piping is coated with a suitable dielectric material;
 - 2. Field-installed cathodic protection systems are designed by a corrosion expert;
- 3. Impressed current systems are designed to allow determination of current operating status as required in paragraph 135.4(2) "c"; and
- 4. Cathodic protection systems are operated and maintained in accordance with <u>subrule</u>135.4(2) or guidelines established by the department; or

NOTE: The following codes and standards of practice may be used to comply with subparagraph 135.3(1) "b" (2): National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code"; American Petroleum Institute Publication 1615, "Installation of Underground Petroleum Storage Systems"; American Petroleum Institute Publication 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems"; and National Association of Corrosion Engineers Standard RP 01-69, "Control of External Corrosion on Submerged Metallic Piping Systems."

- American Petroleum Institute Recommended Practice 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems";
- Underwriters Laboratories Subject 971A, "Outline of Investigation for Metallic Underground Fuel Pipe";
- Steel Tank Institute Recommended Practice R892, "Recommended Practice for Corrosion Protection of Underground Piping Networks Associated with Liquid Storage and Dispensing Systems";
- NACE International Standard Practice SP 0169, "Control of External Corrosion on Underground or Submerged Metallic Piping Systems";
- NACE International Standard Practice SP 0285, "External Corrosion Control of Underground Storage Tank Systems by Cathodic Protection": or
 - National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code."
 - (3) The piping is constructed of metal without additional corrosion protection measures provided that:
- 1. The piping is installed at a site that is determined by a corrosion expert to not be corrosive enough to cause it to have a release due to corrosion during its operating life; and
- 2. Owners and operators maintain records that demonstrate compliance with the requirements of subparagraph 135.3(1)"b"(3)"1" for the remaining life of the piping; or
- Note: National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code"; and National Association of Corrosion Engineers Standard RP-01-69, "Control of External Corrosion on Submerged Metallic Piping Systems," may be used to comply with 135.3(1) "b"(3).
- (4) The piping construction and corrosion protection are determined by the department to be designed to prevent the release or threatened release of any stored regulated substance in a manner that is no less protective of human health and the environment than the requirements in <u>subparagraphs</u> 135.3(1) "b" (1) to (3).
 - c. Spill and overfill prevention equipment.
- (1) Except as provided in subparagraph (2) 135.3(1) "b"(2), to prevent spilling and overfilling associated with product transfer to the UST system, owners and operators must use the following spill and overfill prevention equipment:
- 1. Spill prevention equipment that will prevent release of product to the environment when the transfer hose is detached from the fill pipe (for example, a spill catchment basin); and
 - 2. Overfill prevention equipment that will:
- Automatically shut off flow into the tank when the tank is no more than 95 percent full; or
- Alert the transfer operator when the tank is no more than 90 percent full by restricting the flow into the tank (not allowed for suction product delivery systems, for tanks with stage 1 vapor recovery or when product delivery

is by pumping) or triggering a high-level alarm; or

- Restrict flow 30 minutes prior to overfilling, alert the <u>transfer</u> operator with a high-level alarm one minute before overfilling, or automatically shut off the flow into the tank so that none of the fittings located on top of the tank are exposed to product due to overfilling.
- (2) Owners and operators are not required to use the spill and overfill prevention equipment specified in subparagraph (1) 135.3(1)"b"(1) if:
- 1. Alternative equipment is used that is determined by the department to be no less protective of human health and the environment than the equipment specified in subparagraph (1)"1" paragraph 135.3(1)"b"(1)"1" or "2" of this paragraph; or
 - 2. The UST system is filled by transfers of no more than 25 gallons at one time.
- (3) Flow restrictors used in vent lines may not be used to comply with paragraph 135.3(1) "c" (1)"2" when overfill prevention is installed or replaced.
- (4) Spill and overfill prevention equipment must be periodically tested or inspected in accordance with subrule 135.4(12).
- (5) Spill prevention equipment must be kept free of any liquid and debris. Any liquid or debris must be removed prior to product delivery.
- d. Installation. All tanks and piping The UST system must be properly installed in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory and in accordance with the manufacturer's instructions. The UST system installation shall be conducted by an installer licensed by the department under 567—Chapter 134, Part C, and in accordance with 567—subrules 134.24(3) and 134.24(4). NOTE: Tank and piping system installation practices and procedures described in the following codes may be used to comply with the requirements of paragraph 135.3(1) "d": American Petroleum Institute Publication 1615, "Installation of Underground Petroleum Storage System"; Petroleum Equipment Institute Publication RP100, "Recommended Practices for Installation of Underground Liquid Storage Systems"; or American National Standards Institute Standard 831.4, "Liquid Petroleum Transportation Piping System."
- American Petroleum Institute Publication 1615, "Installation of Underground Petroleum Storage System";
- Petroleum Equipment Institute Publication RP100, "Recommended Practices for Installation of Underground Liquid Storage Systems"; or
- National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code" and 30A "Code for Motor Fuel Dispensing Facilities and Repair Garages."
- e. Certification of installation. All owners and operators must ensure that one or more of the following methods of certification, testing, or and inspection is are used to demonstrate compliance with paragraph 135.3(1) "d" of this subrule by providing a certification of compliance on the UST notification registration form in accordance with subrule 135.3(3).
 - (1) The installer has been certified by the tank and piping manufacturers; or
- (2) (1) The installer has been certified or is licensed by the department as provided in 567—Chapter 134, Part C; or and
- (3) (2) The installation has been inspected and certified by a registered professional engineer with education and experience in UST system installation; or licensed installation inspector as required by 567—Chapter 134, Part C.
- (4) The installation has been inspected and approved by an inspector certified or licensed by the Iowa comprehensive petroleum underground storage tank fund board; or
 - (5) All work listed in the manufacturer's installation checklists has been completed; or
- (6) The owner and operator have complied with another method for ensuring compliance with paragraph "d" that is determined by the department to be no less protective of human health and the environment.
- f. Dispenser systems. Each UST system must be equipped with under-dispenser containment (UDC) for any new or replaced dispenser system.
- (1) A dispenser system is considered new when both the dispenser and the equipment needed to connect the dispenser to the underground storage tank system are installed at a location where there previously was no

dispenser (new UST system or new dispenser location at an existing UST system). The equipment necessary to connect the dispenser to the underground storage tank system includes check valves, shear valves, unburied risers or flexible connectors, or other transitional components that are underneath the dispenser and connect the dispenser to the underground piping.

- (2) UDC shall be installed whenever an existing dispenser system is removed and replaced with another dispenser and the equipment used to connect the dispenser to the underground storage tank system is replaced. This equipment includes flexible connectors or risers or other transitional components that are beneath the dispenser and connect the dispenser to the piping. UDC is not required when only the emergency shutoff or shear valves or check valves are replaced.
- (3) UDC shall be installed beneath the dispenser whenever ten feet or more of piping is repaired or replaced within ten feet of a dispenser.
- (4) UDC must be liquid-tight on its sides, bottom, and at any penetrations. UDC must allow for visual inspection and access to the components in the containment system or be periodically monitored for leaks from the dispenser system.
 - ITEM 49. Amend subrule 135.3(2) as follows:
- 135.3(2) Upgrading of existing UST systems. Owners and operators must permanently close any UST system that does not meet the new UST system performance standards or has not been upgraded in accordance with paragraphs 135.3(2) "b" through "d." This subrule does not apply to previously deferred UST systems. Upgrading is no longer allowed for UST systems not upgraded by December 22, 1998.
- a. Alternatives allowed. Not later than December 22, 1998, all existing UST systems must had to comply with one of the following requirements:
 - (1) New UST system performance standards under 135.3(1);
 - (2) The upgrading requirements in paragraphs "b" through "d" below; or
- (3) Closure requirements under rule 567—135.15(455B), including applicable requirements for corrective action under rules 567—135.7(455B) to 567—135.12(455B).

Replacement or upgrade of a tank system on a petroleum contaminated site classified as a high or low risk in accordance with <u>subrulerule 567—135.12(455B)</u> shall be a double wall tank or a tank equipped with a secondary containment system with monitoring of the space between the primary and secondary containment structures in accordance with <u>paragraph</u> 135.5(4) "g." or other approved tank system or methodology approved by the <u>Iowa comprehensive petroleum underground storage tank fund board.</u>

- b. Tank upgrading requirements. Steel tanks must had to be upgraded to meet one of the following requirements in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory:
 - (1) Interior lining. A tank may be Tanks upgraded by internal lining if must meet the following:
 - 1. The lining is was installed in accordance with the requirements of subrule 135.4(4), and
- 2. Within ten years after lining, and every five years thereafter, the lined tank is internally inspected and found to be structurally sound with the lining still performing in accordance with original design specifications.
- 3. If the internal lining is no longer performing in accordance with original design specifications and cannot be repaired in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory, the lined tank must be permanently closed in accordance with rule 567—135.15(455B).
- (2) Cathodic protection. A tank may be <u>Tanks</u> upgraded by cathodic protection if the cathodic protection system meets meet the requirements of <u>paragraphs</u> 135.3(1) "a"(2)"2," "3," and "4" and the integrity of the tank is <u>was</u> ensured using one of the following methods:
- 1. The tank is was internally inspected and assessed to ensure that the tank is was structurally sound and free of corrosion holes prior to installing the cathodic protection system; or
- 2. The tank has had been installed for less than ten years and is monitored monthly for releases in accordance with 135.5(4) "d" through "h" "i"; or
- 3. The tank <u>has had</u> been installed for less than ten years and <u>is was</u> assessed for corrosion holes by conducting two tightness tests that meet the requirements of <u>paragraph</u> 135.5(4) "c." The first tightness test must <u>be have been</u> conducted prior to installing the cathodic protection system. The second tightness test must <u>be have</u>

been conducted between three and six months following the first operation of the cathodic protection system; or

- 4. The tank is was assessed for corrosion holes by a method that is determined by the department to prevent releases in a manner that is no less protective of human health and the environment than paragraphs 135.3(2)"b"(2)"1" to "3."
- (3) Internal lining combined with cathodic protection. A tank may be <u>Tanks</u> upgraded by both internal lining and cathodic protection if <u>must have met the following</u>:
 - 1. The lining is was installed in accordance with the requirements of subrule 135.4(4); and
- 2. The cathodic protection system was installed within six months of lining installation and meets the requirements of paragraphs 135.3(1) "a"(2)"2," "3," and "4."

NOTE: The following codes and standards may be used to comply with subrule 135.3(2): American Petroleum Institute Publication 1631, "Recommended Practice for the Interior Lining of Existing Steel Underground Storage Tanks"; National Leak Prevention Association Standard 631, "Spill Prevention, Minimum 10 Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection"; National Association of Corrosion Engineers Standard RP 02-85, "Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems"; and American Petroleum Institute Publication 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems." Regarding paragraph 135.3(2) "b": The following historical codes of practice were listed as options for complying with paragraph 135.3(2) "b":

- American Petroleum Institute Publication 1631, "Recommended Practice for the Interior Lining of Existing Steel Underground Storage Tanks";
- National Leak Prevention Association Standard 631, "Spill Prevention, Minimum 10 Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection";
- National Association of Corrosion Engineers Standard RP-02-85, "Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems"; and
- American Petroleum Institute Publication 1632, "Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems."

NOTE regarding paragraph 135.3(2) "b" (1) "2": The following codes of practice may be used to comply with the periodic lining inspection requirement of this subrule:

- American Petroleum Institute Recommended Practice 1631, "Interior Lining and Periodic Inspection of Underground Storage Tanks";
- National Leak Prevention Association Standard 631, Chapter B, "Future Internal Inspection Requirements for Lined Tanks";
- Ken Wilcox Associates Recommended Practice, "Recommended Practice for Inspecting Buried Lined Steel Tanks Using a Video Camera"; or
 - Underwriters Laboratories (UL) 1856 Underground Fuel Tank Internal Retrofit Systems.
- c. Piping upgrading requirements. Metal piping that routinely contains regulated substances and is in contact with the ground must be cathodically protected in accordance with a code of practice developed by a nationally recognized association or independent testing laboratory and must meet the requirements of paragraphs 135.3(1)"b"(2)"2," "3," and "4."

NOTE: The codes and standards of practice listed in the note following subparagraph 135.3(1) "b" (2) may be used to comply with this requirement.

d. Spill and overfill prevention equipment. To prevent spilling and overfilling associated with product transfer to the UST system, all existing UST systems must comply with new UST system spill and overfill prevention equipment requirements specified in paragraph 135.3(1)"c."

ITEM 50. Amend subrule 135.3(3) as follows:

135.3(3) Notification Registration and notification requirements.

- a. Except as provided in <u>paragraph</u> 135.3(3)"b," the owner of an underground storage tank existing on or before July 1, 1985, shall complete and submit to the department a copy of the <u>notification</u> registration form provided by the department by May 1, 1986.
- b. The owner of an underground storage tank <u>system</u> taken out of operation between January 1, 1974, and July 1, 1985, shall complete and submit to the department a copy of the <u>notification registration</u> form provided

by the department by May 8, 1986, unless the owner knows the tank has been removed from the ground. For purposes of this subrule, "owner" means the person who owned the tank immediately before the discontinuation of the tank's use.

- c. An owner or operator who brings into use an underground storage tank <u>system</u> after July 1, 1985, shall complete and submit to the department a copy of the <u>notification registration</u> form provided by the department within 30 days of <u>installing the tank in the ground the final installation inspection required in 567—paragraph 134.27(2) "c" by a licensed installation inspector. The owner or operator shall not allow the deposit of any regulated substance into the tank without prior approval of the department or until the <u>tank has been issued a tank permanent</u> registration tag <u>and annual tank tag have been attached to the tank fill pipe</u> and <u>the tank system</u> is covered by an approved financial responsibility mechanism in accordance with 567—Chapter 136.</u>
- d. All owners and operators of new UST systems must <u>provide UST system details and a site diagram</u>, and certify in the <u>notification registration</u> form compliance with the following requirements:
 - (1) Installation of tanks and piping under paragraph 135.3(1)"e";
 - (2) Cathodic protection of steel tanks and piping under paragraphs 135.3(1) "a" and "b";
 - (3) Financial responsibility under 567—Chapter 136, Iowa Administrative Code;
 - (4) Release detection methods under subrules 135.5(2) and 135.5(3).;
 - (5) Class A, B and C operator certification under subrule 135.4(6);
 - (6) NESHAP Stage 1 vapor recovery.
- e. All owners and operators of new UST systems must ensure that the <u>licensed</u> installer certifies in the <u>notification registration</u> form that the methods used to install the tanks and piping comply with the requirements in <u>paragraph</u> 135.3(1) "d."
- f. Exemption from reporting requirement. Paragraphs 135.3(1) "a" to "c" do not apply to an underground storage tank for which notice was given pursuant to Section 103, Subsection c, of the Comprehensive Environmental Response, Compensation and Liabilities Act of 1980. (42 U.S.C. Subsection 9603(c))
- g. Reporting fee. The notice registration form submitted by the owner to the department under paragraphs 135.3(1) "a" to "c" shall be accompanied by a fee of \$10 for each tank included in the notice form.
- h. Notification requirement for installing a tank. A person installing an underground storage tank and the owner or operator of the underground storage tank must notify the department of their intent to install the tank 30 days prior to installation. Notification shall be on a form provided by the department.
- *i.* Notification requirements for a person who <u>acquires</u>, sells, installs, modifies or repairs a <u>tank UST system</u>.
- (1) A person, company or lending institution that assumes ownership or operation of a regulated underground storage tank must submit notification to the department on a form provided by the department within 30 days of acquisition and prior to tank operation. The owner must include copies of training certificates for the Class A and Class B operators (135.4(6)) and proof of financial responsibility required in 567—Chapter 136. The new owner is responsible for any current and back tank management fees that have not been previously paid.
- (2) A person who sells, installs, modifies, or repairs a tank used or intended to be used in Iowa shall notify, in writing, the purchaser and the owner or operator of the tank of the obligations specified in paragraphs 135.3(3) "c" and "j" and the financial assurance requirements in 567—Chapter 136. The notification must include the prohibition on depositing a regulated substance into tanks which have not been registered and issued tags by the department, or tanks which do not have financial assurance as required in 567—Chapter 136. A standard notification form supplied by the department may be used to satisfy this requirement.
- *j*. It is unlawful for a person to deposit or accept a regulated substance in an underground storage tank that has not been registered and issued permanent or annual tank management tags in accordance with rule 567—135.3(455B). It is unlawful for a person to deposit or accept a regulated substance into an underground storage tank if the person has received notice from the department that the underground storage tank is subject to a delivery prohibition or if there is a "red tag" attached to the UST fill pipe or fill pipe cap as provided in subrule 135.3(8).
- (1) The department may provide written authorization to receive a regulated substance when there is a delay in receiving tank tags or at new tank installations to allow for testing the tank system.

- (2) The department may provide known depositors of regulated substances lists of underground storage tank sites that have been issued tank tags, those that have not been issued tank tags, and those subject to a delivery prohibition pursuant to subrule 135.3(8). These lists do not remove the requirement for depositors to verify that current tank tags are affixed to the fill pipe prior to delivering product. Regulated substances cannot be delivered to underground storage tanks without current tank tags or those displaying a delivery prohibition "red tag" as provided in subrule 135.3(8).
- (3) A person shall not <u>accept or</u> deposit a regulated substance in an underground storage tank after receiving written or oral notice from the department that the tank is not covered by an approved form of financial responsibility in accordance with 567—Chapter 136.
- k. If an owner or operator fails to register an underground storage tank within 30 days after installation of obtain annual renewal tags by April 1, pursuant to paragraph 135.3(3) "c," the owner or operator shall pay an additional \$250 per tank late fee upon registration of the tank or application for tank tag renewal. The imposition of this fee does not preclude the department from assessing an additional administrative penalty in accordance with Iowa Code section 455B.476.

ITEM 51. Amend subrule 135.3(4) as follows:

135.3(4) Farm and residential tanks.

- a. The owner or operator of a farm or residential tank of 1100 gallons or less capacity used for storing motor fuel for noncommercial purposes is subject to the requirements of this subrule.
- b. Farm and residential tanks, installed before July 1, 1987, shall be reported on a notification form by July 1, 1989, but owners or operators are not required to pay a registration fee are required to be registered with the department.
- c. Farm and residential tanks that were installed on or after July 1, 1987, shall must be in compliance with all the underground storage tank regulations.

ITEM 52. Rescind paragraph 135.3(5)"b" and adopt the following new paragraph in lieu thereof:

- b. The owner or operator of tanks over 1,100-gallon capacity must submit a tank management fee form and fee payment of \$65 per tank by January 15 of each year.
 - (1) An additional \$250 per tank late fee must be paid if the tank management fee is not paid by March 1.
- (2) The owner or operator must submit written proof that the tanks are covered by an approved form of financial responsibility in accordance with 567—Chapter 136.
- (3) Upon proper payment of the fee and acceptable proof of financial responsibility, and a determination there are no outstanding compliance violations, a one-year renewal tag will be issued for the period from April 1 to March 31.
- (4) If there are outstanding compliance violations, the annual tank tags may be withheld until the violations are corrected.
- (5) The department shall refund a tank management fee if the tank is permanently closed prior to April 1 for that year.

ITEM 53. Amend paragraph 135.3(5)"d" as follows:

d. A person who conveys or deposits a regulated substance shall inspect the underground storage tank to determine the existence or absence of a <u>current permanent</u> registration tag, a current annual <u>tank management</u> fee <u>renewal</u> tag, or a delivery prohibition "red tag" as provided in subrule 135.3(8). If <u>the tag a current annual renewal tag</u>, or a <u>silver permanent tag for regulated tanks less than 1,100 gallons</u> is not affixed to the fill pipe or fill pipe cap or if a delivery prohibition "red tag" is displayed, the person shall not deposit the substance in the tank.

ITEM 54. Amend subrule 135.3(6) as follows:

- 135.3(6) <u>Petroleum Previously unregistered petroleum</u> underground storage tank registration amnesty program <u>tanks</u>.
- a. A petroleum underground storage tank required to be registered under <u>subrules</u> 135.3(3) and 135.3(4), which has not been registered <u>prior to July 1, 1988, may shall</u> be registered under the following conditions:
 - (1) \underline{a} . The tank registration fee under <u>paragraph</u> 135.3(3) "g" shall accompany the registration.
 - (2) b. The storage tank management fee and any late fees under subrule 135.3(5) and paragraph

135.3(3) "k" shall be paid for past years in which the tank should have been registered.

- b. If a tank is registered under this subrule on or prior to October 1, 1989, penalties under Iowa Code section 455B.477 shall be waived.
 - c. The department may waive the late fee(s).
 - ITEM 55. Rescind and reserve subrule 135.3(7).

ITEM 56. Amend subparagraph 135.3(8)"a"(1) as follows:

- (1) Annual registration renewal tag and tank management fee process. Owners and operators shall certify to the following on a form prepared by the department when applying for annual tank tags pursuant to subrule 135.3(5):
 - 1. to 5. No change.

ITEM 57. Adopt the following <u>new</u> subparagraphs 135.3(8)"b"(11) to (14):

- (11) The owner or operator has failed to provide documentation of Class A or B operator training. REINSTATEMENT CRITERION: The owner or operator must submit a copy of the certificates of training for Class A and B operators.
- (12) The owner or operator has failed to install required secondary containment.

 REINSTATEMENT CRITERION: The owner or operator must document secondary containment has been installed
- REINSTATEMENT CRITERION: The owner or operator must document secondary containment has been installed as provided in subrule 135.3(9).
- (13) The owner or operator has failed to pay the annual tank management fee.

 REINSTATEMENT CRITERION: The owner or operator must pay the current and any previous unpaid tank management fees in addition to any late fees as provided in paragraph 135.3(5) "b."
- (14) When tanks are no longer in use or in temporary closure.

 REINSTATEMENT CRITERION: The owner or operator must provide a completed Return to Service form along with required documents.

ITEM 58. Amend subparagraph 135.3(8)"e"(1) as follows:

(1) Prior to imposing a delivery prohibition response action under paragraph 135.3(8)"b" above, the department will provide notice to the owner or operator or, if notice to the owner or operator cannot be confirmed, to a person in charge at the UST facility of the basis for the finding and the intent to initiate a delivery prohibition response action. Notice may be by verbal contact, by facsimile, or by regular or certified mail to the UST facility address or the owner's or operator's last-known address. The owner and operator will be given a minimum of one business day to provide documentation that the finding is inaccurate or that reinstatement criteria in subparagraphs 135.3(8)"b"(1) through (5) have been satisfied. Additional days and the opportunity for a telephone or in-person conference may be provided the owner and operator to contest the factual basis for a finding under subparagraphs 135.3(8)"b"(6) through (1014). Additional procedural due process may be afforded the owner and operator on a case-by-case basis sufficient to satisfy Constitutional due process standards.

If insufficient information is submitted to change the finding, the department will notify the owner or operator and a person in charge at the UST facility of the final decision to impose the delivery prohibition response action.

ITEM 59. Amend paragraph 135.3(8)"f" as follows:

f. Delivery prohibition procedure. Upon oral or written notice that the delivery prohibition response action has been imposed, the owner or operator and any person in charge of the UST facility shall be notified that they are not authorized to receive any further delivery of regulated substances until conditions for reinstatement of eligibility are satisfied. Owners and operators are required to immediately remove and return to the department the current annual tank management fee tags or the tank registration tags if there are no tank management fee tags. Owners and operators are required to provide the department with names and contact information for all persons who convey or deposit regulated substances to the USTs. The department will attempt to notify known persons who convey or deposit regulated substances to the USTs that they are not authorized to deliver to the USTs until further notice by the department as provided in paragraph 135.3(3) "j" and subrule 135.3(5).

If the tank tags are not returned within three business days, the <u>The</u> department shall visit the site, remove the tags, and affix a "red tag" to the fill pipes or fill pipe caps of all affected USTs. It is unlawful for any person to

deposit or accept a regulated substance into a UST that has a "red tag" affixed to the fill pipe or fill pipe cap. The department may allow the owner and operator to dispense and sell the remainder of existing fuel unless the department determines there is an immediate risk of a release or other risk to human health, safety or the environment. The department shall confirm in writing the basis for the delivery prohibition response action, contacts made prior to the action, and steps the owner or operator must take to reinstate fuel delivery.

ITEM 60. Rescind subrule 135.3(9) and adopt the following **new** subrule in lieu thereof:

- 135.3(9) Secondary containment requirements for UST system installations. All new and replacement underground storage tank systems and appurtenances used for the storage and dispensing of petroleum products shall have secondary containment in accordance with this subrule. The secondary containment provision includes the installation of containment sumps.
- a. Tanks and piping installed or replaced after November 28, 2007, must have secondary containment that is designed, installed, and maintained according to the performance standards in subrule 135.3(1) and paragraph 135.5(3) "b."
- (1) The secondary containment may be manufactured as an integral part of the primary containment or constructed as a separate containment system.
 - (2) At a minimum, the secondary containment must:
 - 1. Contain regulated substances leaked from the UST system until detected and removed.
- 2. Prevent the release of regulated substances into the environment at any time during the operational life of the underground storage tank system.
- 3. Be checked for evidence of a release from the tank at least every 30 days as provided in paragraph 135.5(2) "a."
- b. Testing and inspection. Containment sumps shall be liquid-tight and must be inspected and tested in accordance with the following:
- (1) Inspections for secondary containment sumps (spill catchment basins, turbine sumps, transition or intermediate sumps, and under-dispenser containment).
- 1. Inspections for secondary containment sumps shall consist of visual inspection by an Iowa-licensed installer or Iowa-certified compliance inspector every two years.
- 2. Containment sumps must be intact (no cracks or perforations) and liquid-tight, including sides and bottom.
 - 3. Containment sumps must be maintained and kept free of debris, liquid, and ice at all times.
 - 4. Regulated substances leaked or spilled into any containment sumps shall be immediately removed.
- (2) Secondary containment sumps used for interstitial monitoring of piping shall be tested upon installation and periodically in accordance with subrule 135.4(12).

ITEM 61. Amend paragraph 135.4(1)"a" as follows:

a. Owners and operators must ensure that releases due to spilling or overfilling do not occur. The owner and operator must ensure that the volume available in the tank is greater than the volume of product to be transferred to the tank before the transfer is made and that the transfer operation is monitored constantly to prevent overfilling and spilling.

NOTE: The transfer procedures described in National Fire Protection Association Publication Standard 385, "Standard for Tank Vehicles for Flammable and Combustible Liquids" or American Petroleum Institute Recommended Practice 1007, "Loading and Unloading of MC 306/DOT 406 Cargo Tank Motor Vehicles" may be used to comply with paragraph 135.4(1) "a." Further guidance on spill and overfill prevention appears in American Petroleum Institute Publication 1621, "Recommended Practice 1621 for Bulk Liquid Stock Control at Retail Outlets," and National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code."

ITEM 62. Amend subrule 135.4(2) as follows:

135.4(2) Operation and maintenance of corrosion protection. All owners and operators of steel metal UST systems with corrosion protection must comply with the following requirements to ensure that releases due to corrosion are prevented for as long as until the UST system is used to store regulated substances permanently closed or undergoes a change in service in accordance with subrule 135.15(2):

- a. No change.
- b. All UST systems equipped with cathodic protection systems must be inspected for proper operation by a qualified cathodic protection tester in accordance with the following requirements:
 - (1) No change.
- (2) *Inspection criteria*. The criteria that are used to determine that cathodic protection is adequate as required by this subrule must be in accordance with a code of practice developed by a nationally recognized association. Note: National Association of Corrosion Engineers Standard RP-02-85, "Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems," The following codes of practice may be used to comply with subparagraph 135.4(2) "b" (2).
- NACE International Test Method TM 0101, "Measurement Techniques Related to Criteria for Cathodic Protection of Underground Storage Tank Systems";
- NACE International Test Method TM0497, "Measurement Techniques Related to Criteria for Cathodic Protection on Underground or Submerged Metallic Piping Systems";
- Steel Tank Institute Recommended Practice R051, "Cathodic Protection Testing Procedures for STI-P3® USTs";
- NACE International Standard Practice SP 0285, "External Control of Underground Storage Tank Systems by Cathodic Protection"; or
- NACE International Standard Practice SP 0169, "Control of External Corrosion on Underground or Submerged Metallic Piping Systems."
 - c. and d. No change.
- *e.* When an impressed current cathodic protection system is failing cathodic protection for the time periods given below, owners and operators must take the following actions:
- (1) For impressed current cathodic protection systems that have been inoperative for 0 to 90 days after failing a corrosion protection test or after discovering the system is not operating, all of the following must be completed:
- 1. Power must be restored to an inoperative corrosion protection system. A damaged or failed corrosion protection system must be repaired by a cathodic protection tester. A corrosion expert must approve any modifications to the system that are outside of the original design.
 - 2. The corrosion protection system must be retested within six months of repair.
 - 3. A copy of the test and any repairs must be kept as part of the cathodic protection records.
 - 4. A copy of the new design standards must be kept as part of the cathodic protection records.
- (2) For impressed current corrosion protection systems that have been inoperative for 90 to 365 days or repaired 90 to 365 days after failing a corrosion protection test, all of the following must be completed:
 - 1. Notify the department.
 - 2. Power must be restored to an inoperative corrosion protection system.
- 3. The corrosion protection system must be repaired, tested and returned to service under the supervision of a corrosion expert.
 - 4. A precision tightness test must be conducted on the entire UST system.
 - 5. The corrosion protection system must be retested within six months of the repair or power being restored.
 - 6. A copy of the test and any repairs must be kept as part of the cathodic protection records.
 - 7. A copy of the new design standards must be kept as part of the cathodic protection records.
- 8. If determined the tank is not suitable for corrosion protection, the tank must be permanently closed in accordance with subrule 135.15(2).
- (3) If the impressed current corrosion protection system has been inoperative for more than 365 days or was not repaired for more than 365 days after failing a corrosion protection test, all of the following must be completed:
 - 1. Notify the department.
 - 2. Immediately empty and stop using the tank system.
- 3. An internal inspection of the steel tank must be conducted according to a national standard (e.g., API 1631). If the UST fails the internal inspection, the UST owner must permanently close the tank in accordance with subrule 135.15(2).

- 4. All metal piping and buried metal components (e.g., flex connectors, couplings) that routinely contain product must be inspected by a UST professional or cathodic protection tester. If the metallic components have no visible corrosion and have passed a line tightness test (unless the piping is exempt from leak detection, e.g., Safe or European Suction) then the cathodic protection system may be repaired or replaced under the supervision of a corrosion expert. Metallic components that show visible corrosion must be replaced.
- 5. A precision test must be conducted on the entire UST system following repair or replacement of the cathodic protection system.
 - 6. The corrosion protection system must be retested within six months of repair.
 - 7. A copy of the tests and any repairs must be kept as part of the cathodic protection records.
 - 8. A copy of the new design standards must be kept as part of the cathodic protection records.
- (4) If the impressed current cathodic protection system has been inoperable for more than 365 days and cannot or will not be brought back into immediate use, the tank system must be permanently closed in accordance with rule 567—135.15(2).
 - ITEM 63. Amend subrule 135.4(3) as follows:
- 135.4(3) Compatibility. Owners and operators must use a UST system made of or lined with materials that are compatible with the substance stored in the UST system.
- a. Owners and operators must notify the department at least 30 days prior to switching to a regulated substance containing greater than 10 percent ethanol, greater than 20 percent biodiesel, or any other regulated substance identified by the department.
- b. Owners and operators must have a UST installer licensed under 567—Chapter 134, Part C, submit the department's checklist for equipment compatibility for the UST system to the department.
- NOTE: Owners and operators storing alcohol blends may use the following codes to comply with the requirements of subrule 135.4(3): American Petroleum Institute Publication Recommended Practice 1626, "Storing and Handling Ethanol and Gasoline-Ethanol Blends at Distribution Terminals and Service Stations "; and American Petroleum Institute Publication 1627, "Storage and Handling of Gasoline Methanol/Cosolvent Blends at Distribution Terminals and Service Filling Stations."
 - ITEM 64. Amend subrule 135.4(4) as follows:
- 135.4(4) Repairs <u>allowed and replacement</u>. Owners and operators of UST systems must ensure that repairs will prevent releases due to structural failure or corrosion as long as the UST system is used to store regulated substances. The repairs must meet the following requirements:
- a. Repairs to UST systems must be properly conducted in accordance with a code of practice developed by a nationally recognized association or an independent testing laboratory.
- NOTE: The following codes and standards may be used to comply with <u>paragraph</u> 135.4(4) "a": National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code"; American Petroleum Institute Publication 2200, "Repairing Crude Oil, Liquified Petroleum Gas, and Product Pipelines"; American Petroleum Institute Publication 1631, "Recommended Practice for the Interior Lining of Existing Steel Underground Storage Tanks"; and National Leak Prevention Association Standard 631, "Spill Prevention, Minimum 10 Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection."
 - National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code";
 - International Fire Code;
- American Petroleum Institute Recommended Practice 2200, "Repairing Crude Oil, Liquefied Petroleum Gas, and Product Pipelines";
- American Petroleum Institute Recommended Practice 1631, "Interior Lining and Periodic Inspection of Underground Storage Tanks";
- National Fire Protection Association Standard 326, "Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair";
- National Leak Prevention Association Standard 631, Chapter A, "Entry, Cleaning, Interior Inspection, Repair, and Lining of Underground Storage Tanks";
- Steel Tank Institute Recommended Practice R972, "Recommended Practice for the Addition of Supplemental Anodes to STI-P3® Tanks";
 - NACE International Standard Practice SP 0285, "External Control of Underground Storage Tank

Systems by Cathodic Protection"; or

- Fiberglass Tank and Pipe Institute Recommended Practice T-95-02, "Remanufacturing of Fiberglass Reinforced Plastic (FRP) Underground Storage Tanks."
- b. Repairs to fiberglass-reinforced plastic tanks may be made by the manufacturer's authorized representatives or in accordance with a code of practice developed by a nationally recognized association or an independent testing laboratory.
 - c. Piping and fittings.
- (1) Metal pipe sections and fittings that have released product as a result of corrosion or other damage must be replaced. Fiberglass Noncorrodible pipes and fittings may be repaired in accordance with the manufacturer's specifications.
 - (2) Any replacement of ten feet or more of piping shall have secondary containment.
- (3) If 50 percent or more of any piping run is removed, the entire piping run must be removed and replaced with secondarily contained piping and interstitial monitoring.
- (4) All piping replacements requiring secondary containment shall be constructed with transition or intermediate containment sumps.
- d. Repaired Repairs to secondary containment areas of tanks and piping used for interstitial monitoring and to containment sumps used for interstitial monitoring of piping must have the secondary containment tested for tightness according to the manufacturer's instructions, a code of practice developed by a nationally recognized association or independent testing laboratory, or according to requirements established by the department within 30 days following the date of completion of the repair. All other repairs to tanks and piping must be tightness tested in accordance with paragraphs 135.5(4) "c" and 135.5(5) "b" within 30 days following the date of the completion of the repair except as provided in subparagraphs (1) to (3) below:
- (1) The repaired tank is internally inspected in accordance with a code of practice developed by a nationally recognized association or an independent testing laboratory; or
- (2) The repaired portion of the UST system is monitored monthly for releases in accordance with a method specified in <u>paragraphs</u> 135.5(4) "d" through <u>"h" "i"</u>; or
- (3) Another test method is used that is determined by the department to be no less protective of human health and the environment than those listed above.
- NOTE regarding paragraph 135.4(4) "d": The following codes of practice may be used to comply with paragraph 135.4(4) "d":
- Steel Tank Institute Recommended Practice R012, "Recommended Practice for Interstitial Tightness Testing of Existing Underground Double Wall Steel Tanks"; or
- Fiberglass Tank and Pipe Institute Protocol, "Field Test Protocol for Testing the Annular Space of Installed Underground Fiberglass Double and Triple-Wall Tanks with Dry Annular Space."
- Petroleum Equipment Institute Publication RP1200, "Recommended Practices for the Testing and Verification of Spill, Overfill, Leak Detection and Secondary Containment Equipment at UST Facilities."
- e. Within six months following the repair of any cathodically protected UST system, the cathodic protection system must be tested in accordance with <u>paragraphs</u> 135.4(2)"b" and "c" to ensure that it is operating properly.
- f. Within 30 days following any repair to spill or overfill prevention equipment, the repaired spill or overfill prevention equipment must be tested or inspected, as appropriate, in accordance with subrule 135.4(1) to ensure it is operating properly.
- g. Installation of any new or replacement turbine pumps involving the direct connection to the tank shall have secondary containment.
- f. h. UST system owners and operators must maintain records of each repair for the remaining operating life of until the UST system that demonstrate compliance with the requirements of this subrule is permanently closed or undergoes a change-in-service pursuant to subrule 135.15(2).
- <u>i.</u> Repairs or replacements to a UST system must be conducted by an Iowa-licensed UST professional whose license is issued for that specific work.
 - ITEM 65. Amend subrule 135.4(5) as follows:
 - 135.4(5) Reporting and record keeping. Owners and operators of UST systems must cooperate fully with

inspections, monitoring and testing conducted by the department, as well as requests for document submission, testing, and monitoring by the owner or operator pursuant to Section 9005 of Subtitle I of the Resource Conservation and Recovery Solid Waste Disposal Act, as amended.

- a. Reporting. Owners and operators must submit the following information to the department:
- (1) Notification for all UST systems (135.3(3)), which includes certification of installation for new UST systems (135.3(1) "e");
 - (2) Notification of equipment replacement or addition of new equipment;
- (2) (3) Reports of all releases including suspected releases (135.6(1)), spills and overfills (135.6(4)), and confirmed releases (135.7(2));
- (3) (4) Corrective actions planned or taken including initial abatement measures (135.7(3)), initial site characterization (567—135.9(455B)), free product removal (135.7(5)), investigation of soil and groundwater cleanup and corrective action plan (567—135.8(455B) to 567—135.12(455B)); and
 - (4) (5) A notification before permanent closure or change-in-service (135.15(2))-;
 - (6) Notification of any change in ownership;
 - (7) Notification of any change in Class A or Class B operators;
 - (8) Notification of any loss of financial responsibility (i.e., insurance);
 - (9) Notification prior to UST systems switching to certain regulated substances.
 - b. Record keeping. Owners and operators must maintain the following information:
- (1) A corrosion expert's analysis of site corrosion potential if corrosion protection equipment is not used (135.3(1)"a"(4); (135.3(1)"b"(3)).
 - (2) Documentation of operation of corrosion protection equipment (135.4(2));
 - (3) Documentation of UST system repairs (135.4(4) "f" 135.4(4) "h");
 - (4) Recent Documentation of compliance with release detection requirements (135.5(6)); and
 - (5) Results of the site investigation conducted at permanent closure (135.15(5)).(135.15(3));
 - (6) Cathodic protection system testing results (135.4(2));
 - (7) Class A, B and C operator training certificates (135.4(6));
 - (8) Secondary containment test results (135.3(9));
 - (9) Documentation of periodic walkthrough inspections (135.4(13));
 - (10) Documentation of compatibility for UST systems (135.4(3));
- (11) Documentation of compliance for spill and overfill prevention equipment and containment sumps used for interstitial monitoring of piping (135.4(12)).
 - c. Availability and maintenance of records. Owners and operators must keep the records required either:
 - (1) No change.
- (2) At a readily available alternative site and be provided for inspection to the department upon within two business days of department request.

NOTE: In the case of permanent closure records required under <u>subrule</u> 135.15(5), owners and operators are also provided with the additional alternative of mailing closure records to the department if they cannot be kept at the site or an alternative site as indicated above.

ITEM 66. Amend paragraph 135.4(6)"b" as follows:

b. A facility may not operate after December 31, 2011, unless operators have been designated and trained as required in this rule, or unless otherwise agreed upon by the department based on a finding of good cause for failure to meet this requirement and a plan for designation and training at the earliest practicable date.

ITEM 67. Amend paragraph 135.4(6)"g" as follows:

g. Designated operators must successfully complete required training under subrule 135.4(9) no later than December 31, 2011.

ITEM 68. Amend paragraph 135.4(6)"i" as follows:

i. When a facility is found to be out of compliance, the department may require the owner and operator to retrain that the designated UST system Class A, B, or C operator be retrained under a plan approved by the department. The retraining must occur within 60 30 days from departmental notice for Class A and Class B operators and within 15 days for Class C operators.

ITEM 69. Amend paragraph 135.4(7)"a", as follows:

- a. Class A operator.
- (1) Class A operators have the primary responsibility to operate, and maintain, and have knowledge of the regulatory requirements for the underground storage tank system and facility. The Class A operator's responsibilities include managing resources and personnel to achieve and maintain compliance with regulatory requirements under this chapter in the following ways:
- 1. Class A operators assist the owner by ensuring that underground storage tank systems are properly installed and expeditiously repaired and inspected; financial responsibility is maintained; and records of system installation, modification, inspection and repair are retained and made available to the department and licensed certified compliance inspectors. The Class A operator shall properly respond to and report emergencies caused by releases or spills from UST systems, ensure that the annual tank management fees are paid, and ensure that Class B and Class C operators are properly trained.
 - 2. No change.
 - 3. No change.
- (2) Department-licensed installers, installation inspectors, and <u>department-certified</u> compliance inspectors may perform Class A operator duties when employed or contracted by the tank owner to perform these functions so long as they are properly trained and designated as Class A operators pursuant to subrules 135.4(9) through 135.4(11). Class A operators who are also <u>licensed certified</u> compliance inspectors under 567—Chapter 134, Part <u>CB</u>, may perform in-house facility inspections of the UST system, but shall not perform department-mandated compliance inspections pursuant to rule 567—135.20(455B). Compliance inspections of a UST facility required by rule 567—135.20(455B) must be completed by a third-party compliance inspector <u>licensed certified</u> under 567—Chapter 134, Part B.
 - (3) No change.
 - (4) No change.

ITEM 70. Amend paragraph 135.4(7)"b", as follows:

- (1) A Class B operator implements is knowledgeable of the applicable underground storage tank regulatory requirements and standards and implements them in the field or at the tank facility. A Class B operator oversees and implements the day-to-day aspects of operation, maintenance, and record keeping for the underground storage tanks at facilities within four hours of travel time from the Class B operator's principal place of business. A Class B operator's responsibilities include, but are not limited to:
 - 1. to 8. No change.
- 9. Training and documenting Class C operators to make sure at least one Class C operator is on site during operating hours. Class B operators shall be familiar with Class C operator responsibilities and may provide required training for Class C operators.
- (2) Department-licensed installers, installation inspectors, and <u>department-certified</u> compliance inspectors may perform Class B operator duties when employed or contracted by the tank owner to perform these functions so long as they are properly trained and designated as Class B operators under subrules 135.4(9) through 135.4(11). Class B operators who are also <u>licensed certified</u> compliance inspectors under 567—Chapter 134, Part <u>CB</u>, may perform in-house facility inspections of the UST system, but cannot perform department-mandated compliance inspections pursuant to rule 567—135.20(455B). Compliance inspections of a UST facility pursuant to rule 567—135.20(455B) must be completed by a third-party compliance inspector <u>licensed certified</u> under 567—Chapter 134, Part B.
 - (3) No change.

ITEM 71. Amend subparagraph 135.4(7)"c"(1) as follows:

(1) Within six months after October 14, 2009, written Written basic operating instructions, emergency contact names and telephone numbers, and basic procedures specific to the facility shall be provided to all Class C operators and readily available on site.

ITEM 72. Amend subparagraph 135.4(8)"b"(8) as follows:

(8) Discussion of the benefits of monthly or frequent inspections and content and use of inspection checklists. Requirements of 30-day and annual walkthrough inspections. Training materials for operators shall

include the department's "Iowa UST Operator Inspection Checklist" or a checklist template similar to the department's document.

ITEM 73. Adopt the following **new** subparagraph **135.4(8)**"b"(**19**):

(19) Requirements for facilities that operate unstaffed at any time.

ITEM 74. Rescind paragraph 135.4(8)"c" and adopt the following new paragraph in lieu thereof:

- c. Class C operators. To be certified as a Class C operator, an individual must complete a department-approved training course. A Class A or Class B operator who has completed a department-approved training course may provide the Class C training. Class C operator training must include at a minimum:
 - (1) A general overview of the department's UST program and purpose;
 - (2) Groundwater protection goals;
 - (3) Public safety;
 - (4) UST system overview;
 - (5) Administrative requirements; and
- (6) Action to be taken in response to an emergency condition due to a spill or release from a UST system. Training must include written procedures for the Class C operator, including notification instructions necessary in the event of emergency conditions. The written instructions and procedures must be readily available on site. A Class A or Class B operator may provide additional on-site Class C training specific to the operator's UST system.

ITEM 75. Amend paragraph 135.4(9)"b" as follows:

b. Transferability to another UST site. Class A and Class B operators may transfer to other UST facilities in Iowa provided the operator is properly designated by the facility owner as a Class A or Class B operator according to 567—subrule 134.4(13) 135.4(11). Class A and Class B operators transferring from other states shall seek prior approval of training qualifications, unless the department has preapproved the out-of-state program as substantially equivalent to the requirements of this chapter.

ITEM 76. Amend subrule 135.4(10) as follows:

135.4(10) *Timing of UST operator training.*

- a. An owner shall ensure that Class A, Class B, and Class C operators are trained as soon as practicable after October 14, 2009, contingent upon availability of by approved training providers, but not later than December 31, 2011, except as provided in paragraph 135.4(6)"b." before an operator assumes duties of that class of operator.
- b. When a Class A or Class B operator is replaced, a new operator must be trained prior to assuming duties for that class of operator. A copy of the certificate of training must be submitted to the department within 30 days of assuming duties.
- c. Class C operators must be trained before assuming the duties of a Class C operator. Within six months after October 14, 2009, written Written basic operating instructions, emergency contact names and telephone numbers, and basic procedures specific to the facility shall be provided to all Class C operators and readily available on site. A Class C operator may be briefed on these procedures concurrent with annual safety training required under Occupational Safety and Health Administration regulations, 29 CFR, Part 1910.

ITEM 77. Amend paragraph 135.4(11)"b" as follows:

b. A copy of the certificates of training for Class A and Class B operators shall be on file and readily available for inspection in accordance with subrule 135.4(5). Records verifying completion of training or retraining of Class A, Class B, and Class C operators must identify name of trainee, date trained, operator training class completed, and list the name of the trainer or examiner and the training company name, address, and telephone number. Owners and operators must maintain these records for as long as Class A, Class B, and Class C operators are designated.

ITEM 78. Adopt the following **new** subrules 135.4(12) and 135.4(13):

- **135.4(12)** Periodic testing of spill prevention equipment and containment sumps used for interstitial monitoring of piping and periodic inspection of overfill prevention equipment.
 - a. Owners and operators of UST systems with spill and overfill prevention equipment and containment

sumps used for interstitial monitoring of piping must meet these requirements to ensure the equipment is operating properly and will prevent releases to the environment:

- (1) Spill prevention equipment (such as a catchment basin, spill bucket, or other spill containment device) and containment sumps used for interstitial monitoring of piping must prevent releases to the environment by meeting one of the following:
- 1. The equipment is double walled and the integrity of both walls is periodically monitored at a frequency of not less than the frequency of the walkthrough inspections described in subrule 135.4(13). If owners and operators discontinue periodic monitoring of this equipment, they must begin meeting paragraph 135.4(12) "a"(1)"2" and conduct a test within 30 days of discontinuing periodic monitoring of this equipment; or
- 2. The spill prevention equipment and containment sumps used for interstitial monitoring of piping are tested at least once every three years to ensure the equipment is liquid tight by using vacuum, pressure, or liquid testing in accordance with one of the following criteria:
- Requirements developed by the manufacturer (Note: Owners and operators may use this option only if the manufacturer has developed requirements); or
- A code of practice developed by a nationally recognized association or independent testing laboratory; or
- Requirements determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule.
- (2) Overfill prevention equipment must be inspected at least once every three years. At a minimum, the inspection must ensure that overfill prevention equipment is set to activate at the correct level specified in paragraph 135.3(1)"c" and will activate when regulated substance reaches that level. Inspections must be conducted in accordance with one of the following criteria:
- Requirements developed by the manufacturer (Note: Owners and operators may use this option only if the manufacturer has developed requirements); or
- A code of practice developed by a nationally recognized association or independent testing laboratory; or
- Requirements determined by the department to be no less protective of human health and the environment than the requirements listed in this subrule.
 - b. Owners and operators must begin meeting these requirements as follows:
- (1) For UST systems in use on or before [the effective date of this rule], the initial spill prevention equipment test and overfill prevention equipment inspection must be conducted not later than October 13, 2021.
- (2) For UST systems brought into use after [the effective date of this rule], these requirements apply at installation.
- c. Owners and operators must maintain records as follows for spill prevention equipment and overfill prevention equipment:
 - (1) All records of testing or inspection must be maintained for three years; and
- (2) For spill prevention equipment and containment sumps used for interstitial monitoring of piping not tested every three years, documentation showing that the prevention equipment is double-walled and the integrity of both walls is periodically monitored must be maintained for as long as the equipment is periodically monitored.

NOTE: The following code of practice may be used to comply with this section: Petroleum Equipment Institute Publication RP1200, "Recommended Practices for the Testing and Verification of Spill, Overfill, Leak Detection and Secondary Containment Equipment at UST Facilities."

135.4(13) *Periodic operation and maintenance walkthrough inspections.* Conduct inspections to properly operate and maintain UST systems.

- a. Conduct a walkthrough inspection every 30 days that, at a minimum, checks the following equipment as specified below (Exception: spill prevention equipment at UST systems receiving deliveries at intervals greater than every 30 days may be checked prior to each delivery):
- (1) Spill prevention equipment: visually check for damage; remove liquid or debris; check for and remove obstructions in the fill pipe; check the fill cap to make sure it attaches securely on the fill pipe and gasket is in

good condition; and, for double-walled spill prevention equipment with interstitial monitoring, check for a leak in the interstitial area, and

- (2) Release detection equipment: check to make sure the release detection equipment is operating with no alarms or other unusual operating conditions present, and ensure records of release detection testing are reviewed and current.
- b. Conduct a walkthrough inspection annually, at a minimum, checking the following equipment as specified below:
- (1) Containment sumps: visually check for damage, leaks to the containment area, or releases to the environment; remove liquid (in contained sumps) or debris; and, for double-walled sumps with interstitial monitoring, check for a leak in the interstitial area, and
- (2) Handheld release detection equipment: check devices such as tank gauge sticks or groundwater bailers for operability and serviceability;
- c. Conduct operation and maintenance walkthrough inspections according to a standard code of practice developed by a nationally recognized association or independent testing laboratory that checks equipment comparable to paragraphs 135.4(13) "a" and "b;" or

NOTE to paragraph 135.4(13) "c": the following code of practice may be used to comply with paragraph 135.4(13) "c": Petroleum Equipment Institute Recommended Practice RP 900, "Recommended Practices for the Inspection and Maintenance of UST Systems."

- d. Conduct operation and maintenance walkthrough inspections developed by the department that checks equipment comparable to paragraphs 135.4(13) "a" and "b."
- e. Owners and operators must maintain records (in accordance with subrule 135.4(5)) of operation and maintenance walkthrough inspections for 12 consecutive months. Records must include a list of each area checked, whether each area checked was acceptable or needed action taken, a description of actions taken to correct an issue, and delivery records if spill prevention equipment is checked less frequently than every 30 days due to infrequent deliveries.

ITEM 79. Amend paragraph 135.5(1)"a" as follows:

- a. Owners and operators of new and existing UST systems must provide a method, or combination of methods, of release detection that:
- (1) Can detect a release from any portion of the tank and the connected underground piping that routinely contains product;
- (2) Is installed, and calibrated, operated, and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks for operability or running condition; and
- (3) Beginning October 13, 2021, is operated and maintained, and electronic and mechanical components are tested for proper operation, in accordance with one of the following:
 - 1. Manufacturer's instructions;
- 2. A code of practice developed by a nationally recognized association or independent testing laboratory; or
- 3. Requirements determined by the department to be no less protective of human health and the environment than the two options listed above.
- (4) A test of the proper operation must be performed at least annually and, at a minimum, as applicable to the facility, cover the following components and criteria:
 - 1. Automatic tank gauge and other controllers: test alarm; verify system configuration; test battery backup;
- 2. Probes and sensors: inspect for residual buildup; ensure floats move freely; ensure shaft is not damaged; ensure cables are free of kinks and breaks; test alarm operability or running condition and communication with controller;
- 3. Automatic line leak detector: test operation to meet criteria in paragraph 135.5(5) "a" by simulating a leak:
 - 4. Vacuum pumps and pressure gauges: ensure proper communication with sensors and controller; and
- 5. Handheld electronic sampling equipment associated with groundwater and vapor monitoring: ensure proper operation.

NOTE regarding subparagraphs 135.5(1) "a" (3) and (4): The following code of practice may be used to comply

- with subparagraphs 135.5(1)"a"(3) and (4): Petroleum Equipment Institute Publication RP1200, "Recommended Practices for the Testing and Verification of Spill, Overfill, Leak Detection and Secondary Containment Equipment at UST Facilities."
- (3) (5) Meets the performance requirements in <u>subrule</u>135.5(4) or 135.5(5), with any performance claims and their manner of determination described in writing by the equipment manufacturer or installer. In addition, methods conducted in accordance with <u>paragraphs</u> 135.5(4) "b," "c," and "d" and 135.5(5) "b" after December 22, 1990, and 135.5(5) "a" after September 22, 1991, except for methods permanently installed prior to those dates, <u>paragraphs</u> 135.5(5) "a" and "b" must be capable of detecting the leak rate or quantity specified for that method with a probability of detection of 0.95 and a probability of false alarm of 0.05.

ITEM 80. Amend paragraph 135.5(1)"b" as follows:

b. When a release detection method operated in accordance with the performance standards in subrule 135.5(4) and or 135.5(5) indicates a release may have occurred, owners and operators must notify the department in accordance with rule 567—135.6(455B).

ITEM 81. Rescind paragraph 135.5(1)"c" and adopt the following new paragraph in lieu thereof:

c. When an owner and operator continually show the inability to conduct leak detection with the method being used, the department may require the owner and operator to find an alternative leak detection method. If the owner and operator cannot demonstrate compliance with leak detection, delivery prohibition in accordance with subrule 135.3(8) may be enforced.

ITEM 82. Amend paragraph 135.5(1)"d" as follows:

d. Any existing UST system that cannot apply a method of release detection that complies with the requirements of this rule must complete the closure procedures in rule 567—135.15(455B) by the date on which release detection is required for that UST system under paragraph "c.". For previously deferred UST systems described in rule 567—135.1(455B) and 567—135.21(455B), this requirement applies after the effective dates described in subrule 135.1(3) and paragraph 135.21(1)"a."

ITEM 83. Amend paragraph 135.5(2)"a" as follows:

- a. Tanks. Tanks must be monitored at least every 30 days for releases using one of the methods listed in paragraphs 135.5(4) "d" to "h" except that:
- (1) UST systems that meet the performance standards in 135.3(1) or 135.3(2), and the monthly inventory control requirements in 135.5(4)"a" or "b," may use tank tightness testing (conducted in accordance with 135.5(4)"c") at least every five years until December 22, 1998, or until ten years after the tank is installed or upgraded under 135.3(2)"b," whichever is later; Tanks installed after November 28, 2007, must use interstitial monitoring of the secondary containment as the primary leak detection method in accordance with paragraph 135.5(4)"g."
- (2) UST systems that do not meet the performance standards in 135.3(1) or 135.3(2) may use monthly inventory controls (conducted in accordance with 135.5(4)"a" or "b") and annual tank tightness testing (conducted in accordance with 135.5(4)"c") until December 22, 1998, when the tank must be upgraded under 135.3(2) or permanently closed under 135.15(2); and
- (3) (2) Tanks <u>installed on or before November 28, 2007</u>, with capacity of 550 gallons or less may use weekly and tanks with a capacity of 551 to 1,000 gallons that meet the tank diameter criteria in paragraph 135.5(4) "b" may use manual tank gauging (conducted in accordance with <u>paragraph</u> 135.5(4) "b").

ITEM 84. Amend paragraph 135.5(2)"b" as follows:

- b. Piping. Underground piping that routinely contains regulated substances must be monitored for releases in a manner that meets one of the following requirements:
 - (1) Pressurized piping. Underground piping that conveys regulated substances under pressure must:
- 1. Be equipped with an automatic line leak detector conducted in accordance with <u>paragraph</u> 135.5(5) "a"; and
- 2. Have an annual line tightness test conducted in accordance with <u>paragraph</u> 135.5(5) "b" or have monthly monitoring conducted in accordance with <u>paragraph</u> 135.5(5) "c." <u>Piping installed after November 28, 2007</u>, must use interstitial monitoring of the piping secondary containment in accordance with paragraph 135.5(5) "d."
 - (2) Suction piping. Underground piping that conveys regulated substances under suction must either have a

line tightness test conducted at least every three years and in accordance with <u>paragraph</u>135.5(5)"b," or use a monthly monitoring method conducted in accordance with <u>paragraph</u>135.5(5)"c."Remote fill is considered <u>suction piping</u>. No release detection is required for suction piping that is designed and constructed to meet the following standards:

- 1. to 5. No change.
- (3) Piping installed or replaced must meet one of the following:
- 1. Pressurized piping must be monitored for releases at least every 30 days in accordance with paragraph 135.5(5)"d" and be equipped with an automatic line leak detector.
- 2. Suction piping must be monitored for releases at least every 30 days. No release detection is required for suction piping that meets subparagraphs 135.5 "b" (2)"1" through 135.5 "b" (2)"5."
 - ITEM 85. Rescind subrule 135.5(3) and adopt the following **new** subrule in lieu thereof:
- 135.5(3) Requirements for hazardous substance UST systems. Owners and operators of hazardous substance UST systems must have containment that meets the following requirements and monitor these systems pursuant to paragraph 135.5(4) "g" at least every 30 days:
 - a. Secondary containment systems must be designed, constructed and installed to:
 - (1) Contain regulated substances leaked from the primary containment until they are detected and removed;
- (2) Prevent the release of regulated substances to the environment at any time during the operational life of the UST system; and
 - (3) Be checked for evidence of a release at least every 30 days.
 - b. Double-walled tanks must be designed, constructed, and installed to:
 - (1) Contain a leak from any portion of the inner tank within the outer wall; and
 - (2) Detect the failure of the inner wall.
 - c. External liners (including vaults) must be designed, constructed, and installed to:
 - (1) Contain 100 percent of the capacity of the largest tank within its boundary;
- (2) Prevent the interference of precipitation or groundwater intrusion with the ability to contain or detect a release of regulated substances; and
- (3) Surround the tank completely (i.e., it is capable of preventing lateral as well as vertical migration of regulated substances).
- d. Underground piping must be equipped with secondary containment that satisfies the requirements of this subrule (e.g., trench liners, jacketing of double-walled pipe). In addition, underground piping that conveys regulated substances under pressure must be equipped with an automatic line leak detector in accordance with paragraph 135.5(5)"a";
- e. For hazardous substance UST systems installed on or before November 28, 2007, other methods of release detection may be used if owners and operators:
- (1) Demonstrate to the department that an alternate method can detect a release of the stored substance as effectively as any of the methods allowed in paragraphs 135.5(4) "b" to "i" can detect a release;
- (2) Provide information to the department on effective corrective action technologies, health risks, and chemical and physical properties of the stored substance, and the characteristics of the UST site; and
- (3) Obtain approval from the department to use the alternate release detection method before the installation and operation of the new UST system.

ITEM 86. Amend paragraph 135.5(4)"a" as follows:

- a. Inventory control. Product inventory control (or another test of equivalent performance) must be conducted monthly to detect a release of at least 1.0 percent of flow-through plus 130 gallons on a monthly basis in the following manner:
 - (1) to (5) No change.
- (6) The measurement of any water level in the bottom of the tank is made to the nearest 1/8 of an inch at least once a month.

NOTE: Practices described in the American Petroleum Institute <u>Publication Recommended Practice</u> 1621, "Recommended Practice for Bulk Liquid Stock Control at Retail Outlets," may be used, where applicable, as guidance in meeting the requirements of <u>subrule 135.5(4)</u>, <u>paragraph "a,"</u> subparagraphs (1) to (6) 135.5(4) "a"(1) to 135.5(4) "a"(6).

ITEM 87. Rescind paragraph 135.5(4)"b" and adopt the following new paragraph in lieu thereof:

- b. Manual tank gauging. Manual tank gauging must meet the following requirements:
- (1) Tank liquid level measurements are taken at the beginning and end of the test period during which no liquid is added to or removed from the tank;
- (2) Level measurements are based on an average of two consecutive stick readings at both the beginning and ending of the period;
- (3) The equipment is capable of measuring the level of product over the full range of the tank's height to the nearest 1/8 of an inch;
- (4) A release is suspected and subject to the requirements of rule 567—135.6(455B) if the variation between the beginning and ending measurements exceeds the weekly or monthly standards in the following table. Immediately contact the department if these standards are exceeded.

Nominal Tank Capacity	Minimum Duration of Test	Weekly Standard (one test)	Monthly Standard (four-test average)
550 gallons or less	36 hours	10 gallons	5 gallons
551-1,000 gallons (when tank diameter is 64 inches)	44 hours	9 gallons	4 gallons
551-1,000 gallons (when tank diameter is 48 inches)	58 hours	12 gallons	6 gallons
551-1,000 gallons (also requires annual tank tightness testing)	36 hours	13 gallons	7 gallons
1,001-2,000 gallons (also requires annual tank tightness test)	36 hours	26 gallons	13 gallons

(5) Only those tanks of 550 gallons or less nominal capacity or tanks of 551 to 1,000 gallons nominal capacity with diameters of 64 inches or 48 inches may use this as the sole method of release detection. Other tanks of 551 to 2,000 gallons may use this method in place of inventory control in paragraph 135.5(4) "a." Tanks of greater than 2,000 gallons nominal capacity may not use this method to meet the requirements of this rule.

ITEM 88. Amend paragraph 135.5(4)"c" as follows:

c. Tank tightness testing. Tank tightness testing (or another test of equivalent performance) must be capable of detecting a 0.1 gallon-per-hour leak rate from any portion of the tank that routinely contains product while accounting for the effects of thermal expansion or contraction of the product, vapor pockets, tank deformation, evaporation or condensation, and the location of the water table.

The tank tightness test procedure must be certified by a third party and meet US EPA testing procedures. The testing procedures are found in *Standard Test Procedures for Evaluating Leak Detection Methods: Volumetric Tank Tightness Testing Methods* (EPA /530/UST-90/004) March 1990 or as revised by EPA or *Non Volumetric Tank Tightness Testing Methods* (EPA /530/UST-90/005) March 1990 or as revised by EPA.

ITEM 89. Amend paragraph 135.5(4)"d" as follows:

- d. Automatic tank gauging. Equipment for automatic tank gauging that tests for the loss of product and conducts inventory control must meet the following requirements:
- (1) The automatic product level monitor test can detect a 0.2 gallon-per-hour leak rate from any portion of the tank that routinely contains product; and
- (2) The automatic tank gauging equipment must meet the Inventory control (or another other test of equivalent performance) is conducted in accordance with the requirements of paragraph 135.5(4) "a-";
 - (3) The leak test must be performed according to manufacturer specifications;
- (4) The automatic tank gauging equipment must be certified by a third party and meet US EPA testing procedures in Standard Test Procedures for Evaluating Leak Detection Methods: Automatic Tank Gauging

Systems (ATGS) (EPA /530/UST-90/006) March 1990 or as revised by US EPA; and

- (5) The test must be performed with the system operating in one of the following modes:
- 1. In-tank static testing conducted at least once every 30 days; or
- 2. Continuous in-tank leak detection operating on an uninterrupted basis or operating within a process that allows the system to gather incremental measurements to determine the leak status of the tank at least once every 30 days.

ITEM 90. Amend subparagraph 135.5(4)"e"(6) as follows:

(6) In the UST excavation zone, the site is assessed to ensure compliance with the requirements in <u>subparagraphs</u> 135.5(4) "e"(1) to <u>through</u> (4) and to establish the number and positioning of monitoring wells that will detect releases within the excavation zone from any portion of the tank that routinely contains product; and

ITEM 91. Amend subparagraph 135.5(4)"e"(7) as follows:

- (7) Monitoring wells are clearly marked and secured to avoid unauthorized access and tampering -; and
- ITEM 92. Adopt the following **new** subparagraph **135.5(4)**"e"(8):
- (8) The vapor product detector must be certified by a third party and meet US EPA testing procedures in *Standard Test Procedures for Evaluating Leak Detection Methods: Vapor-Phase Out-of-Tank Product Detectors* (EPA/530/UST-90/008) March 1990 or as revised by US EPA.

ITEM 93. Amend subparagraph 135.5(4)"f"(7) as follows:

(7) Within and immediately below the UST system excavation zone, the site is assessed to ensure compliance with the requirements in <u>subparagraphs</u> 135.5(4) "f"(1) to <u>through</u> (5) and to establish the number and positioning of monitoring wells or devices that will detect releases from any portion of the tank that routinely contains product; and

ITEM 94. Amend paragraph 135.5(4)"g" as follows:

- g. Interstitial monitoring. Interstitial monitoring between the UST system and a secondary barrier immediately around or beneath it may be used, but only if the system is designed, constructed and installed to detect a leak from any portion of the tank that routinely contains product and also meets one of the following requirements:
- (1) For secondary containment systems, the sampling or testing method must be able to detect a release <u>leak</u> through the inner wall in any portion of the tank that routinely contains product:
- 1. Continuously, by means of an automatic leak sensing device that signals to the operator the presence of any regulated substance in the interstitial space; or
- 2. Monthly, by means of a procedure capable of detecting the presence of any regulated substance in the interstitial space.
- 3. The interstitial space shall be maintained and kept free of liquid, debris or anything that could interfere with leak detection capabilities.

NOTE: The provisions outlined in the Steel Tank Institute's "Standard for Dual Wall Underground Storage Tanks" may be used as guidance for aspects of the design and construction of underground steel double-walled tanks.

- (2) For UST systems with a secondary barrier within the excavation zone, the sampling or testing method used can detect a release leak between the UST system and the secondary barrier:
- 1. The secondary barrier around or beneath the UST system consists of artificially constructed material that is sufficiently thick and impermeable (at least 10 -6 cm/sec for the regulated substance stored) to direct a release leak to the monitoring point and permit its detection;
- 2. The barrier is compatible with the regulated substance stored so that a release <u>leak</u> from the UST system will not cause a deterioration of the barrier allowing a release to pass through undetected;
 - 3. to 6. No change.
- (3) For tanks with an internally fitted liner, an automated device can detect a release <u>leak</u> between the inner wall of the tank and the liner, and the liner is compatible with the substance stored.

ITEM 95. Reletter paragraph 135.5(4)"h" as 135.5(4)"i."

ITEM 96. Adopt the following **new** paragraph **135.5(4)**"h":

- h. Statistical inventory reconciliation. Release detection methods based on the application of statistical principles to inventory data that test for the loss of product must meet the following requirements:
 - (1) Use a leak threshold that does not exceed one-half the minimum detectible leak rate;
- (2) The statistical test must be able to detect at least a 0.2 gallon per hour leak rate from any portion of the tank that routinely contains product; and
- (3) The report by the SIR company must be a quantitative result with a calculated leak rate and include the leak threshold (leak rate at which a leak is declared), the calculated leak rate (leak rate calculated from the inventory records) and minimum detectable leak rate (minimum leak rate that can be determined from the inventory records).
- 1. A "pass" means that the calculated leak rate for the data set is less than the leak threshold and the minimum detectable leak rate is less than or equal to the certified performance standard;
 - 2. A "fail" means the calculated leak rate for the data set is equal to or greater than the leak threshold;
- 3. An "inconclusive" means the minimum detectable leak rate exceeds the certified performance standard and the calculated leak rate is less than the leak threshold. If for any other reason the test result is not a "pass" or "fail," the result is "inconclusive";
- (4) Owners and operators must notify the department in accordance with rule 567—135.6(455B) when a monthly SIR report of "fail" occurs or two consecutive inconclusive results occur.
- (5) Owners and operators must assure the SIR analytical results are complete and available to the department upon request.
- (6) The statistical inventory reconciliation method must be certified by a third party and meet US EPA testing procedures in *Standard Test Procedures for Evaluating Release Detection Methods: Statistical Inventory Reconciliation* (EPA 510-B-19-004) May 2019 or as revised by EPA.

ITEM 97. Amend paragraphs 135.5(5)"a" to "c" as follows:

- a. Automatic line leak detectors. Methods which alert the operator to the presence of a leak <u>in pressurized</u> <u>piping</u> by restricting or shutting off the flow of regulated substances through piping or triggering an audible or visual alarm may be used only if they detect leaks of 3 gallons per hour at 10 pounds per square inch line pressure within one hour. An annual test of the operation of the leak detector must be conducted in accordance with the manufacturer's requirements. paragraph 135.5(1) "a."
- b. Line tightness testing. A periodic test of piping may be conducted only if it can detect a 0.1 gallon-per-hour leak rate at one and one-half times the operating pressure. The line leak detection method must be certified by a third party and meet US EPA testing procedures in Standard Test Procedures for Evaluating Release Detection Methods: Pipeline Release Detection (EPA 510-B-19-005) May 2019 or as revised by EPA.
- c. Applicable tank methods. Any Except as described in paragraph 135.5(2)"a," any of the methods in paragraphs 135.5(4)"e" through "h""i" may be used if they are designed to detect a release from any portion of the underground piping that routinely contains regulated substances.

ITEM 98. Amend subparagraph 135.5(5)"d"(1) as follows:

- (1) Leak detection shall be conducted:
- 1. Continuously Continuously, by means of an automatic leak sensing device that signals to the operator the presence of any regulated substance in the interstitial space or containment sump; or
 - 2. No change.

ITEM 99. Amend paragraphs 135.5(6)"a" and "b" as follows:

a. All written performance claims pertaining to any release detection system used, and the manner in which these claims have been justified or tested by the equipment manufacturer or installer, must be maintained for five years, or for another reasonable period of time determined by the department, from the date of installation. Records of site assessments required for vapor monitoring under subparagraph 135.5(4) "f"(7) must be maintained for as long as the methods are used. Records of site assessments must be signed by a professional engineer or professional geologist, or equivalent licensed professional with experience in environmental engineering, hydrogeology, or other relevant technical discipline acceptable to the department;

- b. The results of any sampling, testing, or monitoring must be maintained for at least one year, or for another reasonable period of time determined by the department, except that the results of tank tightness testing conducted in accordance with 135.5(4) "c" must be retained until the next test is conducted; and as follows:
- (1) The results of tank tightness testing conducted in accordance with paragraph 135.5(4) "c" must be retained until the next test is conducted; and
- (2) The results of annual operation tests conducted in accordance with subparagraphs 135.5(1) "a"(3) and (4), must be maintained for three years. At a minimum, the results must list each component tested, indicate whether each component tested meets criteria in subparagraphs 135.5(1) "a"(3) and (4), or needs to have action taken, and describe any action taken to correct an issue; and
- (3) The results of tank tightness testing, line tightness testing, and vapor monitoring using a tracer compound placed in the tank system conducted in accordance with paragraph 135.21(2) "f" must be retained until the next test is conducted; and

ITEM 100. Amend paragraphs 135.6(1)"b" and "c" as follows:

- b. Unusual operating conditions observed by owners and operators (such as the erratic behavior of product dispensing equipment, the sudden loss of product from the UST system, or an unexplained presence of water in the tank, or liquid in the interstitial space of secondarily contained systems), unless system equipment is found to be defective but not leaking, and is immediately repaired or replaced; and:
- (1) The system equipment or component is found not to be releasing regulated substances to the environment;
 - (2) Any defective system equipment or component is immediately repaired or replaced; and
- (3) For secondarily contained systems, except as provided for in paragraph 135.5(4) "g"(2)"4," any liquid in the interstitial space not used as part of the interstitial monitoring method (for example, brine filled) is immediately removed.
- c. Monitoring results , including investigation of an alarm, from a release detection method required under subrules 135.5(2) and 135.5(3) that indicate a release may have occurred unless:
- (1) The monitoring device is found to be defective, and is immediately repaired, recalibrated or replaced, and additional monitoring does not confirm the initial result; or
 - (2) The leak is contained in the secondary containment and:
- 1. Except as provided for in paragraph 135.5(4) "g"(2)"4," any liquid in the interstitial space not used as part of the interstitial monitoring method (for example, brine filled) is immediately removed; and
 - 2. Any defective system equipment or component is immediately repaired or replaced;
- $\frac{(2)}{(3)}$ In the case of inventory control, a second month of data does not confirm the initial result or the investigation determines no release has occurred; or
- (4) The alarm was investigated and determined to be a non-release event (for example, from a power surge or caused by filling the tank during release detection testing).

ITEM 101. Amend paragraph 135.6(3)"a" as follows:

- a. System test. Owners and operators must conduct tests (according to the requirements for tightness testing in <u>paragraphs</u> 135.5(4) "c" and 135.5(5) "b") that determine whether a leak exists in that portion of the tank that routinely contains product, or the attached delivery piping or both or, as appropriate, secondary containment testing described in paragraph 135.4(4).
 - (1) The test must determine whether:
- 1. A leak exists in that portion of the tank that routinely contains product, or the attached delivery piping; or
 - 2. A breach of either wall of the secondary containment has occurred.
- (1) (2) Owners If the system test confirms a leak into the interstice or a release, owners and operators must repair, replace, or upgrade, or close the UST system and. In addition, owners and operators must begin corrective action in accordance with rule 567—135.9(455B) if the test results for the system, tank, or delivery piping indicate a leak release exists.
- (2) (3) Further investigation is not required if the test results for the system, tank, and delivery piping do not indicate a leak release exists and if environmental contamination is not the basis for suspecting a release.
 - (3) (4) Owners and operators must conduct a site check as described in paragraph 135.6(3) "b" of this

subrule if the test results for the system, tank, and delivery piping do not indicate a leak release exists but environmental contamination is the basis for suspecting a release.

ITEM 102. Amend subparagraph 135.6(4)"a"(2) as follows:

(2) Spill, overfill or any aboveground release of a hazardous substance that results in a release to the environment that equals or exceeds its reportable quantity under CERCLA (40 CFR 302) as of September 13, 1988.

ITEM 103. Amend subrule 135.7(3), introductory paragraph, as follows:

135.7(3) Initial abatement measures and site check.

ITEM 104. Amend subrule 135.7(5), introductory paragraph, as follows:

135.7(5) Free product assessment and removal. The free product assessment and removal requirements in this chapter are primarily concerned with a regulated substance that is present as a light nonaqueous phase liquid (LNAPL) in a monitoring well, boring, excavation, or other location at a thickness of more than 0.01 ft. At sites where investigations under subparagraph 135.7(3) "a" (6) indicate 0.01 ft. or more of free product, owners and operators must immediately initiate a free product recovery assessment and submit a report in accordance with paragraph 135.7(5)"d" and initiate interim free product removal while continuing, as necessary, any actions initiated under 135.7(2) to 135.7(4) and 135.7(3), or preparing for actions required under rules 567— 135.8(455B) to 567—135.12(455B). Owners and operators must immediately begin interim free product removal by bailing or by installation and maintenance of passive skimming equipment until an alternative removal method is required by or approved by the department. A certified groundwater professional must initially determine the frequency of bailing and proper installation and maintenance of the skimming equipment based on a determination of the recharge rate of the free product. The department may approve implementation of this interim removal process by persons not certified as groundwater professionals. For approval a certified groundwater professional must submit (1) sufficient documentation establishing that the bailing or skimming system has been adequately designed and tested, and (2) a written plan for regular maintenance, reporting and supervision by a certified groundwater professional. Interim free product recovery reports must be submitted to the department on a monthly basis and on forms provided by the department. In meeting the requirements of this subrule, owners and operators must:

ITEM 105. Amend subparagraphs 135.7(5)"d"(9) and (10) as follows:

- (9) Free product plume definition and map. The extent of free product in groundwater must be assessed. The If monitoring wells are used to define the free product plume, the number and location of wells and separation distance between the wells used to define the free product plume must be based on the receptors present and the site hydrology and geology. A minimum of five monitoring wells are required to construct the plume map. The boundary of the plume may be determined by half the distance between wells with free product and wells with no free product. If the groundwater professional can adequately define the plume using other technology as specified in approved by the department guidance, fewer than five wells may be used. The boundary of the plume may be determined by linear interpolation consistent with the methods described in 135.10(2)"f"(3) to define the boundary of the plume; and
- (10) The estimated volume of free product present, how the volume was calculated, recoverable volume and estimated recovery time-; and

ITEM 106. Adopt the following <u>new</u> subparagraph 135.7(5)"d"(11):

(11) Identification of all water lines, regardless of construction material, within the area of free product. A water line shall be considered within the area of free product if it is located within the boundary of the free product plume as defined by wells unless it can be demonstrated that no LNAPL exists within 10 feet (horizontally or vertically) of the water line and the LNAPL is not migrating nor is likely to migrate. Water lines within the area of free product must be relocated unless there is no other option and the department has approved an alternate plan of construction. See paragraph 135.12(3) "c."

ITEM 107. Amend paragraph 135.7(5)"f" as follows:

f. Termination of free product recovery activities. Owners and operators may propose to the department to terminate free product recovery activities when significant amounts of hydrocarbons are not being recovered.

The department will consider proposals to terminate free product recovery when the amount of product collected from a monitoring well is equal to or less than 0.1 gallon each month for a year unless another plan is approved by the department. When free product activities have been terminated, owners and operators must inspect the monitoring wells monthly for at least a year <u>unless another schedule is approved by the department</u>. The department must be notified and <u>may require that</u> free product recovery activities <u>be</u> reinitiated if during the monthly well inspections it is determined the product thickness in a monitoring well exceeds 0.02 foot ft. The monthly well inspection records must be kept available for review by the department.

ITEM 108. Amend paragraph 135.8(1)"a" as follows:

a. Tier 1. The purpose of a Tier 1 assessment is to identify sites which do not pose whether a site poses an unreasonable risk to public health and safety or the environment based on limited site data. The objective is to determine maximum concentrations of chemicals of concern at the source of a release(s) in soil and groundwater. The Tier 1 assessment assumes worst-case scenarios in which actual or potential receptors could be exposed to these chemicals at maximum concentrations through certain soil and groundwater pathways. The point of exposure is assumed to be the source showing maximum concentrations. Risk-based screening levels (Tier 1 levels) contained in the Tier 1 Look-Up Table have been derived from models which use conservative assumptions to predict exposure to actual and potential receptors. (These models and default assumptions are contained in Appendix A.) If Tier 1 levels are not exceeded for a pathway, that pathway may not require further assessment. If the maximum concentrations exceed a Tier 1 level, the options are to conduct a more extensive Tier 2 assessment, apply an institutional control, or in limited circumstances excavate contaminated soil to below Tier 1 levels. If all pathways clear the Tier 1 levels, it is possible for the site to obtain a no action required classification.

ITEM 109. Amend subrule 135.8(3) as follows:

135.8(3) Chemicals of concern. Soil and groundwater samples from releases of petroleum regulated substances must always be analyzed for the presence of benzene, ethylbenzene, toluene, and xylenes. In addition, if the release is suspected to include any petroleum regulated substance other than gasoline or gasoline blends, or if the source of the release is unknown, the samples must be tested for the presence of Total Extractable Hydrocarbons (TEH). Appendices A and B and department Tier 2 guidance define a method for converting TEH values to a default concentration for naphthalene, benzo(a)pyrene, benz(a)anthracene and chrysene and conversion back to a representative TEH value. These default values must be used in order to apply Tier 2 modeling to these constituents in the absence of accurate laboratory analysis. At Tier 2 and Tier 3, owners and operators have the option of analyzing for these specific constituents and applying them to the specific target levels in Appendices A and B instead of using the TEH conversion method if an approved laboratory and laboratory technique are used.

ITEM 110. Amend subrule 135.9(1), introductory paragraph, as follows:

135.9(1) General. The main objective of a Tier 1 site assessment is to reasonably determine the highest concentrations of chemicals of concern which would be associated with any suspected or confirmed release and an accurate identification of applicable receptors. In addition, the The potential source of a release, nature of the substance released, site stratigraphy, depth to groundwater, and other appropriate factors must be considered when selecting the sample types, sample locations, and measurements methods. The placement and depth of borings and the construction of monitoring wells must be sufficient to determine the sources of all releases, the vertical extent of contamination, an accurate description of site stratigraphy, and a reliable determination of groundwater flow direction.

ITEM 111. Amend paragraphs 135.9(1)"b" and "c" as follows:

b. Pathway clearance. If field data contaminant concentrations for an individual pathway does do not exceed the applicable Tier 1 levels or if a pathway is incomplete, no further action is required to evaluate the pathway unless otherwise specified in these rules. If the field data contaminant concentrations for a pathway exceeds exceed the applicable Tier 1 level(s) in the "Iowa Tier 1 Look-up Table," the response is to conduct further assessment under Tier 2 or Tier 3 unless an effective institutional control is approved. In limited circumstances excavation of contaminated soils may be used as an option to obtain pathway clearance. If further site assessment indicates site data exceeds an applicable Tier 1 level(s) for a previously cleared pathway or the

conditions justifying a determination of pathway incompleteness change, that pathway must be reevaluated as part of a Tier 2 or Tier 3 assessment.

c. Chemical group clearance. If field data concentrations for all chemicals of concern within a designated group of chemicals is are below the Tier 1 levels, no further action is required as to the group of chemicals unless otherwise specified in these rules. Group one consists of benzene, ethylbenzene, toluene, and xylenes (BTEX). Group two consists of naphthalene, benzo(a)pyrene, benz(a)anthracene and chrysene; TEH default values are incorporated into the Iowa Tier 1 Look-Up Table and Appendix A for group two chemicals.

ITEM 112. Amend paragraph 135.9(3)"n" as follows:

n. A Tier 1 site assessment in accordance with the department's Tier 1 guidance. The Tier 1 report shall be submitted on forms and in a format prescribed by this guidance. The Tier 1 data analysis shall be performed by using computer software developed by the department or by using the computer software's hard-copy version.

ITEM 113. Amend paragraph 135.9(7)"e" as follows:

e. Soil gas samples. To establish that the soil gas measurement is representative of the highest expected levels, a groundwater professional must obtain two soil gas samples taken at least two weeks apart. One of the samples must be taken below the typical frostline depth during a seasonal period of lowest groundwater elevation.

One of the samples should be collected beneath the frost line depth during a seasonal period of lowest groundwater elevation.

ITEM 114. Amend paragraph 135.9(7)"h" as follows:

h. Soil excavation. Excavation of contaminated soils for the purpose of removing soils contaminated above the Tier 1 levels is permissible as an alternative to conducting a Tier 2 assessment. Adequate field screening methods must be used to identify maximum concentrations during excavation. At a minimum, one soil sample must be taken for field screening every 100 square feet of the base and each sidewall. Soil samples must be taken for laboratory analysis at least every 400 square feet of the base and each sidewall of the excavated area to confirm that remaining concentrations are below Tier 1 levels. If the base or a sidewall of the excavation is less than 400 square feet, a minimum of one sample must be analyzed for each sidewall and the base.

ITEM 115. Rescind and reserve paragraph 135.9(11)"g."

ITEM 116. Amend paragraph 135.10(1)"a" as follows:

a. Guidance. The Tier 2 site assessment shall be conducted in accordance with the department's "Tier 2 Site Assessment Guidance" and these rules. The site cleanup report shall be submitted on forms and in a format prescribed by this guidance. The Tier 2 data analysis shall be performed by using computer software or online application developed by the department or by using the computer software's hard-copy version.

ITEM 117. Rescind subparagraph 135.10(2)"f"(3).

ITEM 118. Amend paragraphs 135.10(2)"g" and "h" as follows:

- g. Modeled simulation line. The simulation line represents the predicted maximum extent of groundwater contamination and distribution of contaminant concentrations between the source(s) and actual or potential receptor locations. The model calculates the simulation line using maximum concentrations at the source(s) and predicting the amount of dispersion and degradation. Modeled data in the simulation line are compared with actual field data contaminant concentrations to verify the predictive validity of the model and to make risk classification decisions.
- h. Modeled site-specific target level (SSTL) line. The modeled SSTL line represents acceptable levels of contaminant concentrations at points between and including the source(s) and an applicable point(s) of exposure or other point(s) of compliance (ex. a potential receptor point of exposure). The SSTL line is calculated by assuming an applicable target level concentration at the point(s) of exposure or point(s) of compliance and modeling back to the source to determine the maximum concentrations at the source (SSTL) that must be achieved to meet the target level at the point of exposure or compliance. Comparison of field data contaminant concentrations from actual samples to this SSTL line is used to determine a risk classification and determine appropriate corrective action response.

ITEM 119. Rescind paragraph 135.10(2)"m."

ITEM 120. Amend subparagraphs 135.10(3)"a"(2) and (3) as follows:

- (2) Granular bedrock. Granular bedrock is bedrock which is determined to act as a granular aquifer and for which monitoring wells do not exist at the source as of August 15, 1996. For purposes of this rule, a granular aquifer is one that shows no extraordinary variations or inconsistencies in groundwater elevations across the site, groundwater flow, hydraulic conductivities, or total dissolved solid concentrations among monitoring wells. Although the extent of contamination can be defined in granular bedrock, groundwater transport modeling cannot be used because there are no monitoring wells shall not be installed at the source if soil contamination is present. If soil contamination above a Tier 1 level is not identified or an overexcavation of contaminated soil has successfully removed all soil contamination greater than a Tier 1 level, then monitoring wells can be installed in the source area and the site can be evaluated as exempt granular bedrock.
- (3) Exempt granular bedrock. Exempt granular bedrock is bedrock which is determined to act as a granular aquifer as provided in subparagraph (2) and for which monitoring wells exist at the source as of August 15, 1996. Sites in exempt granular bedrock shall be evaluated using the normal regular Tier 1 or and Tier 2 procedures in this rule. Nongranular bedrock is not exempt from this subrule even if groundwater monitoring wells exist at the source.

NOTE: Nongranular bedrock is subject to special bedrock assessment procedures even if groundwater monitoring wells exist at the source, because the flow is not predictable by the Tier 2 model.

ITEM 121. Amend paragraph 135.10(3)"b" as follows:

b. Exempt soil pathways. The soil vapor to enclosed space pathway and the soil to plastie water lines pathway shall be assessed under the normal regular Tier 2 procedures in subrules 135.10(7) and 135.10(9) respectively. In all cases, the normal assessment must comply with the policy of avoiding a preferential pathway to groundwater consistent with subrule 135.8(5) and this subrule.

ITEM 122. Amend subparagraph 135.10(3)"g"(2) as follows:

(2) Groundwater well receptor evaluation for granular and nongranular bedrock designations. All drinking and non-drinking water wells within 1,000 feet of the source must be identified and tested for chemicals of concern. All public water supply systems within one mile of the source must be identified and raw water tested for chemicals of concern. If no drinking water wells are located within 1,000 feet of the source, all the All area within 1,000 feet of the source is considered a potential receptor point of exposure.

ITEM 123. Amend subparagraph 135.10(3)"i"(2) as follows:

(2) High risk classification. A site designated as granular or nongranular bedrock shall be classified high risk for this pathway if the highest groundwater elevation is higher than within three feet below of the bottom of a water line as provided in subparagraph 135.10(8) "a"(1), risk classification cannot be determined as provided in rule 567—135.12(455B) due to limitations on placement of monitoring wells, and water lines exist within 200 feet of a monitoring well which exceeds the Tier 1 level.

ITEM 124. Amend subparagraph 135.10(3)"j"(1) as follows:

(1) Point of compliance. The monitoring well closest to the surface water body must be used as the point of compliance to evaluate impacts to designated use segments as described in <u>subrule</u> 135.10(10) and for general use segments that fail the visual inspection criteria of <u>paragraph</u> 135.10(10) "b." If the surface water criteria is <u>are</u> exceeded for a designated use segment, an allowable discharge concentration must be calculated and met at the point of compliance. For general use segments failing the visual inspection criteria, the acutely toxic target level must be met at the point of compliance.

ITEM 125. Amend subparagraphs 135.10(3)"k"(1) and (2) as follows:

(1) Groundwater ingestion pathway. For high risk sites, where soil exceeds the soil leaching to groundwater Tier 1 level for actual receptors, soil excavation or other active remediation of soils must be conducted in accordance with department guidance to reduce soil concentrations to below the soil leaching Tier 1 level. Corrective action other than monitoring of groundwater is required at sites designated as nongranular bedrock if the actual receptor has been or is likely to be impacted. Corrective action other than monitoring of groundwater is required at sites designated as granular bedrock if the actual receptor has been impacted or the sentry well required by subparagraph 135.10(3) "g"(4) has been impacted above Tier 1 levels. Acceptable corrective action for impacted or vulnerable groundwater wells may include active remediation, technological controls,

institutional controls, well plugging, relocation, and well reinstallation with construction measures sufficient to prevent contaminant infiltration to the well and to prevent formation of a preferential pathway.

(2) Groundwater ingestion pathway high risk monitoring. For high risk sites designated as nongranular or granular bedrock, if the soil concentrations do not exceed the soil leaching to groundwater Tier 1 levels or have been reduced to this level by corrective action, and corrective action of groundwater is not required as in subparagraph 135.10(3) "k" (1), these sites shall be subject to groundwater monitoring as provided in paragraph 135.10(3) "l." Corrective action other than monitoring of groundwater is required at sites designated as granular bedrock if groundwater concentrations exceed the applicable target level less than 200 feet from an actual receptor. Reevaluation of the potential for impact to actual receptors is required at sites designated as nongranular bedrock if concentrations from monitoring wells increases increase more than 20 percent of the previous samples.

ITEM 126. Amend subparagraphs 135.10(3)"m"(1) and (2) as follows:

- (1) Groundwater in nongranular bedrock designations. Exit monitoring requires that samples from all groundwater monitoring wells must not exceed the applicable target levels for annual sampling for three consecutive years. If soil contamination above a Tier 1 level is not identified or if an overexcavation has successfully removed all soil contamination greater than a Tier 1 level and monitoring wells are installed in the source area, exit monitoring criteria are met when two consecutive samples collected at least six months apart from all monitoring wells show concentrations less than the lowest target level.
- (2) Groundwater in granular bedrock designations. Exit monitoring must be met in two ways: A monitoring well between the source and the receptor must not exceed applicable target levels for three sampling events, and samples must be separated by at least six months; and the three most recent consecutive groundwater samples from a monitoring well between the source and the receptor with detected levels of contamination must show a steady or declining trend and meet the following criteria: The first of the three samples must be more greater than detection limits, concentrations cannot increase more than 20 percent from the first of the three samples to the third sample; concentrations cannot increase more than 20 percent of from the previous sample; and samples must be separated by collected at least six months apart.

ITEM 127. Amend paragraph 135.10(4)"j" as follows:

j. Use of institutional controls. The use of institutional Institutional controls may be used to obtain no action required pathway classification. If the pathway is complete and the concentrations exceed the applicable Tier 1 level(s) for actual receptors, the drinking or non-drinking water well must be properly plugged in accordance with 567—Chapters 39 and 49 and the institutional control must prohibit the use of a protected groundwater source (if one exists) within the actual or modeled plume as provided in paragraphs 135.10(2) "j" and 135.10(2) "k." If the Tier 1 level is exceeded for potential receptors, the institutional control must prohibit the use of a protected groundwater source within the actual or modeled plume, whichever is greater. If concentrations exceed the Tier 1 level for drinking water wells and the groundwater is a protected groundwater source, the owner or operator must provide notification of the site conditions on a department form to the department water supply section, or if a county has delegated authority, then the designated county authority responsible for issuing private water supply construction permits or regulating non-public water well construction as provided in 567—Chapters 38 and 49.

ITEM 128. Amend paragraph 135.10(6)"g," introductory paragraph, as follows:

g. Pathway evaluation and classification. Upon completion of analysis evaluation of field data analytical results of appropriate samples and modeled data, the pathway must be classified high risk, low risk or no further action as provided in <u>rule</u> 567—135.12(455B).

ITEM 129. Amend paragraph 135.10(8)"d" as follows:

d. Pathway <u>evaluation and classification</u>. Upon completion of <u>analysis evaluation</u> of <u>field data analytical results of appropriate samples</u> and modeled data, the pathway must be classified high risk, low risk or no further action as provided in <u>rule</u> 567—135.12(455B). The water quality inside the water lines is not a criterion for clearance of this pathway.

ITEM 130. Amend paragraph 135.10(9)"d" as follows:

d. Pathway classification. Upon completion of analysis evaluation of field data analytical results of

<u>appropriate samples</u>, the pathway must be classified high risk, low risk or no further action as provided in <u>rule</u> 567—135.12(455B). Measurements of water quality inside the water lines may be required, but are not allowed as criteria to clear this pathway.

ITEM 131. Amend paragraph 135.10(10)"e" as follows:

- e. Target levels. Determining target levels for this pathway involves a two-step process.
- (1) Groundwater modeling as provided in <u>subrule</u>135.10(2) must be used to calculate the projected concentrations of chemicals of concern at the point of compliance. If the modeled concentrations or field data at the point of compliance exceed surface water criteria for designated use segments, an allowable discharge concentration must be calculated. If the projected concentrations and <u>field data actual concentrations</u> at the point of compliance do not exceed surface water criteria, no further action is required to assess this pathway.
- (2) The department water quality section will calculate the allowable discharge concentration using information provided by the certified groundwater professional on a department form. Required information includes, at a minimum, the site location and a discharge flow rate calculated according to the department's Tier 2 guidance. The allowable discharge concentration is the target level which must be met adjacent to the surface water body which is the point of compliance.
- (3) The target level at the point of exposure/compliance for general use segments subject to evaluation is the acutely toxic levels established by the department under 567—Chapter 61 and subrule 567—subrule 62.8(2). If the modeled concentrations of field data contaminant concentrations at the point of exposure/compliance exceed the acutely toxic levels, modeling must be used to determine site classifications and corrective action in accordance with rule 567—135.12(455B).

ITEM 132. Amend paragraph 135.10(10)"f" as follows:

- f. Pathway <u>evaluation and classification</u>. Upon completion of <u>analysis of field data</u> <u>evaluation of analytical</u> <u>results of appropriate samples</u> and modeled data, the pathway must be classified high risk, low risk or no further action as provided in <u>rule</u> 567—135.12(455B).
- (1) For general use segments, as defined in 567—subrule 61.3(1), if the groundwater professional determines there is no sheen or residue present or if the site is not the source of the sheen or residue or if the sheen does not consist of petroleum-regulated substances, no further action is required for assessment of this pathway. If a petroleum-regulated substance sheen is present, the pathway is high risk and subject to classification in accordance with rule 567—135.12(455B).
- (2) For designated use segments, as provided in 567—subrules 61.3(1) and 61.3(5), if projected concentrations of chemicals of concern and field data actual contaminant concentrations at the point of compliance do not exceed the target level adjacent to the surface water, and the groundwater professional determines there is no sheen or residue present, no further action is required for assessment of this pathway.
 - ITEM 133. Rescind paragraph 135.10(11)"f."
 - ITEM 134. Reletter paragraphs 135.10(11)"g" and "h" as 135.10(11)"f" and "g."
 - ITEM 135. Amend subrule 135.12(1) as follows:
- 135.12(1) General. 1995 Iowa Code section 455B.474(1) "d"(2) provides that sites shall be classified as high risk, low risk and no action required. Risk classification is accomplished by comparing actual field data contaminant concentrations to the concentrations that are predicted by the use of models. Field data Concentrations must be compared to the simulation model which uses the maximum concentrations at a source and predicts at what levels actual or potential receptors could be impacted in the future. Field data Concentrations must also be compared to the site-specific target level line which assumes a target level concentration at the point of exposure and is used to predict the reduction in concentration that must be achieved at the source in order to meet the applicable target level at the point of exposure. These models not only predict concentrations at points of exposure or a point of compliance at a source but also predict a distribution of concentrations between the source and the point of exposure which may also be points of compliance. The comparison of field data contaminant concentrations with these distribution curves primarily is considered for purposes of judging whether the modeled data is reasonably predictive and what measures such as monitoring are prudent to determine the reliability of modeled data and actual field data contaminant concentrations.

For the soil vapor to enclosed space and soil to water line pathways, there are no horizontal transport models to

use for predicting future impacts. Therefore, for these pathways, sites are classified as high risk, low risk or no action required based on specified criteria below and in <u>rule</u> 567—135.10(455B).

ITEM 136. Amend subrule 135.12(2), introductory paragraph, as follows:

135.12(2) *High risk classification.* Except as provided below, sites shall be classified as high risk if, for any pathway, any actual field data exceeds contaminant concentrations exceed the site-specific target level line at any point for an actual receptor.

ITEM 137. Amend paragraphs 135.12(3)"a" and "b" as follows:

- a. Objectives. The primary objectives of corrective action in response to a high risk classification are both short-term short-term and long-term. The short-term goal is to eliminate or reduce the risk of exposure at actual receptors which have been or are imminently threatened with exposure above target levels. The longer term goal is to prevent exposure to actual receptors which are not currently impacted or are not imminently threatened with exposure. To achieve these objectives, it is the intent of these rules that concentrations of applicable chemicals of concern be reduced by active remediation to levels below the site-specific target level line at all points between the source(s) and the point(s) of exposure as well as to undertake such interim corrective action as necessary to eliminate or prevent exposure until concentrations below the SSTL line are achieved. If it is shown that concentrations at all applicable points have been reduced to below the SSTL line, the secondary objective is to establish that the field data actual chemical concentrations can be reasonably relied upon to predict future conditions at points of exposure rather than reliance on the modeled data. Reliance on field data actual contaminant concentrations is achieved by establishing through monitoring that concentrations within the contaminant plume are steady or declining. Use of institutional control Institutional controls and technological controls may be used to sever pathways or control the risk of receptor impacts.
- b. For the groundwater to water line and soil to water line receptors, these objectives are achieved by active remediation, replacement or relocation of high risk water line receptors from areas within the actual plume plus some added site specific distance to provide a safety factor to areas outside the site specific target level line. In areas of free product, all water lines regardless of construction material must be relocated unless there is no other option and the department has approved an alternate plan of construction in the actual and modeled plume areas. If water lines and gaskets are replaced in an area of contamination, they must be replaced with water line materials and gasket materials of appropriate construction in accordance with current department standards set forth in 567—Chapter 43 and with no less than nitrile or FKM gaskets or as otherwise approved by the department. If a service line is replaced and remains in a contaminated area, a backflow preventer shall be installed to prevent impacts to the larger water distribution system.

ITEM 138. Reletter paragraphs 135.12(3)"c" to "i" as 135.12(3)"d" to "j."

ITEM 139. Adopt the following new paragraph 135.12(3)"c":

c. In areas of free product, all water lines, regardless of construction material, must be relocated unless there is no other option and the department has approved an alternate plan of construction. Refer to subparagraph 135.7(5)"d"(11). If a service line remains in the area of LNAPL, a backflow preventer shall be installed to prevent impacts to the larger water distribution system.

ITEM 140. Amend subrule 135.12(4) as follows:

- **135.12(4)** Low risk classification. A site shall be classified as low risk if none of the pathways are high risk and if any of the pathways are low risk. A pathway shall be classified low risk if it meets one of the following conditions:
- a. For actual and potential receptors, if the modeled data and the actual field data concentrations are less than the site-specific target level line, and any of the field data is actual concentrations are greater than the simulation line.
- b. For potential receptors, if any actual field data exceeds concentrations exceed the site-specific target level line at any point.
- c. For the soil leaching to groundwater ingestion pathway where modeling predicts that the Tier 1 levels for potential receptors would be exceeded in groundwater at applicable potential receptor points of compliance and the soil concentration exceeds the soil leaching to groundwater site-specific target level but groundwater concentrations are currently below the Tier 1 level for potential receptors, the site shall be initially classified as

low risk and subject to monitoring under <u>subparagraph</u> 135.12(5) "d"(2). If at any time during the three-year monitoring period, groundwater concentrations exceed the Tier 1 level for potential receptors, the site shall be classified as high risk requiring soil remediation in accordance with 135.12(3) "e." paragraph 135.12(3) "d."

ITEM 141. Amend paragraphs 135.12(6)"b" to "e" as follows:

- b. For initial classification, groundwater pathways shall be classified as no action required if the field data is contaminant concentrations are below the site-specific target level line and all field data is concentrations are at or less than the simulation line, and confirmation monitoring has been completed successfully. Confirmation sampling for groundwater is a second sample which confirms the no action required criteria.
- c. A groundwater pathway shall be reclassified from high risk to no action required if all field data is contaminant concentrations are below the site-specific target level and if exit monitoring criteria have been met. Exit monitoring criteria means that the three most recent consecutive groundwater samples from all monitoring wells must show a steady or declining trend and the most recent samples are below the site-specific target level. Other criteria include the following: The first of the three samples for the source well and transition well must be more than detection limits; concentrations cannot increase more than 20 percent from the first of the three samples to the third sample; concentrations cannot increase more than 20 percent of the previous sample; and samples must be separated by at least six months.
- d. A low risk site shall be reclassified as "no action required" if field data is contaminant concentrations are below the site-specific target level and if exit monitoring criteria have been met pursuant to paragraph 135.12(6) "c" or if the site has maintained less than the applicable target level for four consecutive sampling events separated by at least six months as defined in the monitoring plan regardless of exit monitoring criteria and guidance.
- e. Confirmation sampling for soil gas and indoor vapor. For the enclosed space pathways, confirmation sampling is required to reasonably establish that the soil gas and indoor vapor samples represent the highest expected levels. A groundwater professional must obtain two samples taken at least two weeks apart. One of the samples must be taken during a seasonal period of lowest groundwater elevation and soil gas samples must be taken below the frost line One of the samples should be collected beneath the frost line depth during a seasonal period of lowest groundwater elevation.

ITEM 142. Amend paragraph 135.12(9)"d" as follows:

d. Review. A CADR submitted by a groundwater professional shall be accepted by the department and shall be primarily relied upon by the department to determine the corrective action response requirements of the site. However, if within 90 days of receipt of a CADR, the department identifies material information in the CADR that is inaccurate or incomplete, and if based upon information in the report the appropriate corrective action response cannot be reasonably determined by the department based on industry standards, the department may reject the report and require modifications. If the department does not reject the report within 90 days of receipt, the report shall be deemed approved as submitted unless changes to the report are requested by the groundwater professional. The department shall work with the groundwater professional and the owner or operator to correct any materially inaccurate information or to obtain the additional information necessary to determine the appropriate corrective action response as soon as practicable. However, from July 1, 2010, through June 30, 2011, the department shall have 120 days to notify the certified groundwater professional when a report is not accepted based on material information that is found to be inaccurate or incomplete.

ITEM 143. Amend paragraph 135.12(10)"b," introductory paragraph, as follows:

b. No further action certificate. When the no action required site classification has been determined based on a recommendation of the certified groundwater professional as provided in <u>subrules</u> 135.9(11), 135.10(11) and 135.12(12) 135.12(6) (see also 2009 Iowa Code Supplement section 455B.474(1)"h"(1) and (3) as amended by 2010 Iowa Aets, House File 2531, section 174 455B.474(1)"a"(8)(a) and (c)), the department shall issue a no further action certificate.

ITEM 144. Amend subparagraph 135.12(10)"b"(9) as follows:

(9) The owner or operator or other persons conducting corrective action shall be responsible for recording the no further action certificate with the county recorder and return a file-stamped copy to the department within 30 days of the issue date. At its discretion, the department may record the no further action certificate with the

appropriate county recorder as authorized in 2009 Iowa Code Supplement section 455B.474(1)"h"(3) as amended by 2010 Iowa Acts, House File 2531, section 174 455B.474(1) "a" (8)(c).

ITEM 145. Amend subrule 135.12(11) as follows:

135.12(11) Expedited corrective action. An owner, operator or responsible party of a site at which a release of regulated substance is suspected to have occurred may carry out corrective actions at the site so long as the department receives notice of the expedited cleanup activities within prior to 30 calendar days of their commencement; the owner, operator, or responsible party complies with the provisions of these rules; and the corrective action does not include active treatment of groundwater other than:

- a. As previously approved by the department; or
- b. Free product recovery pursuant to subrule 135.7(5).
- c. Soil exeavation overexcavation. When undertaking exeavation overexcavation of contaminated soils, adequate field screening methods must be used to identify maximum concentrations during excavation. At a minimum one soil sample must be taken for field screening every 100 square feet of the base and each sidewall. Soil samples must be taken for laboratory analysis at least every 400 square feet of the base and each sidewall of the excavated area to confirm remaining concentrations are below Tier 1 levels. If the excavation is less than 400 square feet, a minimum of one sample must be analyzed for each sidewall and the base. The owner or operator must maintain adequate records of the excavation area to document compliance with this procedure unless submitted to the department and must provide it to the department upon request.

ITEM 146. Amend rule 567—135.14(455B) as follows:

567—135.14(455B) Action levels. The following corrective action levels apply to petroleum-regulated substances as regulated by this chapter. These action levels shall be used to determine if further corrective action under rules 567—135.6(455B) through 567—135.12(455B) or rule 567—135.15(455B) is required as the result of tank closure sampling under subrule 135.15(3) or other analytical results submitted to the department. The contaminant concentrations must be determined by laboratory analysis as stated in <u>rule</u>567—135.16(455B). Final cleanup determination is not limited to these contaminants. The contamination corrective action levels are:

	Soil (mg/kg)	Groundwater (ug/L)
Benzene	0.54	5
Toluene	3.2	1,000
Ethylbenzene	15	700
Xylenes	52	10,000
Total Extractable Hydrocarbons <u>Diesel</u>	3,800	1,200
Total Extractable Hydrocarbons— Waste Oil		<u>400</u>

ITEM 147. Amend rule 567—135.15(455B), catchwords, as follows:

567—135.15(455B) Out-of-service UST systems, temporary closure, and permanent closure.

ITEM 148. Rescind subrule 135.15(1) and adopt the following **new** subrule in lieu thereof:

135.15(1) *Out-of-service UST systems and temporary closure.*

- a. UST systems not meeting either the performance standards in subrule 135.3(1) for new UST systems or the upgrading requirements in subrule 135.3(2) by December 22, 1998, must be permanently closed according to subrule 135.15(2). The tanks cannot be brought back into use.
- b. When a UST system in compliance with new tank standards is out of service for less than three months, owners and operators must:

- (1) Continue operation and maintenance of corrosion protection in accordance with subrule 135.4(2);
- (2) Continue operation and maintenance of any release detection in accordance with rule 567—135.5(455B) unless the system is empty. The UST system is empty when all materials have been removed using commonly employed practices. No more than 2.5 centimeters (1 inch) of residue, or 0.3 percent by weight of the total capacity of the UST system, may remain in the system;
 - (3) Comply with rules 567—135.6(455B) to 567—135.12(455B) if a release is suspected or confirmed;
- (4) Maintain financial responsibility (e.g., insurance) in accordance with 567—Chapter 136. If at any time financial responsibility coverage is or will be terminated, a site check for contamination must be completed before coverage is terminated. A site check must use the closure-in-place sampling procedures in paragraphs 135.15(3)"b" and "d" or the Tier 1 site assessment in rule 567—135.9(455B). If the tanks are located in a contaminated area with active monitoring and remediation, the tank owner may request the department waive the site check providing justification.
 - (5) Continue to pay the tank management fee as required in subrule 135.3(5).
 - (6) Continue to have compliance inspections conducted as required in rule 567—135.20(455B).
- c. When a UST system is out of service for three months or more, an owner must submit a notification of temporary closure form to the department. Owners and operators must complete the requirements in paragraph 135.15(1)"b" for temporary closure and certify the following:
 - (1) The UST system is empty of all regulated substances (e.g., receipt of product removal).
 - (2) Vent lines are open and functioning.
 - (3) All other piping, pumps, accesses, and ancillary equipment are capped and locked.
- (4) The corrosion protection system is being maintained in accordance with subrule 135.4(2). Include documentation that electricity is being maintained to operate the impressed current cathodic protection system if present.
 - (5) For lined tanks, provide a copy of the last internal inspection.
 - (6) Provide proof of financial responsibility (e.g., insurance) according to 567—Chapter 136.
- d. When a tank system is temporarily closed for more than 12 months, the owner must remain in compliance with the department's temporary closure requirements in paragraph 135.15(1) "c." The department may provide an extension to the 12-month temporary closure period. Owners and operators must complete a site check in accordance with paragraph 135.6(3) "b" before such an extension can be applied for.
- e. If a tank system is temporarily closed for more than 12 months, but the tank system has not been temporarily closed according to the requirements of paragraph 135.15(1) "c," or the owner or operator has failed to maintain out-of-service requirements in paragraph 135.15(1) "b," the UST system must be permanently closed in accordance with subrule 135.15(2).
- f. Prior to returning a temporarily closed tank back into service, the owner or operator must complete and submit the department's return-to-service form signed by a licensed installer and provide the following documentation. The tank system cannot be operated or receive fuel until current tank tags have been issued.
 - (1) Documentation that the tanks were temporarily closed in accordance with subrule 135.15(1).
- (2) Where applicable, documentation that corrosion protection has been maintained continuously in accordance with subrule 135.4(2). The owner or operator must provide an inspection log of the cathodic protection system and the inspection report of the cathodic protection system completed by an Iowa-licensed corrosion tester.
 - (3) For lined tanks, provide a lining and tank integrity inspection report.
- (4) Results of precision tightness tests (0.1 gph) conducted on tanks in accordance with rule 567—135.5(455B).
- (5) Results of precision tightness tests (0.1 gph) conducted on lines in accordance with rule 567—135.5(455B). This includes piping used for remote fill.
- (6) Function test (3.0 gph) results of mechanical or electronic leak detectors conducted in accordance with rule 567—135.5(455B).

NOTE: Function tests are not required on confirmed "safe suction" dispensing lines.

- (7) Tank and piping leak detection is operational and in good condition.
- (8) Secondary containment is installed where necessary in accordance with subrule 135.3(9).

- (9) Spill containment, overfill prevention and all containment sumps are in good condition and operating in accordance with subrule 135.4(1). Tightness tests conducted within the last 12 months must be provided for secondary containment of tanks, piping, sumps, under dispenser containment and spill containment.
- (10) Copy of the financial responsibility (e.g., UST insurance) mechanism in accordance with 567—Chapter 136.
- (11) Certification from an Iowa-licensed installer that the UST system and equipment are installed correctly, are in good operable condition and meet all regulatory requirements for startup and operation.
 - (12) Copies of Class A and Class B operator training certificates.
 - (13) Change of ownership form (if the UST facility was sold).

ITEM 149. Amend subrule 135.15(2) as follows:

- 135.15(2) Permanent closure and changes-in-service. Permanent closure of an underground storage tank system must be conducted by an Iowa-licensed tank remover. Closure sampling must be conducted by or under the supervision of an Iowa-certified groundwater professional.
 - a. No change.
- b. To permanently close a tank or piping, owners and operators must empty and clean them by removing all liquids and accumulated sludge. All tanks taken out of service permanently must also be either removed from the ground, or filled with an inert solid material, or closed in place by a method approved by the department. Piping must either be removed from the ground or have the ends plugged with an inert solid material.

When permanently closing a tank by filling with inert solid material, the tank may not be filled until a closure report is approved by the department. The tank must be filled within 30 days after department approval. The owner and operator must notify the department within 15 days after filling the tank with inert solid material.

- c. No change.
- d. Permanent closure procedures must be followed in the replacement of tanks or piping. Notification must be made using DNR Form 542-1308, "Notification of Tank Closure or Change-in-Service." The form must include the date scheduled for the closure. Oral confirmation of the closure date must be given to the DNR field office 24 hours prior to the actual closure. The required assessment of the excavation zone under 139.15(3) subrule 135.15(3) must be performed after notifying the department but before completion of the permanent closure or change-in-service.

NOTE: The following cleaning and closure procedures may be used to comply with subrule 135.15(2): American Petroleum Institute Recommended Practice 1604, "Removal and Disposal of Used Underground Petroleum Storage Tanks"; American Petroleum Institute Publication 2015, "Cleaning Petroleum Storage Tanks"; American Petroleum Institute Recommended Practice 1631, "Interior Lining of Underground Storage Tanks," may be used as guidance for compliance with this subrule; and the National Institute for Occupational Safety and Health "Criteria for a Recommended Standard... Working in Confined Space" may be used as guidance for conducting safe closure procedures at some hazardous substance tanks.

- American Petroleum Institute Recommended Practice RP 1604, "Closure of Underground Petroleum Storage Tanks";
- American Petroleum Institute Standard 2015, "Safe Entry and Cleaning of Petroleum Storage Tanks, Planning and Managing Tank Entry From Decommissioning Through Recommissioning";
- American Petroleum Institute Recommended Practice 2016, "Guidelines and Procedures for Entering and Cleaning Petroleum Storage Tanks";
- American Petroleum Institute Recommended Practice RP 1631, "Interior Lining and Periodic Inspection of Underground Storage Tanks," may be used as guidance for compliance with this subrule;
- National Fire Protection Association Standard 326, "Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair"; and
- National Institute for Occupational Safety and Health Publication 80-106, "Criteria for a Recommended Standard...Working in Confined Space" may be used as guidance for conducting safe closure procedures at some hazardous substance tanks.

ITEM 150. Amend subrule 135.15(3) as follows:

- **135.15(3)** Assessing the site at closure or change-in-service.
- a. Before permanent closure or a change-in-service is completed, owners or operators must measure for

the presence of a release where contamination is most likely to be present at the UST site. This soil and groundwater closure investigation must be conducted or supervised by a groundwater professional certified under 567—Chapter 134, Part A, unless the department in its discretion grants an exemption and provides direct supervision of the closure investigation. In selecting the sample types, sample locations, and measurement methods, owners and operators must consider the method of closure, the nature of the stored substance, the type of backfill, the depth to groundwater, and other factors appropriate for identifying the presence of a release.

At UST sites with a history of petroleum storage, soil and groundwater samples shall in every case be analyzed for benzene, toluene, ethylbenzene, and xylenes (BTEX) with each compound reported separately in accordance with <u>rule</u> 567—135.16(455B). If there has been a history or suspected history of petroleum storage other than gasoline or gasoline blends (i.e., all grades of diesel fuels, fuel oil, kerosene, oil and mineral spirits), or such storage history is unknown or uncertain, soil and groundwater samples shall also be analyzed for total extractable hydrocarbons in accordance with <u>rule</u> 567—135.16(455B).

All such samples shall be collected separately and shipped to a laboratory certified under 567—Chapter 42, Part C, 567—Chapter 83 within 72 hours of collection. Samples shall be refrigerated and protected from freezing during shipment to the laboratory.

When a UST is removed from an area of confirmed contamination, the department may waive closure sampling if written documentation is submitted with the closure notification. Documentation should include laboratory analytical reports and a site map showing tank and piping locations along with contamination plume and sampling locations.

b. For all permanent tank and piping closures or changes-in-service, at least one water sample must be taken from the first saturated groundwater zone via a <u>developed</u> monitoring well or borehole except as provided in paragraph "g."The well or borehole must be located downgradient from and as close as possible to the <u>excavation UST system</u> but no farther away than 20 feet <u>from system components</u>. At some tank and piping closures, a minimum of one monitoring well may not be sufficient to represent a release where it is most likely to be present. An additional groundwater monitoring well or wells may be necessary.

If, however, the first saturated groundwater zone is not encountered within 10 feet below the lowest elevation of the tank excavation, the requirement for groundwater sampling shall not apply unless:

- (1) and (2) No change.
- c. For permanent closure by tank removal, the departmental guidance document entitled "Underground Storage Tank Closure Procedures for Tank and Piping Removal Guidance" must be followed. The minimum number of soil samples that must be taken depends on the tank size and length of product piping. Samples must be taken at a depth of 1 to 2 feet beneath the tank fill area below the base of the tank along the tank's centerline. Soil samples must also be taken at least every 10 feet along the product piping at a depth of 1 to 2 feet beneath the piping fill area below the piping, unless alternate sampling is approved by the department.

If sands or other highly permeable soils are encountered, alternative sampling methods may be required.

If contamination is suspected or found in any area within the excavation (i.e., sidewall or bottom), a soil sample must be taken at that location.

The numbers of samples required for tanks are as follows:

Nominal Tank Capacity (gallons)	Number of Samples	Location on Centerline
1,000 or less	1	center of tank
1,001 - 8,000	2	1/3 from ends
8,001 - 30,000	3	5 feet from ends and at center of tank
30,001 - 40,000	4	5 and 15 feet from ends
40,001 and more	5	5 and 15 feet from ends and at center of tank

d. For closing a tank in place by filling with an inert solid material or for a change-in-service, the departmental guidance document entitled "Underground Storage Tank Closure for Filling in Place" must be

followed. The minimum number of soil borings required for sampling depends on the size of the tank and the length of the product piping. Soil samples must be taken within 5 feet of the sides and ends of the tank at a depth of 2 to 4 feet below the base of the tank, but outside the backfill material, at equal intervals around the tank. Soil samples must also be taken at least every 10 feet along the product piping at a depth of 1 to 2 feet beneath the piping fill area below the piping, unless alternate sampling is approved by the department. If sands or other highly permeable soils are encountered, alternative sampling methods may be required.

The minimum numbers of soil	borings and sample	es required are as follows:

Nominal Tank Capacity (gallons)	Number of Samples	Location of Samples
6,000 or less	4	1 each end and each side
6,001 - 12,000	6	1 each end and 2 each side
12,001 or more	8	1 each end and 3 each side

e. A closure report in a format prescribed by the department must be submitted to the department within 45 days of the tank removal or sampling for a closure in place. The report must include all laboratory analytical reports, soil boring and well or borehole construction details and stratigraphic logs, and a dimensional drawing showing location and depth of all tanks, piping, sampling, and wells or boreholes, and contaminated soil encountered. Refer to the Underground Storage Tank Closure Guidance for reporting format. The tank tags must be returned with the closure report.

f. and g. No change.

ITEM 151. Amend subrule 135.15(7) as follows:

135.15(7) Applicability to pre-1974 USTs. The closure provisions of rule 567—135.15(455B) are not applicable to USTs which have been out of operation as of prior to January 1, 1974. For purposes of this subrule, out of operation means that no regulated substance has been deposited into or dispensed from the tanks and that the tanks do not currently contain an accumulation of regulated substances other than a de minimus minimis amount as provided in paragraph 135.15(1) "a."

Owners and operators or other interested parties are not required to submit documentation that USTs meet the exemption conditions and may rely on this subrule as guidance. However, should a question arise as to whether USTs meet the exemption, or owners and operators or other interested parties request acknowledgment by the department that USTs are exempt, they must submit an affidavit on a form provided by the department. The affiant must certify that based on a reasonable investigation and to the best of the affiant's knowledge, the USTs were taken out of operation prior to January 1, 1974, the USTs have not contained a regulated substance since January 1, 1974, and the USTs do not currently contain an accumulation of regulated substances.

If the department has a reasonable basis to suspect a release has occurred, the release investigation and confirmation steps of subrule 135.8(1) rule 567—135.6(455B) and the corrective action requirements as provided in rules 567—135.7(455B) to 567—135.8(455B) through 567—135.12(455B) shall apply.

ITEM 152. Amend rule 567—135.16(455B) as follows:

567—135.16(455B) Laboratory analytical methods for petroleum contamination of soil and water.

135.16(1) General. When having soil or water analyzed analyzing for petroleum or hazardous substances, owners and operators of UST systems must use a laboratory certified under 567—Chapter 83. In addition they must ensure that all soil and groundwater samples are properly preserved and shipped within 72 hours of collection to a laboratory certified under 567—Chapter 83, for UST petroleum analyses. This rule provides acceptable analytical procedures for petroleum substances and required information that must be provided in all laboratory reports.

135.16(2) No change.

135.16(3) Analysis of soil and water for high volatile petroleum compounds (i.e., gasoline, benzene,

ethylbenzene, toluene, xylene). Sample preparation and analysis shall be by Method OA-1, "Method for Determination of Volatile Petroleum Hydrocarbons (gasoline)," revision 7/27/93, University Hygienic Laboratory, Iowa City, Iowa. This method is based on U.S. EPA methods 5030, 8000, and 8015, SW-846, "Test Methods for Evaluating Solid Waste," 3rd Edition. 12/01/2019, state hygienic laboratory at the University of Iowa, or EPA Method 8260D, "Test Methods for Evaluating Solid Waste," 3rd Edition—Update 6, July 2018. Copies of Method OA-1 are available from the department.

- 135.16(4) Analysis of soil and water for low volatile petroleum hydrocarbon contamination (i.e., all grades of diesel fuel, fuel oil, kerosene, oil, and mineral spirits). Sample preparation and analysis shall be by Method OA-2, "Determination of Extractable Petroleum Products (and Related Low Volatility Organic Compounds)," revision 7/27/93, University Hygienic Laboratory, Iowa City, Iowa. This method is based on U.S. EPA methods 3500, 3510, 3520, 3540, 3550, 8000, and 8100, SW-846, "Test Methods for Evaluating Solid Waste," 3rd Edition. 12/01/2019, state hygienic laboratory at the University of Iowa. Copies of Method OA-2 are available from the department.
- 135.16(5) Analysis of soil gas for volatile petroleum hydrocarbons. Analysis of soil gas for volatile petroleum hydrocarbons shall be conducted in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 1501, Issue 3, March 15, 2003, or a department-approved equivalent method.
- <u>135.16(6)</u> Analytical methods for methyl tertiary-butyl ether (MTBE). Analysis of water for MTBE must be conducted by a laboratory certified under 567—Chapter 83 for petroleum analyses.
- <u>a. Sample preparation and analysis shall be by U.S. Environmental Protection Agency Method 8260D, "Test Methods for Evaluating Solid Waste," 3rd Edition–Update 6, July 2018.</u>
- <u>b.</u> Laboratories performing the analyses must run standards for MTBE on a routine basis, and standards for other possible compounds like ethyl tertiary-butyl ether (ETBE), tertiary-amyl methyl ether (TAME), disopropyl ether (DIPE), and tertiary-butyl alcohol (TBA) to be certain of their identification should they be detected.
- c. Laboratories must run a method detection limit study and an initial demonstration of capability for MTBE. These records must be kept on file.
 - d. The minimum detection level for MTBE in water is 15 ug/L.
 - ITEM 153. Amend subrule 135.17(2) as follows:
- 135.17(2) Individual claims. The financial ability of individual owners and operators of USTs, with or without an active business (including but not limited to sole proprietorships and general partnerships), shall may be evaluated using the "Individual Ability to Pay Guidance" document dated June 19, 1992, most current version of "INDIPAY" developed by the U.S. Environmental Protection Agency and generally accepted principles of financial analysis. This guidance is only one tool the department may use in evaluating claims of financial inability.
 - ITEM 154. Amend subrule 135.17(3) as follows:
- 135.17(3) Corporate claims. The financial ability of corporate owners and operators of USTs shall may be evaluated using the June 1992 most current version of "ABEL" developed by the U.S. Environmental Protection Agency and generally accepted principles of financial analysis. This guidance is only one tool the department may use in evaluating claims of financial inability.
 - ITEM 155. Rescind subrules 135.18(1) to 135.18(4).
 - ITEM 156. Renumber subrules 135.18(5) to 135.18(7) as 135.18(1) to 135.18(3).
 - ITEM 157. Amend rule 567—135.19(455B) as follows:

567—135.19(455B) Analyzing for methyl tertiary-butyl ether (MTBE) in soil and groundwater samples.

- 135.19(1) General. The objective of analyzing for MTBE is to determine its presence in soil and water samples collected as part of investigation and remediation of contamination at for underground storage tank facilities.
- 135.19(2) Required MTBE testing. Soil and water Water samples must be analyzed for MTBE when collected for risk-based corrective action as required in rules 567—135.8(455B) through 567—135.12(455B). These sampling requirements include but are not limited to ÷ Tier 2 and Tier 3 assessments where groundwater

ingestion pathway evaluation and subsequent monitoring is required.

- a. Risk-based corrective action (RBCA) evaluations required for Tier 1, Tier 2, and Tier 3 assessments and corrective action design reports.
 - b. Site monitoring.
 - c. Site remediation monitoring.
- 135.19(3) MTBE testing not required. Soil and water samples Analysis for MTBE is not required for the following actions are not required to be analyzed for MTBE:
 - a. Closure sampling under rule 567—135.15(455B) unless Tier 1 or Tier 2 sampling is being performed.
 - b. Site checks under subrule 135.7(3) unless Tier 1 or Tier 2 sampling is being performed 135.6(3).
 - c. If prior analysis at a site under subrule 135.19(2) has not shown MTBE present in soil or groundwater.
 - d. If the department determines MTBE analysis is no longer needed at a site.
 - **135.19(4)** Reporting. The analytical data must be submitted in a format prescribed by the department.
- 135.19(5) Analytical methods for methyl tertiary butyl ether (MTBE). When having soil or water analyzed for MTBE from contamination caused by petroleum or hazardous substances, owners and operators of UST systems must use a laboratory certified under 567—Chapter 83 for petroleum analyses. In addition, the owners and operators must ensure all soil and water samples are properly preserved and shipped within 72 hours of collection to a laboratory certified under 567—Chapter 83 for petroleum analyses.
 - a. Sample preparation and analysis shall be by:
- (1) GC/MS version of OA-1, "Method for Determination of Volatile Petroleum Hydrocarbons (gasoline)," revision 7/27/93, University Hygienic Laboratory, Iowa City, Iowa; or
- (2) U.S. Environmental Protection Agency Method 8260B, SW-846, "Test Methods for Evaluating Solid Waste," Third Edition.
- b. Laboratories performing the analyses must run standards for MTBE on a routine basis, and standards for other possible compounds like ethyl tertiary-butyl ether (ETBE), tertiary-amyl methyl ether (TAME), disopropyl ether (DIPE), and tertiary-butyl alcohol (TBA) to be certain of their identification should they be detected.
- c. Laboratories must run a method detection limit study and an initial demonstration of capability for MTBE. These records must be kept on file.
- d. The minimum detection level for MTBE in soil is 15 ug/kg. The minimum detection level for MTBE in water is 15 ug/l.

ITEM 158. Amend subrule 135.20(1) as follows:

135.20(1) The owner or operator must have the UST system inspected and an inspection report submitted to the department by a UST compliance inspector certified by the department under 567—Chapter 134, Part B. An initial compliance site inspection shall be conducted no later than December 31, 2007 within two years after new tank installation. All subsequent compliance site inspections conducted after the initial compliance site inspection for the 2008-2009 biennial period shall be conducted within 24 months of the prior compliance site inspection. Compliance site inspections must be separated by at least six months.

ITEM 159. Adopt the following **new** rule 567—135.21:

567—135.21(455B) UST systems with field-constructed tanks and airport hydrant fuel distribution systems.

135.21(1) General requirements.

- *a*. Implementation of requirements. Owners and operators must comply with the requirements of this rule for UST systems with field-constructed tanks and airport hydrant systems as follows:
- (1) For UST systems installed on or before [the effective date of this rule], the requirements are effective according to the following schedule:

Requirement	Effective Date
Upgrading UST systems, general operating requirements, and operator training	October 13, 2021

Release detection	October 13, 2021
Release reporting, response, and investigation; closure; financial responsibility and notification (except as provided in paragraph 135.21(1)"b")	[the effective date of this rule]

- (2) For UST systems installed after [the effective date of this rule], the requirements apply at installation.
- b. All owners of previously deferred UST systems must submit a registration form provided by the department. Owners and operators of UST systems must demonstrate financial responsibility at the time of submission of the registration form.
- c. Except as provided in subrule 135.21(2), owners and operators must comply with the requirements of rules 567—135.1(455B) through 567—135.20(455B) and 567—Chapter 136.
- d. In addition to the codes of practice listed in subrule 135.3(1), owners and operators may use military construction criteria, such as Unified Facilities Criteria (UFC) 3-460-01, Petroleum Fuel Facilities, when designing, constructing, and installing airport hydrant systems and UST systems with field-constructed tanks.
- 135.21(2) Additions, exceptions, and alternatives for UST systems with field-constructed tanks and airport hydrant systems.
- a. Exception to piping secondary containment requirements. Owners and operators may use single-walled piping when installing or replacing piping associated with UST systems with field-constructed tanks greater than 50,000 gallons and piping associated with airport hydrant systems. Piping associated with UST systems with field-constructed tanks less than or equal to 50,000 gallons not part of an airport hydrant system must meet the secondary containment requirement when installed or replaced.
- b. Upgrade requirements. Not later than October 13, 2021, airport hydrant systems and UST systems with field-constructed tanks where installation commenced on or before [the effective date of this rule] must meet the following requirements or be permanently closed pursuant to rule 567—135.15(455B).
- (1) Corrosion protection. UST system components in contact with the ground that routinely contain regulated substances must meet one of the following:
- 1. Except as provided in paragraph 135.21(2) "a," the new UST system performance standards for tanks in paragraph 135.3(1) "a" and for piping in paragraph 135.3(1) "b"; or
- 2. Be constructed of metal and cathodically protected according to a code of practice developed by a nationally recognized association or independent testing laboratory, and meet the requirements of paragraphs 135.3(1) "a"(2)"3" and "4" for tanks, and subparagraphs 135.3(1) "a"(2), (3) and (4) for piping. A tank greater than ten years old without cathodic protection must be assessed to ensure the tank is structurally sound and free of corrosion holes prior to adding cathodic protection. The assessment must be by internal inspection or another method determined by the department to adequately assess the tank for structural soundness and corrosion holes. NOTE regarding paragraph 135.21(2) "b": The following codes of practice may be used to comply with this paragraph:
- NACE International Standard Practice SP 0285, "External Control of Underground Storage Tank Systems by Cathodic Protection";
- NACE International Standard Practice SP 0169, "Control of External Corrosion on Underground or Submerged Metallic Piping Systems";
- National Leak Prevention Association Standard 631, Chapter C, "Internal Inspection of Steel Tanks for Retrofit of Cathodic Protection"; or
- American Society for Testing and Materials Standard G158, "Standard Guide for Three Methods of Assessing Buried Steel Tanks."
- (2) Spill and overfill prevention equipment. To prevent spilling and overfilling associated with product transfer to the UST system, all UST systems with field-constructed tanks and airport hydrant systems must comply with new UST system spill and overfill prevention equipment requirements specified in paragraph 135.3(1) "c."
- c. Walkthrough inspections. In addition to the walkthrough inspection requirements in subrule 135.4(13), owners and operators must inspect the following additional areas for airport hydrant systems at least once every 30 days if confined space entry according to the Occupational Safety and Health Administration (see 29 CFR

part 1910) is not required or at least annually if confined space entry is required and keep documentation of the inspection according to paragraph 135.4(13) "e."

- (1) Hydrant pits: visually check for any damage; remove any liquid or debris; and check for any leaks, and
- (2) Hydrant piping vaults: check for any hydrant piping leaks.
- d. Release detection. Owners and operators of UST systems with field-constructed tanks and airport hydrant systems must begin meeting the release detection requirements described in this subrule not later than October 13, 2021.
- (1) Methods of release detection for field-constructed tanks. Owners and operators of field-constructed tanks with a capacity less than or equal to 50,000 gallons must meet the release detection requirements in rule 567—135.5(455B).
- (2) Owners and operators of field-constructed tanks with a capacity greater than 50,000 gallons must meet either the requirements in rule 567—135.5(455B) (except paragraphs 135.5(4) "e" and "f" must be combined with inventory control as stated below) or use one or a combination of the following alternative methods of release detection:
 - 1. Conduct an annual tank tightness test that can detect a 0.5 gallon per hour leak rate;
- 2. Use an automatic tank gauging system to perform release detection at least every 30 days that can detect a leak rate less than or equal to 1 gallon per hour. This method must be combined with a tank tightness test that can detect a 0.2 gallon-per-hour leak rate performed at least every three years;
- 3. Use an automatic tank gauging system to perform release detection at least every 30 days that can detect a leak rate less than or equal to 2 gallons per hour. This method must be combined with a tank tightness test that can detect a 0.2 gallon-per-hour leak rate performed at least every two years;
- 4. Perform vapor monitoring (conducted in accordance with paragraph 135.5(4) "e" for a tracer compound placed in the tank system) capable of detecting a 0.1 gallon-per-hour leak rate at least every two years;
- 5. Perform inventory control (conducted in accordance with Department of Defense Directive 4140.25; ATA Airport Fuel Facility Operations and Maintenance Guidance Manual; or equivalent procedures) at least every 30 days that can detect a leak equal to or less than 0.5 percent of flow-through; and
 - Perform a tank tightness test that can detect a 0.5 gallon per hour leak rate at least every two years; or
- Perform vapor monitoring or groundwater monitoring (conducted in accordance with paragraph 135.5(4) "e" or "f," respectively, for the stored regulated substance) at least every 30 days; or
- 6. Another method approved by the department if the owner and operator can demonstrate that the method can detect a release as effectively as any of the methods allowed in subparagraph 135.21(2) "d"(2). In comparing methods, the department shall consider the size of release that the method can detect and the frequency and reliability of detection.
- (3) Methods of release detection for piping. Owners and operators of underground piping associated with field-constructed tanks less than or equal to 50,000 gallons must meet the release detection requirements in rule 567—135.5(455B). Owners and operators of underground piping associated with airport hydrant systems and field-constructed tanks greater than 50,000 gallons must follow either the requirements in rule 567—135.5(455B) (except paragraphs 135.5(4)"e" and "f" must be combined with inventory control as stated below) or use one or a combination of the following alternative methods of release detection:
- 1. Perform a semiannual or annual line tightness test at or above the piping operating pressure in accordance with the table below.

Maximum Leak Detection Rate Per Test Section Volume		
Test Section Volume	Semiannual Test—	Annual Test—
(Gallons)	Leak Detection Rate Not to Exceed	Leak Detection Rate Not to Exceed
	(Gallons Per Hour)	(Gallons Per Hour)
< 50,000	1.0	0.5
\geq 50,000 to $<$ 75,000	1.5	0.75

\geq 75,000 to $<$ 100,000	2.0	1.0
> 100.000	3.0	1.5

Piping segment volumes $\geq 100,000$ gallons not capable of meeting the maximum 3.0 gallon per hour leak rate for the semiannual test may be tested at a leak rate up to 6.0 gallons per hour according to the following schedule:

Phase in for Piping Segments ≥ 100,000 Gallons in Volume

First test Not later than October 13, 2021 (may use up to 6.0 gph leak rate)

Second test Between October 13, 2021, and October 13, 2024 (may use up to 6.0 gph leak rate)

Third test Between October 13, 2024, and October 13, 2025 (must use

3.0 gph for leak rate)

Subsequent tests After October 13, 2025, begin using semiannual or annual line testing according to the

Maximum Leak Detection Rate Per Test Section Volume table above

- 2. Perform vapor monitoring (conducted in accordance with paragraph 135.5(4) "e" for a tracer compound placed in the tank system) capable of detecting a 0.1 gallon per hour leak rate at least every two years;
- 3. Perform inventory control (conducted in accordance with Department of Defense Directive 4140.25, ATA Airport Fuel Facility Operations and Maintenance Guidance Manual; or equivalent procedures) at least every 30 days that can detect a leak equal to or less than 0.5 percent of flow-through, and
- Perform a line tightness test (conducted in accordance with paragraph 1 of this section using the leak rates for the semiannual test) at least every two years; or
- Perform vapor monitoring or groundwater monitoring (conducted in accordance with paragraph 135.5(4) "e" or "f," respectively, for the stored regulated substance) at least every 30 days; or
- 4. Another method approved by the department if the owner and operator can demonstrate that the method can detect a release as effectively as any of the methods allowed in paragraphs 1 through 3 of this section. In comparing methods, the department shall consider the size of release that the method can detect and the frequency and reliability of detection.
- (4) Record keeping for release detection. Owners and operators must maintain release detection records according to the recordkeeping requirements in subrule 135.5(6).
- e. Applicability of closure requirements to previously closed UST systems. When directed by the department, the owner and operator of a UST system with field-constructed tanks or airport hydrant system permanently closed before [the effective date of this rule] must assess the excavation zone and close the UST system in accordance with rule 567—135.15(455B) if releases from the UST may, in the judgment of the department, pose a current or potential threat to human health and the environment.
- ITEM 160. Strike "Rural Electrification Administration" wherever it appears in **567—Chapter 136** and insert "Rural Utilities Service" in lieu thereof.
 - ITEM 161. Amend subrule 136.1(4) as follows:
- **136.1(4)** The requirements of this chapter do not apply to owners and operators of farm or residential tanks of 1,100 gallons or less capacity <u>installed prior to July 1, 1987</u>, or any UST system described in 567—paragraph 135.1(3) "b" or "c." subparagraph 135.1(3) "c"(1), (3) or (4).
 - ITEM 162. Amend rule **567—136.3(455B)**, definition of "Accidental release," as follows:
- "Accidental release" means any sudden or nonsudden release of petroleum <u>arising</u> from <u>operating</u> an underground storage tank that results in a need for corrective action and/or compensation for bodily injury or property damage neither expected nor intended by the tank owner or operator.
 - ITEM 163. Rescind the definition of "Petroleum marketing firms" in rule 567—136.3(455B).
- ITEM 164. Amend subrule **136.6(4)**, first paragraph of the "Letter from Chief Financial Officer," as follows:

I am the chief financial officer of [insert: name and address of the owner or operator, or guarantor]. This letter is in support of the use of [insert: "the financial test of self-insurance," and/or "guarantee"] to demonstrate financial responsibility for [insert: "taking corrective action" and/or "compensating third parties for bodily injury and property damage"] caused by [insert: "sudden accidental releases" and/or or "nonsudden accidental releases" or "accidental releases"] in the amount of at least [insert: dollar amount] per occurrence and [insert: dollar amount] annual aggregate arising from operating (an) underground storage tank(s).

ITEM 165. Amend subrule **136.6(4)**, third paragraph of the "Letter from Chief Financial Officer," as follows:

A [insert: "financial test," and/or "guarantee"] is also used by this [insert: "owner or operator," or "guarantor"] to demonstrate evidence of financial responsibility in the following amounts under other EPA regulations or state programs authorized by EPA under 50 40 CFR Parts 271 and 145:

ITEM 166. Amend paragraph 136.8(2)"a"(2)"2" as follows:

2. The ["Insurer" or "Group"] is liable for the payment of amounts within any deductible applicable to the policy to the provider of corrective action or a damaged third party, with a right of reimbursement by the insured for any such payment made by the ["Insurer" or "Group"]. This provision does not apply with respect to that amount of any deductible for which coverage is demonstrated under another mechanism or combination of mechanisms as specified in rules 567—136.6(455B) to 136.11(455B) 567—136.17(455B).

ITEM 167. Amend subrule 136.9(2), third to fifth unnumbered paragraphs, as follows:

Whereas said Principal is required under Subtitle I of the Resource Conservation and Recovery Act (RCRA), Solid Waste Disposal Act, as amended, to provide financial assurance for [insert: "Taking corrective action" and/or "compensating third parties for bodily injury and property damage caused by" either "sudden accidental releases" or "nonsudden accidental releases"; if coverage is different for different tanks or locations, indicate the type of coverage applicable to each tank or location] arising from operating the underground storage tanks identified above, and

Whereas said Principal shall establish a standby trust fund as is required when a surety bond is used to provide such financial assurance;

Now, therefore, the conditions of the obligation are such that if the Principal shall faithfully ["take corrective action, in accordance with rule 567—135.7(455B) and the Director of the Iowa Department of Natural Resources instructions for," and/or "compensate injured third parties for bodily injury and property damage caused by" either "sudden accidental releases" or "nonsudden accidental releases" or "sudden and nonsudden"] accidental releases "accidental releases" arising from operating the tank(s) identified above, or if the Principal shall provide alternate financial assurance, as specified in 567—Chapter 136, within 120 days after the date the notice of cancellation is received by the Principal from the Surety(ies), then this obligation shall be null and void; otherwise it is to remain in full force and effect.

ITEM 168. Amend subrule 136.9(4) as follows:

136.9(4) The owner or operator who uses a surety bond to satisfy the requirements of rule 136.4 (455B) 567—136.4(455B) must establish a standby trust fund when the surety bond is acquired. Under the terms of the bond, all amounts paid by the surety under the bond will be deposited directly into the standby trust fund in accordance with instructions from the director under rule 136.23(455B) 567—136.21(455B). This standby trust fund must meet the requirements specified in rule 136.18(455B) 567—136.12(455B).

ITEM 169. Amend subrule **136.10(2)**, paragraph (2) of the "Irrevocable Standby Letter of Credit" as follows:

(2) your signed statement reading as follows: "I certify that the amount of the draft is payable pursuant to regulations issued under authority of Subtitle I of the Resource Conservation and Recovery Act of 1976 Solid Waste Disposal Act, as amended."

ITEM 170. Amend subrule **136.13(4)**, first paragraph of the "Letter from Chief Financial Officer," as follows:

I am the chief financial officer of [insert: name and address of local government owner or operator, or guarantor].

This letter is in support of the use of the bond rating test to demonstrate financial responsibility for [insert: "taking corrective action" and/or "compensating third parties for bodily injury and property damage"] caused by [insert: "sudden accidental releases" and/or or "nonsudden accidental releases" or "accidental releases"] in the amount of at least [insert: dollar amount] per occurrence and [insert: dollar amount] annual aggregate arising from operating (an) underground storage tank(s).

ITEM 171. Amend subrule **136.13(5)**, first paragraph of the "Letter from Chief Financial Officer," as follows:

I am the chief financial officer of [insert: name and address of local government owner or operator, or guarantor]. This letter is in support of the use of the bond rating test to demonstrate financial responsibility for [insert: "taking corrective action" and/or "compensating third parties for bodily injury and property damage"] caused by [insert: "sudden accidental releases" and/or or "nonsudden accidental releases" or "accidental releases"] in the amount of at least [insert: dollar amount] per occurrence and [insert: dollar amount] annual aggregate arising from operating (an) underground storage tank(s). This local government is not organized to provide general governmental services and does not have the legal authority under state law or constitutional provisions to issue general obligation debt.

ITEM 172. Adopt the following **new** subrule 136.13(8):

136.13(8) If the local government owner or operator fails to obtain alternate assurance within 150 days of finding that it no longer meets the requirements of the bond rating test or within 30 days of notification by the director of the department that it no longer meets the requirements of the bond rating test, the owner or operator must notify the director of such failure within 10 days.

ITEM 173. Amend subrule **136.14(5)**, first paragraph of the "Letter from Chief Financial Officer," as follows:

I am the chief financial officer of [insert: name and address of the owner or operator]. This letter is in support of the use of the local government financial test to demonstrate financial responsibility for [insert: "taking corrective action" and/or "compensating third parties for bodily injury and property damage"] caused by [insert: "sudden accidental releases" and/or or "nonsudden accidental releases" or "accidental releases"] in the amount of at least [insert: dollar amount] per occurrence and [insert: dollar amount] annual aggregate arising from operating (an) underground storage tank(s).

ITEM 174. Amend subrule **136.16(4)**, first to third unnumbered paragraphs of the "Letter of Chief Financial Officer," as follows:

I am the chief financial officer of [insert: name and address of local government owner or operator, or guarantor]. This letter is in support of the use of the local government fund mechanism to demonstrate financial responsibility for [insert: "taking corrective action" and/or "compensating third parties for bodily injury and property damage"] caused by [insert: "sudden accidental releases" and/or or "nonsudden accidental releases" or "accidental releases"] in the amount of at least [insert: dollar amount] per occurrence and [insert: dollar amount] annual aggregate arising from operating (an) underground storage tank(s).

Underground storage tanks at the following facilities are assured by this local government fund mechanism: [List for each facility: the name and address of the facility where tanks are assured by the local government fund]. [Insert: "The local government fund is funded for the full amount of coverage required under 567—136.4(455B) of the Iowa Administrative Code (IAC), or funded for part of the required amount of coverage and used in combination with other mechanism(s) that provide the remaining coverage," or "The local government fund is funded for ten five times the full amount of coverage required under 567—136.4(455B) IAC, or funded for part of the required amount of coverage and used in combination with other mechanism(s) that provide the remaining coverage," or "A payment is made to the fund once every year for seven years until the fund is fully funded and [name of local government owner or operator] has available bonding authority, approved through voter referendum, of an amount equal to the difference between the required amount of coverage and the amount held in the dedicated fund" or "A payment is made to the fund once every year for seven years until the fund is fully funded and I have attached a letter signed by the state attorney general stating that (1) the use of the bonding authority will not increase the local government's debt beyond the legal debt ceilings established by the relevant state laws and (2) prior voter approval is not necessary before use of the bonding authority".]

ITEM 175. Amend rule 567—136.22(455B) as follows:

567—136.22(455B) Release from the requirements. An owner or operator is no longer required to maintain financial responsibility under this chapter for an underground storage tank after the tank has been properly permanently closed or undergoes a change-in-service or, if corrective action is required, after corrective action has been completed and the tank has been properly permanently closed or undergoes a change-in-service as required by rule 567—135.15(455B).